

X-3

Date

Data sheet for Spencer Lab

Steam Supply to Building (digital gage)

Calc


Mbtu/hr

 $M = 10^6$ 

lbm/hr

(Btu/hr/h<sub>fg</sub>)

Steam Supply splits: (1) Heat water that circulates to terminal units (offices)

(2) Heat outside air for labs, halls, interior spaces

(1) U-tube heat exchanger (steam on shell side, water in tubes:

Water out		F	
Water retrn		F	
Pump flow	180 gpm		lbm/hr
Water $\Delta T$		F	

 $Q = m c_p \Delta T$ 

	Btu/hr
	Mbtu/hr

(2) Balance of steam supplied heats outside air

(3-story intakes on bldg near Academy St entrance)

An energy conservation metric is Btu/hr/ft<sup>2</sup>

Spencer occupied space (3 stories + basement):

Total square ft = 58,000

Btu/hr/ft<sup>2</sup>

--

Btu/ft<sup>2</sup> or

--

kw/m<sup>2</sup>

(This metric obviously depends on conditions. Smaller is better)