

PA2403416 – 171 Leakes Road, Truganina



Officer Assessment Report
Development Approvals & Design




Department
of Transport
and Planning

OFFICIAL



Contents

Executive Summary	3
Proposal	5
Application Process	5
Background – Subdivision	6
Proposal Summary	6
Subject Site and Surrounds	8
Site Description	8
Site Surrounds	8
Planning Provisions	10
Municipal Planning Strategy	10
Planning Policy Framework	10
Statutory Planning Controls	11
Applicable Zones	11
Applicable Overlay	11
Particular Provisions	12
Provisions that Require, Enable or Exempt a permit	12
General Requirements and Performance Standards	12
Other Strategic Considerations	12
Structure Plan	12
Referrals and Notice	14
Referrals	14
Municipal Council Comments	14
Informal Referrals	15
Notice	15
Assessment	16
Key Considerations	16
Strategic Direction and Land Use	16
Zoning and Built Form	16
Car Parking, Bicycles Storage and Other Services	17
Car Parking	17
Design Standards for Car Parking	17
Access, Traffic Movements and Circulation	17



Bicycles Facilities _____ 17

Waste _____ 17

Environmental Risks _____ 17

 Bushfire Risk _____ 17

Sustainability _____ 17

 Environmentally Sustainable Design (ESD) _____ 17

 Stormwater Management _____ 18

Other Matters _____ 18

Signs _____ 18

Recommendation _____ 19

 Prepared by: _____ 20

 Reviewed / Approved by: _____ 20

Executive Summary



Key Information		Details		
Application No:	PA2403416			
Received:	11/12/2024			
Statutory Days:	93			
Applicant:			c/- Aurecon	
Planning Scheme:	Wyndham			
Land Address:	171 Leakes Road, Truganina			
Proposal:	Use and development of the site for a Utility Installation (Data Centre) and display of directional signage			
Development Value:	\$ 119,318,934.00 m			
Why is the Minister responsible?	In accordance with the schedule to Clause 72.01 of the Planning Scheme, the Minister for Planning is the responsible Authority for an application for use and development of land to which Clause 53.22 – Significant Economic Development applies.			
Why is a permit required?	Clause	Control		Trigger
Zone:	Clause 37.07-7	Urban Growth Zone – Schedule 2		To use the land for the purposes of a ‘Utility Installation’ (Data Centre)
	Clause 37.07-11	Urban Growth Zone – Schedule 2		Construct a building or construct or carry out works
	Cluse 33.02-1	Industrial Zone 2 – Schedule 2		To use the land for the purposes of a ‘Utility Installation’ (Data Centre)
	Clause 33.02-4	Industrial Zone 2 – Schedule 2		Construct a building or construct or carry out works
Overlays:	N/A			
Particular Provisions:	Clause 52.05-12	Signs		For the display of more than one directional sign per premises
Cultural Heritage:	A CHMP is not required as the site is not within an area of Aboriginal Cultural Heritage Sensitivity.			
Total Site Area:	121,409	m²		
Height:	2	Storeys excluding plant		
	12.8m	Metres excluding plant		
Land Uses:	Dwellings	Office	Retail	Other
	-	-	-	Utility Installation (Data Centre)
Parking:	Cars	Motorcycles		Bicycles



	Building A – 54 spaces	N/A	Building A – 10 spaces
	Building B – 55 spaces	N/A	Building B – 20 spaces
Referral Authorities:	WorkSafe Victoria (s55 – determining) Head, Transport for Victoria (s55 – determining) Fire Rescue Victoria (informal) Wyndham City Council (informal)		
Public Notice:	Notice of the application under section 52 of the Act was not required because: • Pursuant to Clause 37.07-13, an application under any provision of this scheme which is generally in accordance with the precinct structure plan applying to the land is exempt from the notice requirements of section 52(1)(a), (b) and (d), the decision requirements of section 64(1), (2) and (3) and the review rights of section 82(1) of the Act, unless the schedule to this zone specifies otherwise. • There are no specific requirements in Schedule 2 to this zone relevant to 'General Industrial A' land. The Proposal is generally in accordance with the PSP as detailed further in this report, as such is exempt from the notice requirements. • Pursuant to Clauses 33.02-2 and 33.02-4 of the INZ2, an application for use of land or for buildings and works is also exempt from the notice requirements of section 52(1)(a), (b) and (d), the decision requirements of section 64(1), (2) and (3) and the review rights of section 82(1) of the Act.		
Delegates List:	Approval to determine under delegation received on 19 March 2025 .		



Application Process

1. The key milestones in the application process were as follows:

Milestone	Date
Development Facilitation Pre-application meeting Ref PPA-27 (DTP, Wyndham Council & applicant)	9/11/2023
Application lodgement	11/12/2024
Decision Plans	Plans prepared by Metier Architects, titled ‘Development Application 171 Leakes Rd, Truganina, VIC 3029’ Rev C and dated 09/02/2024. Demolition Plan Building A & B prepared by Metier Architects, Rev D, dated 18/04/2024 Landscape Plans prepared by Arcadia, dated December 2023
Other Assessment Documents	Acoustic Environmental Impact Assessment, Rev A.02 prepared by Aurecon, dated 23/01/2024 Contamination Memorandum prepared by Aurecon, Rev 1, dated 24/01/2024 Ecology Memorandum prepared by Aurecon, dated 04/10/2023 Green Travel Plan prepared by Aurecon, Rev A, dated 19/06/2024 Planning Report prepared by Aurecon, Rev A.03, dated 31/07/2024 Preliminary Hazard Analysis Building A & B, prepared by Aurecon, Rev A, dated 29/07/2024 Stormwater Management Plan prepared by Aurecon, Rev A, dated 30/07/2024 Stormwater Management Strategy prepared by Aurecon, Rev B, dated 03/09/2024 Sustainability Management Memorandum prepared by Aurecon, dated 22/02/2024 Sustainability Management Plan prepared by Aurecon, Rev A, dated 28/06/2024 Transport Impact Assessment prepared by Aurecon, Rev C, dated 01/08/2024 Tree Protection & Removal Plan prepared by Aurecon, dated 21/08/2024 Urban Context Report prepared by Metier Architects, Rev D, dated 24/01/2024 Waste Management Plan prepared by Aurecon, Rev A.02, dated 09/08/2024

2. The subject of this report is the decision plans (as described above).



Background – Subdivision

Previous

3. The land is currently subject to an existing subdivision permit for 73 lots. It is understood that a planning permit has been issued however the Plan of Subdivision has not been certified. The proposed application layout (73 lots) does not align with the Proposal.
4. The permit allows for multiple stages of subdivision to be progressively certified until 2025, with the Stage 1 to be certified in November 2023. As noted, Stage 1 has not been certified.

Proposed

5. A separate application to subdivide the subject land has been lodged with the Wyndham Council on 21 February 2024 for approval (Permit Reference Number WYP14490/24; Certification Reference Number WYS6209/24).
6. The proposed Plan of Subdivision consolidates the land into one lot and proposes to deliver the required roads in accordance with the PSP and Council requirements.
7. Development contributions as required by the PSP will be managed under the subdivision application. Contributions include a 10m tree reserve along Leakes Road (identified as Reserve No.1), a service road along the Leakes Road boundary and New Connector Road (identified as R3) along the southern site boundary are stipulated under the PSP. A loop road (identified as R2) connecting Balrook Way and Jarklan Street on the eastern site boundary is included per Council requirements.

Proposal Summary

8. Specific details of the application include:
 - The use and development of the site for a Utility Installation (Data Centre) with ancillary offices, the display of directional signage and car parking. Ancillary works to support the development include a substation to support the use and loading docks.
 - The proposal includes two buildings (Building A and B) which will operate independent of each other with the office buildings positioned prominent of the warehouse buildings, with both warehouses featuring an external plant area to service the use.
 - Each data centre will operate 24 hours a day, 7 days a week with approximately 60 staff members and 13 off-peak skeleton staff to maintain security and operations.
 - Each building site will contain an office space, fire pump, diesel generators, fuel depot, and a catcher room, MV room and generator yard to provide a backup source of power. A designated waste storage area will be provided the rear of the office buildings.
 - The data centres will be serviced by a proposed substation to supply power to the buildings and built to the Leakes Road front boundary. Backup power will be provided by diesel electrical generators located within the external plant area.
 - Each building will be accessible by internal two-way access roads and serviced by attendant car parks (for staff and visitors), bike spaces and loading facilities.
 - Building A will be located in the northern half of the site, oriented towards Leakes Road. Separate 12m wide entry and exit points will service the site and accessed via Leakes Road (westbound approach) through a proposed service road. Building B is proposed in the southern portion of the site and oriented towards the southern boundary where vehicular access is proposed via Pallarang Way.
 - The buildings will feature a range of external materials including colorbond metal panels finished in grey and cream along the top element of the buildings with concrete wall panels finished in a range of grey and cream

tones, as well as black louvres along the elevations to create the illusion of windows / openings, as well as glazing to the office buildings.

- Landscaped setbacks will be provided along both site frontages incorporating low groundcovers through to large tree plantings. Throughout the site the development will feature a mix of low-level landscaping, shade-trees and large trees around the car parking areas and accessways.
- A 2.7m high palisade-style security fence finished in black around the perimeter of the site. Lighting will also be featured around the site.
- Three direction signs to guide traffic flow through the site and located at the entry / exit points to the site.

9. The applicant has provided the following concept images of the proposal:



Figure 1: 3D Render image – North-West facade



Figure 2: 3D Render image – South facade



Figure 3: 3D Render image – East facade



Figure 4: 3D Render image – North façade – Leakes Road



Site Description

10. The site is located on the southern side of Leakes Road, between Palmers Road to the West and Amherst Drive to the East. Along the eastern boundary the site has connections to Balrook Way, Jarklan Street and Pallarang Way.
11. The existing site is vacant, generally flat and clear of any vegetation. No formal vehicle access is currently provided to the site from Leakes Road. Upon completion of the proposed development, access to the site will be via a new service road (westbound approach) along Leakes Road and via Pallarang Way running along the south boundary.
12. The site has a rectangular shape and measures 217.14m with a depth of 559.13m, with a total size of 12.15 hectares.
13. The site is formally described as comprising the following land parcels:
 - Lot 3 on Plan of Subdivision 133719 Volume 09395 Folio 748
14. There are no easements, restrictions or reserves on the site. A notice Section 45 Melbourne Strategic Assessment (Environmental Mitigation Levy) 2020 AT390578W 01/07/2020 is registered on Title. The payable MSA Levy will be confirmed with the Department of Energy, Environment and Climate Action (DEECA) and will be paid prior to the issue of a building permit.
15. The subject site is located within the Truganina Employment Precinct Structure Plan (PSP) and identified as 'General Industrial A' land under the PSP.

Site Surrounds

16. The surrounding development consists mainly of light industrial uses such as large warehouse and distribution centres, truck rentals and truck repair centres.
17. Development surrounding the site can be described as follows:
 - To the **north** of the site is Leakes Road which is a four-lane wide arterial road with a pedestrian walkway and bike path running adjacent. Land across from Leakes Road accommodates a substation and an Amart Furniture distribution centre.
 - To the **south** and **west** of the site, land is vacant.
 - To the **east** of the site, land accommodates a two-storey warehouse development, an end-to-end ecommerce logistics business and a truck yard.
18. A site inspection of the subject site and surrounds was undertaken on **7 February 2025**. Images of the site and surrounds are reflected in **Figures 5-8**.



Figure 5: View of site from Leakes Road facing south




Figure 6: View of Leakes Road looking north-west facing south



Figure 7: View of site from Pallarang Way facing west



Figure 8: View of site from Balrook Way facing north- west



Municipal Planning Strategy

19. The following objectives and strategies of the Municipal Strategic Statement of the scheme are relevant to the proposal:

Clause	Description
02.01	Context
02.02	Vision
02.03-1	Settlement
02.03-3	Environmental Risks and Amenity
02.03-7	Economic Development

Planning Policy Framework

20. The following objectives and strategies of the Planning Policy Framework of the scheme are relevant to the proposal:

Clause 11	Settlement
11.01-1R	Settlement – Metropolitan Melbourne
11.03-2S	Growth Areas
Clause 13	Environmental Risks and Amenity
13.05-1S	Noise Management
13.07-1S	Land Use Compatibility
Clause 15	Built Environment and Heritage
15.01-1S	Urban Design
15.01-1L-01	Landscaping
15.01-1L-02	Signs
15.01-2S	Building Design
5-01-2L-01	Environmentally Sustainable Development
15.01-2L	Industrial and Commercial Design
Clause 17	Economic Development
17.01-1	Employment
17.01-1S	Diversified Economy – Metropolitan Melbourne
Clause 19	Infrastructure
19.03-1S	Development and Infrastructure Contributions Plans
19.03-3S & 19.03-3L	Integrated Water Management

21. The assessment section of this report provides a detailed assessment of the relevant planning policies



Statutory Planning Controls

Applicable Zones

22. A planning permit is required to use land for utility installation (Data Centre) and to construct a building or construct or carry out works in accordance with Clause 37.07-9 and 37.07-11 of the UGZ2 and Clause 33.02-1 and Clause 33.02-4 of the INZ2, respectively.
23. The purpose of the **UGZ2** is:
- *To implement the Municipal Planning Strategy and the Planning Policy Framework.*
 - *To manage the transition of non-urban land into urban land in accordance with a precinct structure plan.*
 - *To provide for a range of uses and the development of land generally in accordance with a precinct structure plan.*
 - *To contain urban use and development to areas identified for urban development in a precinct structure plan.*
 - *To provide for the continued non-urban use of the land until urban development in accordance with a precinct structure plan occurs.*
 - *To ensure that, before a precinct structure plan is applied, the use and development of land does not prejudice the future urban use and development of the land.*
24. The purpose of the **INZ2** is:
- *To implement the Municipal Planning Strategy and the Planning Policy Framework.*
 - *To provide for manufacturing industry, the storage and distribution of goods and associated facilities in a manner which does not affect the safety and amenity of local communities.*
 - *To promote manufacturing industries and storage facilities that require a substantial threshold distance within the core of the zone.*
 - *To keep the core of the zone free of uses which are suitable for location elsewhere so as to be available for manufacturing industries and storage facilities that require a substantial threshold distance as the need for these arises.*
25. The following sections include a discussion of how the proposal responds to these requirements.

Applicable Overlay

26. The subject site is affected by the Development Contributions Plan Overlay – Schedule 9 (DCPO9).
27. The purpose of the DCPO is:
- *To implement the Municipal Planning Strategy and the Planning Policy Framework.*
 - *To identify areas which require the preparation of a development contributions plan for the purposes of levying contributions for the provision of works, services and facilities before development can commence.*
28. Development contributions required under the Overlay will be negotiated and confirmed as part of the separate subdivision application (referenced in point 5 above) managed through Wyndham Council.



Particular Provisions

Provisions that Require, Enable or Exempt a permit

29. Clause 52.05 sets out the requirements for signage. Pursuant to Clause 52.05-12, a permit is required for the display of more than one directional sign per premises.
30. Clause 52.06 sets out the requirements of car parking provision and design. Clause 52.06-5 (Table 1 - Car parking requirement) does not include the land use 'data centre', as such pursuant to Clause 52.06-6, car parking spaces must be provided to the satisfaction of the responsible authority.

General Requirements and Performance Standards


31. Clause 53.10 applies to uses with adverse amenity potential. The Proposal includes the storage of diesel in quantities of approximately 250kL, which is less than the threshold limit set out in the Table to Clause 53.10-2 (2000 tonnes). Accordingly, there is no referral required under Clause 53.10-1 to the Environment Protection Authority.
32. Clause 53.18 applies to the buildings and works of this application. The clause includes standards and objectives relating to stormwater management. The proposed site is located within Melbourne Water's Doherty's Drain Development Services Scheme (DSS) as detailed in the Stormwater Management Plan. The DSS ensures planning for urban development is conducted on a catchment wide basis and meets appropriate standards for flood protection and environmental performance, including protection and enhancement of water and biodiversity values. The Applicant will continue to engage with Melbourne Water and Wyndham Council throughout the design and development phase (separate to this planning application) and prior to lodgement of any subdivision plans to ensure all stormwater management is appropriate and avoids potential impacts.
33. Clause 53.22 Significant Economic Development seeks to:
 - *To prioritise and facilitate the planning, assessment and delivery of projects that will make a significant contribution to Victoria's economy and provide substantial public benefit, including jobs for Victorians.*
 - *To provide for the efficient and effective use of land and facilitate use and development with high quality urban design, architecture and landscape architecture.*
34. The proposal is submitted under Category 1, having met the relevant conditions and eligibility criteria of this Clause.

Other Strategic Considerations

Structure Plan

35. The subject site is located within the Truganina Employment PSP, 19 kilometres west of central Melbourne along the West Gate Transport Corridor within the City of Wyndham. The precinct is part of the Western Industrial Node – one of Melbourne's three major industrial nodes – which extends from Yarraville to Derrimut to form one of Australia's largest, contiguous industrial areas.
36. The vision for the Truganina Employment PSP area is:

“To provide diverse employment opportunities for Wyndham and the western region of Melbourne by establishing a thriving industrial employment precinct that extends west Western Industrial Node and provides for a wide range of businesses and jobs. The precinct will comprise quality industrial park developments with a logistics bias and have strong links to industrial activity centres and future higher order services.”
37. The subject site has been categorised as 'General Industrial A' land which dictates that the predominant land use will accommodate industrial and manufacturing uses. Heavy and general industry, manufacturing, logistics and other related activities may be located in this area.

- 
38. The subject site has a total area of 13.15 ha, of which 11.93 ha is developable under the PSP and 0.22 ha is encumbered by a designated tree reserve along Leakes Road. The tree reserve, required under the PSP, will be designed and delivered via the proposed subdivision application separate to this planning application.



Referrals

39. The application was referred to the following groups:

Provision / Clause	Organisation	Response and date received
Section 55 Referral – Determining	WorkSafe Victoria	No objection – subject to conditions on 28/02/2025
Section 55 Referral – Determining	Head, Transport for Victoria	No objection – subject to conditions on 12/02/2025

40. WorkSafe's conditions require that prior to the Applicant obtaining Building Permit Approval, they must:

- In consultation with the relevant fire authority's Dangerous Good Unit, undertake a fire safety study to design a suitable fire protection system for the proposed facility
- Seek and have regard to written advice from the relevant fire authority's Dangerous Goods unit regarding a suitable fire protection system for the facility;
- Seek and have regard to written advice from the relevant fire authority's Dangerous Goods unit regarding a suitable emergency plan for the facility.

41. WorkSafe also drew attention that the proposed development will need to ensure compliance with the relevant requirements of the Dangerous Goods Act 1985 and its subordinate legislation, prior to commencement of operations.

42. It is noted WorkSafe provided a revised set of conditions with updated wording on 03/04/2025 for inclusion on the permit.

Municipal Council Comments

43. The **Wyndham** City Council (the council) reviewed the application and raised no objection to the issue of a planning permit. Council provided comment around landscaping, sustainable design, drainage engineering and technical engineering requirements. A set of without prejudice draft conditions have also been provided by the Council, the majority of which have been accepted and adopted into the permit.

44. The following are conditions recommended by Council which have not been included on the permit and reasoning as to why, as follows:

- Condition 1 a) i) - Consistent with the two previous planning applications approved by DTP for data centres by the same Applicant (Ref PA2403014 & PA2403016), separate office elevations and specific details on glazing cannot be provided due to the secure nature of the operation. Additionally, typical office spaces required for more labour-intensive activities are not necessary for a data centre use and thus, minimal glazing is employed in the design. The majority of the office spaces will consist of non-functional areas, primarily housing technology equipment, which for security reasons, cannot include openings. Where available, windows have been included in the design to the office spaces, and black louvres along the elevations to create the illusion of windows / openings. The submission of office plans at a scale of 1:500 is consistent with the previous planning applications approved by DTP.
- Condition 1 a) ii) - Consistent with the two previous planning applications approved by DTP, the development will implement the recommendations of the Sustainability Management Plan via a condition of permit. Specific details on shading devices will be implemented via the Sustainability Management Plan.
- Condition 1 a) iii) - Consistent with the two previous planning applications approved by DTP, the Town Planning drawings accompanying the planning application identify 11 car spaces to each data centre building with EV charging facilities. The spaces do not impede pedestrian access.

- Condition 1 a) iv) - Bicycle spaces are not a requirement for this land use (data centre); however, each data centre will have a bicycle cage with visitor spaces (9 parking spaces for Building A and 20 parking spaces for Building B). This approach is consistent with the two previous planning applications approved by DTP.
- Condition 1 a) v) - Consistent with the two previous planning applications approved by DTP, the development will implement the recommendations of the Sustainability Management Plan via a condition of permit.
- Condition 1 a) vi) – See justification below provided for Condition 6
- Condition 3 – The landscaping plan will not require approval by Wyndham City Council, rather DTP as the Responsible Authority.
- Condition 5 - Consistent with the two previous planning applications approved by DTP, no screening will be installed around the substation. The substation ('minor utility installation') is exempt from requiring a planning permit Clause 62.01 (Uses not requiring a permit) and Clause 62.02 (Buildings and works) of the Wyndham Planning Scheme and therefore is not included in this planning application.
- Condition 6 - Consistent with the two previous planning applications approved by DTP, this level of sustainability measure is not required for the proposed data centre application.
- Condition 15 & 16 - There is no native vegetation on the land. The planning application does not include the removal of vegetation that triggers a planning permit.
- Conditions 17-20, 25 & 26 – These conditions go beyond the scope of works considered in the planning application and relate to matters addressed under the subdivision application WYP14490/24.
- Conditions 39-46 - Only directional signage is proposed as part of the planning application and therefore, conditions 39-46 go beyond the scope of the planning application.

Informal Referrals

45. The application was referred informally to Fire Rescue Victoria (FRV). FRV had no comment to make on the application and recommended a condition relating to a Fire Safety Study be included on the permit. The condition has been reviewed and accepted by the applicant for inclusion on the permit.

Notice

46. The application is exempt from the notice requirements of section 52(1)(a), (b) and (d), the decision requirements of section 64(1), (2) and (3) and the review rights of section 82(1) of the *Planning and Environment Act 1987* pursuant to the following provisions:
 - Pursuant to Clause 37.07-13, an application under any provision of this scheme which is generally in accordance with the precinct structure plan applying to the land is exempt from the notice requirements of section 52(1)(a), (b) and (d), the decision requirements of section 64(1), (2) and (3) and the review rights of section 82(1) of the Act, unless the schedule to this zone specifies otherwise.
 - There are no specific requirements in Schedule 2 to this zone relevant to 'General Industrial A' land. The Proposal is generally in accordance with the PSP as detailed further in this report, as such is exempt from the notice requirements.
 - Pursuant to Clauses 33.02-2 and 33.02-4 of the INZ2, an application for use of land or for buildings and works is also exempt from the notice requirements of section 52(1)(a), (b) and (d), the decision requirements of section 64(1), (2) and (3) and the review rights of section 82(1) of the Act.



Key Considerations

47. The following are deemed the key considerations in assessing the acceptability of the proposal:

- Proposal responds to the Municipal Planning Strategy and Planning Policy Framework of the Wyndham Planning Scheme
- Proposal responds to the objectives and decision guidelines of the applicable zoning and overlays
- Proposed parking provision and signage is acceptable

Strategic Direction and Land Use

48. The *Planning Policy Framework* encourage appropriate land use and development which enhances the built environment, supports economic growth, meets the community expectations on retail and commercial provision, delivers diversity in housing supply to meet existing and future needs, and integrates transport and infrastructure planning.

49. The relevant MPS and PPF policies have been considered in assessing the application.

50. The proposed land use is consistent with the strategic direction of the following policies:

- In accordance with *Clause 11.03-2S Growth Areas*, the proposal supports the ongoing growth of the Truganina Employment Precinct by creating jobs and attracting similar 'new technology' projects in the area.
- In accordance with *Clause 13 Environmental Risks and Amenity*, the proposal will not have any detrimental impacts to the amenity of the surrounding area, as there are no sensitive uses adjoining or nearby in the area. Utilising the land for a data centre is consistent with the intended use of the land under the relevant PSP which designates the area for heavy and general industry, manufacturing and logistics.
- The proposal is consistent with the provisions of *Clause 15 Built Environment and Heritage* as it provides a modern and architecturally designed development which will enhance the amenity of the area. The main considerations around the building layouts and design are security and functionality to protect the development from threats that could comprise its confidentiality and availability of business information assets or intellectual property. The built form and façade treatment responds to the immediate context of the site using a range of contemporary building materials and finishes such as vertical metal ribbing and textured concrete panelling.
- Native and draught tolerant species are proposed for landscaped areas, as well as trees to the Leakes Road and Pallarang Way boundaries.
- In accordance with *Clause 17.01-1 Employment* supports the objectives of the West Growth Area Corridor Plan and PSP which aims to provide diversified employment opportunities close to where people live. The proposal provides industrial employment opportunities for nearby residential areas west of Palmers Road.

Zoning and Built Form

51. The zoning provisions have been considered in the application.

52. The purpose of the zoning has been considered, and it is noted that site is located within an industrial precinct where development is encouraged to provide for manufacturing industry, the storage and distribution of goods and associated facilities in a manner which does not affect the safety and amenity of local communities. The data centre is directly in line with this objective and will aid in the creation and retention of more than 60 permanent operational employment positions and a significant number of construction jobs as well as providing valuable connective infrastructure to support regional industry and commerce.

53. The proposal is in accordance with the decision guidelines of the zoning, as the proposal is in line with the MPS & PPF, the use is unlikely to cause amenity impacts to the surrounding area. Further, the drainage of the land has



been reviewed by Council and the land has availability and connection to services. Traffic to be generated on roads is not expected to notably impact the capacity or safety of the surrounding road network.

Car Parking, Bicycles Storage and Other Services

Car Parking

54. Clause 52.06-5 (Table 1 - Car parking requirement) does not include the land use 'data centre', as such pursuant to Clause 52.06-6, car parking spaces must be provided to the satisfaction of the responsible authority. 30 staff members are proposed within each building A & B with 53 car parking spaces provided to each. The anticipated car parking demand is comfortably met by the proposal, as such the proposal provides a satisfactory number of car parking spaces.

Design Standards for Car Parking

55. The proposal includes a Transport Impact Assessment which outlines that all relevant design standard for car parking as outlined in Clause 52.06-9 have been met.

Access, Traffic Movements and Circulation

56. The Building A and Building B main car park has a 7.5 m wide two-way access, with the Building B access having a 0.5 m wide median and boom gate control for entry and exits.

Bicycles Facilities

57. Clause 52.34-1 of the Scheme does not require bicycle parking for data centres (or any uses under the utility installation land use group) and therefore there is no bicycle parking requirement.
58. Notwithstanding the above, the proposal provides 10 bicycle spaces for Building A and 20 for Building B, as well as 2 shower facilities for Building A and 3 for Building B.

Waste

59. A waste management plan has been provided. Council has reviewed the plan and requested further detail be provided which will be attended to via conditions on the permit.

Environmental Risks


Bushfire Risk

60. The subject site is located within a Bushfire Prone Area. Minimum construction standards to prevent bushfire risk within Bushfire Prone Areas only apply to sensitive developments for example schools, childcare facilities, aged care facilities and places of assembly. The Proposal is not required to consider bushfire risk as the use and development is not sensitive.
61. None the less, two fire pumps and four fire water tanks will be provided beside each main building. There will also be standard fire safety equipment provided within the buildings to ensure the safety of those on site as well as adjoining properties.

Sustainability

Environmentally Sustainable Design (ESD)

62. This Proposal includes a Sustainability Management Plan which outlines sustainability objectives to be met during the construction and operation of the Proposal. The development incorporates a number of sustainable design



initiatives that address the whole life of the building from conception through to construction and operation, these include:

- Green Star rating equivalent
- Bicycle parking with end of trip facilities to encourage sustainable modes of transport
- Greenhouse gas emissions – the proponent has made a commitment to 100% renewable energy for all operations by 2025
- Energy consumption
- Water use, including on-site irrigation, measures to minimise consumption, use of low flow fittings and meeting the current best practice performance objectives for stormwater quality as contained in the Urban Stormwater – Best Practice Environmental Management Guidelines (Victorian Stormwater Committee, 1999).
- Urban heat, including non-roof measures such as maximising tree planting and material selection for pavement and roofing

Stormwater Management

63. The Proposal includes an area on the site for stormwater management to help treat stormwater flows generated by the site.
64. The council recommended several conditions that address stormwater requirements which have also been reviewed and accepted by the Applicant for inclusion on the permit.
65. Subject to the above conditions, the proposal will result in appropriate stormwater outcomes.

Other Matters

Signs

66. Three direction signs to guide traffic flow through the site and located at the entry / exit point to the site. The signs will have a display area of 0.3sqm, will measure 300mm above ground, with a total height of 800mm. The signs are of an appropriate scale and design to their purpose and will be appropriately sited to avoid driver conflict and will not be illuminated.

Recommendation



67. The proposal is generally consistent with the relevant planning policies of the Wyndham Planning Scheme and will contribute to the provision of utility installation (data centre) within the Truganina area.
68. The proposal is generally supported by the various formal and informal referral agencies.
69. It is recommended that a Delegate for the Minister of Planning issue Planning Permit No. PA2403416 for the use and development of the site for a Utility Installation (Data Centre) and display of directional signage at 171 Leakes Road, Melbourne, subject to conditions.
70. It is recommended that the applicant and the council be notified of the above in writing.

Prepared by:

I have considered whether there is a conflict of interest in assessing this application and I have determined that I have:

- ☒ **No Conflict**
- ☐ Conflict and have therefore undertaken the following actions:
- ☐ Completed the **Statutory Planning Services declaration of Conflict/Interest form**.
- ☐ Attached the Statutory Planning Services declaration of Conflict/Interest form on to the hardcopy file.
- ☐ Attached the Statutory Planning Services declaration of Conflict/Interest form into the relevant electronic workspace.

Name:

Title: Planner, Development Approvals and Design

Signed:

Phone:

Dated: 19 March 2025

Reviewed / Approved by:

I have considered whether there is a conflict of interest in assessing this application and I have determined that I have:

- ☒ **No Conflict**
- ☐ Conflict and have therefore undertaken the following actions:
- ☐ Completed the **Statutory Planning Services declaration of Conflict/Interest form**.
- ☐ Attached the Statutory Planning Services declaration of Conflict/Interest form on to the hardcopy file.
- ☐ Attached the Statutory Planning Services declaration of Conflict/Interest form into the relevant electronic workspace.

Name:

Title: Manager, Development Approvals and Design

Signed:

Phone:

Dated: 25 March 2025