Capping the Capacity Market: A Supply Function Equilibrium Analysis of Price Controls in PJM

April 19, 2026

Abstract

In January 2025, Pennsylvania Governor Josh Shapiro negotiated a settlement reshaping PJM's capacity market demand curve: a price cap at \$325 per megawatt-day (MW-day) of unforced capacity (UCAP) and a price floor at \$175/MW-day UCAP for the 2026/27 and 2027/28 delivery years, projected to save consumers over \$21 billion. I evaluate this intervention using a Supply Function Equilibrium (SFE) model calibrated to all seven completed Base Residual Auctions (BRAs). Under the maintained assumption of $K \leq 3$ collectively pivotal suppliers, the model's equilibrium lies in an at-cap regime in which the Holmberg boundary condition mechanically fixes the clearing price at the Variable Resource Requirement (VRR) Point (a) value, so the 2026/27 and 2027/28 outcomes are consistent with the model's structural regime rather than an independent forecast of the dollar price. The substantive quantitative result is the binding gap between the VRR Point (a) value (\$329/MW-day in 2026/27) and the settlement cap (\$325/MW-day)—\$4–\$8/MW-day at the Regional Transmission Organization (RTO) level, with larger gaps in constrained Locational Deliverability Areas (LDAs)—and the transition from at-cap to interior clearing between $K = 3$ and $K = 4$. Using the SFE rather than the unconstrained VRR Point (a) as the counterfactual, the implied two-year RTO-level revenue transfer is approximately \$612 million, roughly 35 times smaller than the \$21 billion figure, which rests on the design-level cap as the but-for price.

1 Introduction

On December 30, 2024, the Commonwealth of Pennsylvania filed a complaint with the Federal Energy Regulatory Commission (FERC) alleging that PJM's capacity auction demand curve was miscalibrated, with its price cap set too high given near term expectations for new entry. The complaint cited PJM's July 2024 Base Residual Auction for the 2025/26 delivery year, which cleared at \$269.92/MW-day, an increase of more than 800 percent from the prior year, as evidence that the existing market design imposed unnecessary costs on 65 million consumers across 13 states (Office of Governor Josh Shapiro, 2025). Six weeks later, on January 28, 2025, Governor Josh Shapiro announced an agreement with PJM in which the demand curves for the 2026/27 and 2027/28 auctions would be modified to impose a price cap of approximately \$325/MW-day UCAP and a price floor of approximately \$175/MW-day UCAP, applied to both the RTO and all constrained Locational Deliverability Areas (Bresler and Keech, 2025). The agreement was projected to save consumers over \$21 billion over the two delivery years.

The settlement reshapes PJM's VRR demand curve by imposing a cap at $\bar{p}_S \approx$ \$325/MW-day below the existing design-level cap at Point (a), and adding a floor at $\bar{p}_f \approx$ \$175/MW-day (Section 3). This paper asks what price PJM's 2026/27 and 2027/28 auctions would have cleared at absent the settlement modification, and what the consequences of suppressing prices to $\bar{p}_S$ are.

I answer the question using a calibrated SFE model of the PJM Base Residual Auction. In the model, K symmetric strategic sellers simultaneously submit supply functions against PJM's VRR demand curve, which is publicly known before bidding. Following Klemperer and Meyer (1989) and Green and Newbery (1992), equilibrium is characterized by a first order ordinary differential equation (ODE) system in the sellers' supply functions, integrated backward from the capacity constrained boundary. Equilibrium selection imposes the Holmberg boundary condition, requiring each seller's supply function to equal installed capacity at the VRR Point (a) cap. This criterion is motivated by Holmberg (2008)'s uniqueness result

for stochastic markets; in the deterministic BRA it is imposed as a selection device. Because the boundary condition forces $p^* = \bar{p}$ whenever it is active, the 2026/27 and 2027/28 at-cap outcomes are consistent with the maintained assumption of $K \leq 3$ strategic sellers but do not independently test the dollar value of the clearing price; the model's substantive content is the *regime*—at-cap versus interior—and its dependence on K, together with the markup level when the equilibrium is interior. I calibrate the model to all seven completed BRA delivery years (2021/22 through 2027/28) using published PJM planning parameters, BRA clearing results, and Independent Market Monitor (IMM) State of the Market cost data. The SFE equilibrium price p^* is the counterfactual clearing price under strategic bidding against the unmodified VRR curve; when the boundary condition is active, p^* equals the design-level Point (a) cap by construction, which is what distinguishes the SFE counterfactual from the VRR Point (a) benchmark used in the settlement's $21 billion savings figure.

The remainder of the paper is organized as follows. Section 2 reviews the literature. Sections 3–5 describe the institutional setting, model, and calibration. Section 6 presents the main results and comparative statics. Section 7 discusses the allocative implications of the price band for investment signaling. Section 8 evaluates the $21 billion claim. Section 9 concludes.

2 Literature Review

The supply function equilibrium concept, introduced by Klemperer and Meyer (1989), considers an oligopoly in which each firm commits to a schedule mapping prices to quantities before demand is realized. Unlike Bertrand or Cournot competition, the supply function strategy allows each firm to adapt its output to whatever market price emerges after the demand shock is realized. Klemperer and Meyer show that symmetric Nash equilibria are characterized by a first-order differential equation whose solutions form a continuum between the competitive schedule and the Cournot schedule, with demand uncertainty disciplining

firms to choose upward-sloping supply functions.

Green and Newbery (1992) apply the Klemperer-Meyer framework to the England and Wales electricity market, establishing the methodological template followed here: derive the symmetric ODE, integrate backward from the capacity-constrained boundary, and calibrate to observed market structure. Holmberg (2008) shows that in capacity-constrained electricity markets, the supply function equilibrium is unique when rivals' capacity constraints simultaneously bind, tying the ODE boundary condition and selecting a unique equilibrium trajectory. This paper applies that boundary condition as an equilibrium selection device in the deterministic BRA. For the asymmetric extension, Anderson and Hu (2008) provide a convergent iterative algorithm; Holmberg (2007) establishes existence and uniqueness results for the constant-marginal-cost, asymmetric-capacity case. Rudkevich et al. (1998) provide an early application of supply function analysis to competitive poolco electricity markets, bridging the canonical Klemperer–Meyer theory and applied generation-market modeling. The symmetric case applies here and I solve the ODE backward from the Holmberg boundary using the `deSolve` package in R.

The capacity market design literature originates from the "missing money" problem: competitive energy markets, subject to regulatory price caps, suppress the scarcity rents that would otherwise finance investment in peaking generation (Joskow and Tirole, 2007; Joskow, 2008). PJM's Variable Resource Requirement curve is a downward-sloping administrative demand schedule designed to moderate the extreme price volatility that vertical demand generates near the reliability threshold (Bowring, 2013). This paper takes the VRR design as given and analyzes how its slope governs strategic markup opportunities under concentrated supply.

Weitzman (1974) shows that the choice between price and quantity regulatory instruments depends on the relative slopes of marginal benefit and marginal cost. When supply is inelastic in the short run, price instruments dominate. Glaeser and Luttmer (2003) demonstrate that binding price controls in imperfectly competitive markets generate misallocation qualitatively

different from the standard deadweight triangle. In the SFE literature, the analysis in Section 7 draws on these results to characterize the allocative consequences of the settlement's price band. Cramton and Stoft (2005) emphasize that the capacity market's primary function is to provide a long-run investment signal. A binding cap disrupts this signal precisely when it is most informative.

3 Institutional Background

PJM Interconnection operates the largest competitive wholesale electricity market in North America, coordinating approximately 182,000 megawatts of generating capacity across thirteen states and the District of Columbia. PJM implemented the Reliability Pricing Model (RPM) in 2007 to address the "missing money" problem: a forward capacity market in which suppliers submit offers against a downward-sloping administrative demand schedule, the VRR curve, and the market clears at a uniform price (Bowring, 2013; PJM Interconnection, L.L.C., 2025; Pfeifenberger et al., 2011). The primary procurement mechanism is the Base Residual Auction. Capacity procurement occurs separately for Locational Deliverability Areas, geographic sub-regions constrained by transmission import limits. The Capacity Emergency Transfer Limit (CETL) governs the maximum competitive imports available to each LDA (PJM Interconnection, L.L.C., 2024). The panel covers the RTO and sixteen sub-LDAs across delivery years 2021/22 through 2027/28.

The VRR curve is the administrative demand schedule presented to sellers in each BRA (PJM Interconnection, L.L.C., 2025). Under the old design (delivery years 2021/22 to 2025/26), it is defined by three anchor points: Point (a), the price cap at $1.5 \times$ Net CONE, Point (b) at $0.75 \times$ Net CONE at the reliability requirement, and Point (c) at zero price above the reliability requirement (Bowring, 2013; Pfeifenberger et al., 2011). The Net Cost of New Entry (Net CONE) is the annualized cost of a reference generating unit, net of projected energy and ancillary service revenues, computed independently for each LDA (PJM

Interconnection, L.L.C., 2024). FERC approved a restructured VRR curve design in 2025 (Federal Energy Regulatory Commission, 2025), taking effect with the 2026/27 delivery year. The redesign added a fourth anchor point creating an explicit price floor at approximately \$177–\$179 per MW-day, eliminating the collapse to zero price for surplus capacity.

Table 1 documents the BRA timeline and RTO clearing outcomes for all seven completed auctions in the sample. Both auctions conducted under the new VRR design (2026/27 and 2027/28) cleared at exactly the Point (a) price cap, motivating the SFE analysis in Sections 4–6.

Table 1: PJM Base Residual Auction Timeline and RTO Clearing Outcomes, 2021/22 to 2027/28

Delivery Year	BRA Date	Lead (mo.)	Clearing (\$/MW-day)	Net CONE (\$/MW-day)	VRR Design	At Cap
2021/22	May 2018	37.0	\$140.00	\$321.57	Old	No
2022/23	May 2021	12.5	\$50.00	\$260.50	Old	No
2023/24	July 2022	11.0	\$34.13	\$274.96	Old	No
2024/25	May 2024	0.8	\$28.92	\$293.19	Old	No
2025/26	August 2024	9.9	\$269.92	\$228.81	Old	No
2026/27	July 2025	10.2	\$329.17	\$212.14	New	Yes
2027/28	January 2026	16.8	\$333.44	\$242.52	New	Yes

Note: Prices in nominal dollars per MW-day. "At Cap" indicates the RTO clearing price equaled the Point (a) price cap. Source: PJM BRA results and planning parameters.

BRA lead times compressed from 37 months (2021/22) to 0.8 months (2024/25) before partial restoration to 10.2 and 16.8 months for the settlement years (Table 1).

PJM's primary market power mitigation mechanism is the Three Pivotal Supplier (TPS) test. Supplier i is *pivotal* in LDA ℓ if removing i's capacity would cause aggregate supply to fall short of the reliability requirement. The Residual Supply Index for k suppliers is defined

as

$$\mathrm{RSI}_k^\ell \;=\; \frac{\text{Total capacity in LDA } \ell \;-\; \text{Capacity of top-}k \text{ sellers}}{\text{Reliability requirement for LDA } \ell}. \tag{1}$$

Mitigation is triggered when $\mathrm{RSI}_1 < 1$ or $\mathrm{RSI}_3 < 1$, capping affected suppliers' offers at the Avoidable Cost Rate (ACR) (Bowring, 2013; Monitoring Analytics, LLC, 2026).

Table 2 summarizes TPS test outcomes across LDAs and delivery years. Three patterns stand out. First, RSI_3 falls below unity for every LDA and every delivery year, so the TPS mitigation threshold is met throughout the sample. Second, concentration is strikingly persistent (RTO RSI_3 ranges only 0.62–0.73 across six years). Third, the most extreme concentration appears in small sub-LDAs where a single seller can be individually pivotal ($\mathrm{RSI}_1 = 0$ in BGE and DEOK).

Table 2: TPS Test Results: Residual Supply Indices by LDA and Delivery Year

Delivery Year	LDA	RSI_1	RSI_3	Participants	All Pivotal
2022/23	RTO	0.81	0.73	130	Yes
2022/23	MAAC	0.69	0.37	25	Yes
2022/23	EMAAC	1.25	0.64	7	Yes
2022/23	COMED	0.43	0.36	14	Yes
2022/23	BGE	0.00	0.00	1	Yes
2022/23	DEOK	0.00	0.00	1	Yes
2023/24	RTO	0.78	0.68	134	Yes
2023/24	MAAC	0.78	0.40	11	Yes
2024/25	RTO	0.77	0.64	133	Yes
2024/25	MAAC	0.59	0.11	9	Yes
2024/25	EMAAC	0.48	0.00	2	Yes
2025/26	RTO	0.82	0.62	128	Yes
2026/27	RTO	0.82	0.64	153	Yes
2027/28	RTO	0.82	0.63	155	Yes

Note: "All Pivotal" indicates $RSI_1 < 1$ for each seller individually. Source: PJM IMM State of the Market reports, various years.

The high BRA clearing prices of 2025/26 and the anticipation of similarly elevated prices in subsequent auctions triggered a political intervention that directly modified the demand curve for two delivery years. On December 30, 2024, the Office of Governor Josh Shapiro filed a complaint against PJM's tariff with the Federal Energy Regulatory Commission under Section 206 of the Federal Power Act. The complaint's legal theory was that the VRR Point (a) price cap was set too high given lower expectations for new entry in the near term (Bresler and Keech, 2025). Because compressed auction lead times (Section 3) limited the ability of new generation to respond to high prices within upcoming delivery

periods, the complaint argued that high prices would not produce efficient entry and instead represented an unjust and unreasonable rate. The proposed remedy was to lower the cap to $1.5 \times$ Net CONE and remove reliance on Gross CONE in the Point (a) calculation.

Following confidential settlement discussions, PJM and the Governor's office announced an agreement in principle on January 28, 2025 (Office of Governor Josh Shapiro, 2025). The settlement was presented to the PJM Markets and Operations Committee on February 7, 2025, and PJM indicated a target filing date of February 14, 2025, with the 2026/27 BRA scheduled for July 2025 and the 2027/28 BRA for December 2025 (Bresler and Keech, 2025). The agreement imposes a price band on the demand curves for both delivery years: a price cap at approximately \$325/MW-day UCAP (Unforced Capacity), equivalent to \$256.75/MW-day in Installed Capacity (ICAP) terms at the assumed 79% accreditation of the dual-fuel combustion turbine reference unit, and a price floor at approximately \$175/MW-day UCAP (\$138.25/MW-day ICAP), below which all available capacity clears regardless of the VRR slope.

The settlement cap is denoted as $\bar{p}_S \approx$ \$325/MW-day (UCAP) and the floor as $\bar{p}_f \approx$ \$175/MW-day (UCAP) to distinguish them from the existing VRR Point (a) cap $\bar{p}$. Both values are indexed to the accreditation of the reference unit and may differ slightly from these round numbers when final Effective Load Carrying Capability (ELCC) values are determined.

The settlement does not impose an external price constraint on an otherwise unchanged auction. Instead, it modifies the shape of the VRR demand curve itself (Bresler and Keech, 2025). At prices above $\bar{p}_S$, the demand curve is flat (no capacity with offers above the cap can clear). Between $\bar{p}_S$ and $\bar{p}_f$, the existing VRR sloped segment applies. At prices at or below $\bar{p}_f$, the demand curve extends horizontally to clear all available capacity at the floor price. This mechanism applies identically to the RTO demand curve and to every LDA demand curve. Clearing results continue to respect CETL transmission limitations (Bresler and Keech, 2025; Federal Energy Regulatory Commission, 2025). The pre-existing Point (a) cap $\bar{p}$ is calibrated to investment incentives (approximately $1.5 \times$ Net CONE), while the settlement

cap $\bar{p}_S$ is lower and is motivated by near-term consumer cost concerns. Table 1 shows that $\bar{p} = \$329.17$/MW-day in 2026/27, only \$4.17 above $\bar{p}_S = \$325$/MW-day; the gap is larger in constrained LDAs where local Point (a) caps substantially exceeded \$325 in prior years.

4 Model

The BRA is modeled as a static, complete-information game in which sellers simultaneously submit supply functions before the auction clears. This formulation follows Klemperer and Meyer (1989) and, for the electricity market application, Green and Newbery (1992). The timing is: (1) PJM publishes the VRR curve parameters for the upcoming delivery year; (2) sellers submit supply functions; (3) PJM clears the auction at the uniform price where aggregate supply meets the VRR curve; (4) sellers deliver committed capacity during the delivery year.

Assumption 1. *There are $K \geq 2$ strategic sellers, indexed $i = 1, \ldots, K$, and a competitive fringe. Each strategic seller i holds a fixed capacity portfolio $\bar{q}_i > 0$ measured in megawatts. A supply function $S_i : [0, \bar{p}] \to [0, \bar{q}_i]$ is a nondecreasing, twice continuously differentiable mapping from price to quantity. Each seller simultaneously commits to a supply function before the auction clears.*

Assumption 2. *The competitive fringe bids at its avoidable cost rate $c_f > 0$. Fringe supply is $S_f(p) = 0$ for $p < c_f$ and $S_f(p) = \bar{Q}_f$ for $p \geq c_f$, where $\bar{Q}_f > 0$ is total fringe capacity. The fringe is price-taking and its behavior is common knowledge.*

Assumption 3. *Each strategic seller has a constant marginal cost $c > 0$ for output $q \leq \bar{q}_i$ and infinite marginal cost above capacity. For the symmetric calibration I set c equal to the sector-average avoidable cost rate published by the PJM IMM.*

The market clears at the price p^* satisfying

$$\sum_{i=1}^{K} S_i(p^*) + S_f(p^*) = D(p^*), \tag{2}$$

where $D(\cdot)$ is the VRR demand schedule described below. Every seller receives the same clearing price p^* for its committed capacity. The *residual demand* facing seller i at price p is

$$R_i(p) \;=\; D(p) - \sum_{j \neq i} S_j(p) - S_f(p). \tag{3}$$

In equilibrium, $S_i(p^*) = R_i(p^*)$. Because $D(\cdot)$ and all rivals' strategies are publicly known before the auction, there is no demand uncertainty: the residual demand curve each seller faces is deterministic. This determinism means firms observe the VRR parameters before submitting offers. The boundary condition is imposed as an equilibrium selection criterion, as discussed below.

PJM's Variable Resource Requirement curve is a piecewise-linear, publicly-announced downward-sloping demand schedule. Under the old design (delivery years 2021/22–2025/26) it is parameterized by three anchor points (p_a, q_a), (p_b, q_b), and $(0, q_c)$:

$$D(p) = \begin{cases} q_a & p \geq p_a \\ q_a + \dfrac{q_b - q_a}{p_b - p_a}(p - p_a) & p_b \leq p < p_a \\ q_b + \dfrac{q_c - q_b}{0 - p_b}(p - p_b) & 0 \leq p < p_b, \end{cases} \tag{4}$$

where $p_a = 1.5 \times$ Net CONE is the price cap and $p_b = 0.75 \times$ Net CONE is the reliability-requirement price. The quantities $q_a < q_b < q_c$ are the corresponding capacity levels, with q_b equal to the reliability requirement. Because $D(p) = q_a$ for all $p \geq p_a$, the VRR curve is effectively inelastic above the cap.

Under the new design (delivery years 2026/27 onward), FERC Order ER25-1357 introduces a fourth anchor point (p_f, q_f) and (p_f, q_d) with $q_f > q_b$, creating a flat floor segment at price

$p_f \approx$ \$177– \$179/MW-day. The new schedule is:

$$D(p) = \begin{cases} q_a & p \geq p_a \\ q_a + \dfrac{q_b - q_a}{p_f - p_a}(p - p_a) & p_f \leq p < p_a \\ q_d & 0 \leq p < p_f. \end{cases} \tag{5}$$

The flat floor segment at p_f means that clearing prices cannot fall below p_f along the VRR, changing the elasticity profile that sellers face and thus the equilibrium markup. The comparative static in Section 6 isolates this design change. The slope $D'(p)$ is piecewise constant and satisfies:

Assumption 4. *$D'(p) < 0$ on the sloped segments; $D'(p) = 0$ on the flat segments (at and above p_a, and below p_f under the new design). The function $D(\cdot)$ is known to all players before the auction.*

Seller i chooses $S_i(\cdot)$ to maximize profit. Taking rivals' supply functions as fixed, the profit at any market-clearing price p is $\pi_i = p \cdot S_i(p) - c \cdot S_i(p) = (p - c) \cdot S_i(p)$, since marginal cost is constant at c. The seller's problem is equivalent to maximizing profit along its residual demand curve $R_i(\cdot)$. At price p, if seller i considers increasing its offered quantity by $\mathrm{d}q$, the market-clearing price must fall by $\mathrm{d}p$ to preserve equation (2):

$$\mathrm{d}p \;=\; \frac{\mathrm{d}q}{D'(p) - \sum_{j \neq i} S_j'(p) - S_f'(p)}. \tag{6}$$

Since $D'(p) < 0$ and $S_j'(p) \geq 0$, the denominator is strictly negative: an increase in supply lowers the clearing price. The seller's marginal revenue from increasing quantity at price p is:

$$\mathrm{MR}_i(p) \;=\; p + \frac{S_i(p)}{D'(p) - \sum_{j \neq i} S_j'(p) - S_f'(p)}. \tag{7}$$

Setting marginal revenue equal to marginal cost c yields the *supply function equilibrium*

condition:

Proposition 1. *In a supply function equilibrium, each seller i's strategy $S_i(\cdot)$ satisfies*

$$S_i(p) \;=\; -\Big(p-c\Big)\Big[D'(p) - \textstyle\sum_{j\neq i} S_j'(p) - S_f'(p)\Big] \tag{8}$$

at every price p at which the market can clear. This is a system of K coupled first-order ordinary differential equations in the supply functions $\{S_1, \ldots, S_K\}$.

Equation (8) is the K-seller generalization of the first-order condition derived by Green and Newbery (1992) for the symmetric duopoly (their equation 3) and of the general condition in Anderson and Hu (2008) (their equation 1). Its economic content is straightforward: seller i equates its residual-demand markup $(p-c)$ to the inverse of the residual demand elasticity at that price. When more sellers compete (K large) or the VRR slope is steep (large $|D'|$), the system requires a smaller markup at each price, pushing the equilibrium supply function toward the competitive schedule.

The ODE system (8) generally admits a continuum of solutions. Klemperer and Meyer (1989) show that under demand uncertainty, the set of symmetric supply function equilibria is an interval bounded above by the Cournot schedule (where each firm behaves as if rivals are at capacity) and below by the competitive schedule (where $p = c$). Any trajectory between these two stationary solutions is a Nash equilibrium. This multiplicity complicates both prediction and comparative statics. I select from this continuum using the boundary condition from the following result, which applies to the capacity-auction setting:

Proposition 2 (Holmberg 2008)**.** *Suppose sellers are symmetric, demand is inelastic above the price cap $\bar{p}$, and the probability that aggregate demand reaches the capacity ceiling is strictly positive. Then there exists a unique symmetric supply function equilibrium. In this equilibrium each seller's supply function satisfies the boundary condition*

$$S_i(\bar{p}) \;=\; \bar{q}_i \quad \textit{for all } i. \tag{9}$$

The intuition is direct. When rivals' capacity constraints simultaneously bind, seller i faces perfectly inelastic residual demand. Its monopoly optimum at that moment is to set price equal to the cap $\bar{p}$; any lower price sacrifices revenue without reducing quantity (since residual demand is inelastic), and any higher price is infeasible. This forces the supply function to pass through the point $(\bar{p}, \bar{q}_i)$, tying the arbitrary constant in the ODE and selecting a unique trajectory. In the PJM BRA, the price cap $\bar{p}$ equals the VRR Point (a) price, and Assumption 4 ensures $D'(\bar{p}) = 0$ (the VRR is flat at the cap). The at-cap clearing outcomes in 2026/27 and 2027/28 (Table 1) confirm that the boundary condition is active in those years, consistent with Holmberg's (2008) selection criterion: PJM's reliability target requires procuring essentially all installed capacity, making binding-capacity outcomes the empirically relevant case. I therefore integrate the ODE (8) *backward* from the boundary condition $S_i(\bar{p}) = \bar{q}_i$, following the solution method of Green and Newbery (1992).

For calibration and comparative statics I begin with the symmetric case in which all K strategic sellers are identical: $\bar{q}_i = \bar{q}$ and $c_i = c$ for all i. In a symmetric Nash equilibrium, $S_i(p) = s(p)$ for all i. Substituting into equation (8):

$$s(p) \;=\; -\Big(p - c\Big)\Big[D'(p) - (K-1)\, s'(p) - S_f'(p)\Big]. \tag{10}$$

Under Assumption 2, $S_f'(p) = 0$ almost everywhere. Rearranging (10) for $s'(p)$ yields the *symmetric SFE ordinary differential equation*:

$$s'(p) \;=\; \frac{1}{K-1}\left[D'(p) + \frac{s(p)}{p-c}\right], \quad p \in [c, \bar{p}), \tag{11}$$

with boundary condition $s(\bar{p}) = \bar{q}$. This is a first-order, nonautonomous ODE in the single unknown function $s(\cdot)$. It is the K-firm generalization of Green and Newbery's equation (3), to which it reduces when $K = 2$ and $S_f \equiv 0$.

Equation (11) has a direct economic interpretation. The term $D'(p)$ captures the direct effect of price on quantity demanded: a steeper VRR slope (larger $|D'|$) makes $s'(p)$ more

negative, meaning each firm's equilibrium supply function falls more steeply toward the cap as price rises. The term $s(p)/(p-c)$ is a markup-boundary feedback: as p approaches c from above, this term diverges and forces $s'(p)$ to remain bounded away from the demand slope, enforcing the lower boundary of the supply function and preventing equilibrium offers below cost. At prices well above c, the feedback term partially offsets $D'(p)$, making the supply function steeper in price than a linear interpolation between c and $\bar{p}$ would predict. More competitors (larger K) divide the denominator, flattening each firm's supply function toward the competitive benchmark.

The equilibrium clearing price p^* is found by solving

$$K \cdot s(p^*) + S_f(p^*) = D(p^*) \tag{12}$$

for p^* after integrating (11) backward from $\bar{p}$. The implied price-cost margin (Lerner index) is

$$L \;=\; \frac{p^* - c}{p^*}, \tag{13}$$

which measures the equilibrium price-cost margin reported in Section 6. The competitive benchmark corresponds to $c = p^*$ ($L = 0$), attained as $K \to \infty$ or as $|D'(p)| \to \infty$ (perfectly elastic demand). The Cournot upper bound on the markup is $L^{\text{Cournot}} = 1/(K \cdot |D'(p^*) \cdot p^*/D(p^*)|)$, the standard inverse-elasticity rule evaluated at market demand (which equals the residual demand elasticity in the symmetric case).

Treating the three largest PJM sellers as symmetric is a tractability assumption: it reduces the K-dimensional coupled ODE system (8) to the scalar ODE (11), making the model calibratable from publicly available aggregate data. This is the standard approach in the calibrated SFE literature (Green and Newbery, 1992; Sioshansi and Oren, 2007). I treat the symmetric Lerner index as an estimate of the capacity-weighted average markup; the spread around this average is an object of interest for future asymmetric extensions. Equation (11) is solved numerically using a fourth-order Runge–Kutta integrator with fixed

step size $h = 0.05\,\$/\text{MW-day}$, integrating backward from the boundary condition $s(\bar{p}) = \bar{q}$.

5 Calibration

The calibration draws on four publicly available datasets produced by PJM and the IMM. PJM publishes VRR curve anchor points, Net CONE, CETL, and reliability requirements for every LDA in advance of each BRA. I compiled planning parameter files for delivery years 2021/22 through 2028/29, covering both the three-point (old) and four-point (new) curve designs. PJM releases clearing prices and quantities by LDA after each auction; the sample covers seven completed auctions (2021/22 through 2027/28), verified against PJM press releases. Residual Supply Index values and participant counts are drawn from the IMM's annual State of the Market reports (Volumes 2022 and 2025). RSI data is available for a subset of LDAs and delivery years, as documented in Table 2. Lead time is defined as the number of calendar months between the BRA settlement date and the first day of the delivery year (Table 1). The four datasets are joined at the LDA–delivery-year level to produce a master panel with 110 observations spanning 17 LDAs and seven delivery years (2021/22 through 2027/28).

Table 3 reports the VRR curve parameters for the RTO under both the old and new designs for the six delivery years with complete BRA data. Under the old design, Point (a) equals $1.5 \times$ Net CONE and Point (b) equals $0.75 \times$ Net CONE by construction, so the ratio $p_a/p_b = 2$ is exact for all old-design years except 2025/26, where a transitional administrative cap produced a Point (a) price (\$451.61) above the standard $1.5 \times$ Net CONE multiple (\$343.22), because VRR anchor points are fixed at planning-parameter publication and may diverge from the final Net CONE. I use the published anchor points as the realized VRR parameters throughout. Under the new design, Points (b) and (c) equal the explicit floor price of approximately \$177–\$179 per MW-day, and Point (a) is calibrated by FERC Order ER25-1357. The new-design Point (a) prices (\$329.17 for 2026/27, \$333.44 for 2027/28) do

not equal simple Net CONE multiples because they reflect the settlement implementation and are fixed from planning parameters published before each auction. The settlement's flat-top at \$325/MW-day creates binding gaps of \$4.17 and \$8.44 respectively below these Point (a) values.

Table 3: RTO VRR Curve Parameters, 2022/23–2027/28

Delivery Year	Net CONE (\$/MW-day)	Pt. (a) Price	Pt. (a) MW	Pt. (b) Price	Pt. (b) MW	VRR Design
2022/23	\$260.50	\$390.75	136,076	\$195.38	139,656	Old
2023/24	\$274.96	\$412.44	135,914	\$206.22	139,473	Old
2024/25	\$293.19	\$439.79	138,341	\$219.89	141,910	Old
2025/26	\$228.81	\$451.61	133,554	\$171.61	137,160	Old
2026/27	\$212.14	\$329.17	134,887	\$177.24	136,361	New
2027/28	\$242.52	\$333.44	141,681	\$179.55	143,218	New

Note: Prices in nominal dollars per MW-day; quantities in MW. The 2025/26 Point (a) price exceeds $1.5 \times$ Net CONE due to a transitional administrative cap. Source: PJM Planning Parameters.

The panel encompasses 110 LDA–delivery-year cells with observed clearing prices across 17 LDAs. All seven completed BRA years are used in the analysis: five old-design years (2021/22 through 2025/26) spanning clearing prices from \$28.92 to \$269.92/MW-day, and two new-design years (2026/27 and 2027/28) that both cleared at exactly the Point (a) cap.

Capacity market concentration in PJM is high by any standard measure. The PJM IMM reports LDA-level Herfindahl-Hirschman Index (HHI) values in its annual State of the Market (SotM) reports. In every delivery year covered by the sample, the RTO-level HHI exceeds 2,500 and most constrained LDAs exceed 4,000, thresholds the Department of Justice classifies as highly concentrated markets under standard antitrust benchmarks.

The key calibration input is the number of strategic sellers, K. I use the Residual Supply Index with threshold three (RSI_3) as the calibration criterion: $\text{RSI}_3 < 1$ means that the three

largest sellers collectively hold pivotal capacity, i.e., no competitive outcome is supportable without their participation. In all seven delivery years, the RTO-level RSI_3 falls below unity (ranging from 0.62 to 0.73; Table 2), consistent with at most three large sellers being jointly pivotal. The 2026/27 at-cap clearing outcome is also consistent with $K \leq 3$: the model predicts interior clearing for four or more symmetric sellers in that year (Section 6), so the observed at-cap outcome aligns with a low effective strategic-seller count under the maintained model. The IMM TPS test confirms individual pivotality for all three largest sellers in every constrained LDA, supporting $K = 3$ over $K = 2$ as the baseline. I therefore set $K = 3$ as the baseline strategic count, and examine sensitivity to this assumption via the K comparative static in Section 6. Because RSI data is available only at the RTO level for most delivery years, I impose the same $K = 3$ structure on each LDA calibration and allow cross-LDA variation to enter through the VRR parameters and CETL-based fringe capacity. This homogeneity across LDAs is a known limitation. Where the IMM reports $\text{RSI}_1 < 1$ (e.g., BGE, DEOK in certain years), a single supplier is pivotal and the effective K is closer to one; the symmetric $K = 3$ calibration there understates local market power. Conversely, in LDAs with $\text{RSI}_3 > 1$, three suppliers are not jointly pivotal and $K = 3$ overstates concentration. LDA-level Lerner indices should therefore be read as applying a common structural assumption to heterogeneous local conditions rather than as LDA-specific estimates.

The ACR for each strategic seller is set to $c = \$150$ per MW-day, the combined-cycle sector average reported in the 2025 PJM IMM State of the Market (Monitoring Analytics, LLC, 2026, Table 7-38, \$149.32/MW-day, rounded). Combined-cycle units represent the marginal capacity technology in PJM's current resource mix, and the IMM identifies the combined-cycle ACR as the relevant benchmark for capacity-offer mitigation under the TPS test (Monitoring Analytics, LLC, 2026, 2025). The symmetric-firm assumption sets all $K = 3$ sellers to the same c, and heterogeneity in costs and capacity sizes is abstracted away. It is important to note that the ACR is a proxy for opportunity cost, not its direct measure. The

true avoidable cost of offering a megawatt of capacity depends on projected energy-market revenues, fuel hedge positions, maintenance schedules, and the firm's financial structure, none of which are publicly observable at the portfolio level. The sector-average combined-cycle ACR therefore understates cost heterogeneity across strategic sellers. The sensitivity of equilibrium markups to this approximation is examined directly in Table 6, which varies c over \$100–\$200 per MW-day at $K = 3$ and shows that the qualitative settlement-binding finding is robust across this range. The range is also informative as a bracketing device: applying a uniform ACR of \$100/MW-day to all three strategic sellers yields an upper Lerner bound of 0.70 in the 2026/27 at-cap equilibrium, while a uniform ACR of \$200/MW-day yields a lower bound of 0.39. Heterogeneous-cost configurations whose sector-average ACR is within this range need not produce a Lerner index strictly between these symmetric bounds—the symmetric SFE is not a proven envelope—but the bracketing analysis establishes that the central Lerner estimate of 0.54 at $c = \$150$ is not an artifact of a narrow assumed cost level.

Fringe supply is modeled as an inelastic block offered at c: any capacity not controlled by the K strategic sellers is assumed to offer at cost. At the RTO level, fringe capacity is set to total installed capacity minus the capacity attributed to the three largest sellers. This residual is scaled with γ to explore fringe-size sensitivity. For individual LDA calibrations, CETL serves as the effective fringe capacity, since CETL measures the maximum deliverable import from the rest of PJM into the LDA. LDA-level CETL values by delivery year are drawn directly from the PJM planning parameter files described in Section 5.

I calibrate and solve the model for all seven completed BRA delivery years (2021/22 through 2027/28), spanning both VRR design regimes and the full range of observed market conditions. Five auctions (2021/22 through 2025/26) were conducted under the old three-point VRR design; two (2026/27 and 2027/28) under the new four-point design with an explicit price floor. The SFE is a static game in which sellers submit supply functions against the VRR curve; the auction mechanism is structurally identical across all seven years regardless of lead time, so no year is excluded on timing grounds.

6 Results

Table 4 presents the baseline symmetric SFE results for all seven completed BRA delivery years, calibrated with $K = 3$ strategic sellers and $c = \$150$/MW-day (the sector-average ACR for combined-cycle generators from the 2025 IMM State of the Market). For each year, the table reports the model-predicted equilibrium price p^*, the observed BRA clearing price, and the implied price-cost margin (Lerner index) $L = (p^* - c)/p^*$.

Table 4: Baseline SFE Equilibrium: $K = 3$, $c = \$150$/MW-day

Year	Design	$\bar{p}$	$\bar{p}_S$	p^*	p_{actual}	L	Outcome
2021/22	Old	\$482	—	\$405	\$140	0.63	Interior
2022/23	Old	\$391	—	\$310	\$50	0.52	Interior
2023/24	Old	\$412	—	\$330	\$34	0.55	Interior
2024/25	Old	\$440	—	\$358	\$29	0.58	Interior
2025/26	Old	\$452	—	\$426	\$270	0.65	Interior
2026/27	New	\$329	\$325	\$329	\$329	0.54	At cap
2027/28	New	\$333	\$325	\$333	\$333	0.55	At cap

Notes: $\bar{p}$: VRR Point (a) price cap. $\bar{p}_S$: Shapiro settlement cap (\$325/MW-day UCAP); "—" indicates the settlement does not apply. Prices in \$/MW-day. "Interior": equilibrium falls strictly inside $(c, \bar{p})$; "At cap": $S_i(\bar{p}) = \bar{q}_i$ for all i. Source: PJM BRA clearing data and SFE model.

The central finding is that the Shapiro cap is *binding*: the SFE equilibrium for 2026/27, $p^* = \$329$/MW-day, exceeds the settlement cap $\bar{p}_S = \$325$/MW-day by \$4/MW-day at the RTO level. For constrained LDAs, the binding gap is larger (\$115–\$141/MW-day based on 2025/26 clearing prices of \$444–\$466/MW-day; Section 6).

The 2026/27 result is the most informative for assessing the maintained model. The Holmberg boundary condition selects $p^* = \bar{p} = \$329.17$/MW-day for $K = 3$. It is important to be transparent about what this means: the matching of the observed clearing price is a *mechanical* consequence of the boundary condition, not an independent forecast. Once $K = 3$ is assumed and the 2026/27 capacity margin (-0.2%) is tight enough to trigger the at-cap regime, the ODE solution is forced to $\bar{p}$ by construction. The dollar amount \$329.17 is simply the VRR Point (a) price read from the planning parameters. The substantively informative content is the *binary* at-cap versus interior outcome: for $K \geq 4$, the model predicts interior

clearing strictly below the cap (see Section 6), so the observed at-cap outcome is consistent with $K \leq 3$ as the maximal effective seller count in 2026/27. The model does not confirm the price. It confirms the structural regime.

For all five old-design years, p^* substantially exceeds the observed clearing price. The gap is largest in well-supplied years where TPS mitigation was broadly applied (e.g., $p^* = \$330$ vs. $p_{\text{actual}} = \$34$ in 2023/24, with $\text{RSI}_3 = 0.68$ and capacity margin 9.9%). The gap narrows in 2025/26 ($p^* = \$426$ vs. $p_{\text{actual}} = \$270$), reflecting a capacity margin of only 1.6% and a price spike that occurred even under partial mitigation. This pattern is consistent across all old-design years: the SFE predicts the *unmitigated* equilibrium, while actual prices reflect the TPS screen.

This distinction shapes how the 2026/27 and 2027/28 results should be read. The SFE equilibrium p^* describes what the auction would clear at under strategic bidding when no binding mitigation cap is imposed. The observed clearing price equals the minimum of p^* and the TPS-mitigated offer cap (approximately $c \cdot (1 + m)$, where m is the IMM's mitigation multiplier); in old-design years that minimum is the mitigation cap, not the SFE. For 2026/27 and 2027/28 the $K = 3$ equilibrium is at the VRR Point (a) cap (\$329 and \$333), which sits below any plausible TPS mitigation cap for combined-cycle-anchored capacity offers; the settlement cap at \$325 therefore binds below both the SFE benchmark and the TPS screen, and the counterfactual used for the \$612 million two-year transfer (Section 8) uses the SFE rather than the TPS mitigation cap. If TPS mitigation would have bound near \$325 in the absence of the settlement—an empirical question that would require endogenizing the TPS test—the SFE-based transfer estimate overstates the true settlement-induced reduction in capacity payments.

Figure 1 and Table 5 report the equilibrium price-cost margin L as a function of the number of strategic sellers K, holding calibration-year parameters fixed. The results reveal three qualitative zones.

Table 6 varies the assumed marginal cost c from \$100 to \$200 per MW-day. The at-cap



Figure 1: Markups Collapse Between Three and Four Strategic Sellers
Notes: Source: SFE model calibrated to PJM planning parameters for each benchmark year. Shaded region indicates at-cap outcomes where $S_i(\bar{p}) = \bar{q}_i$.

finding is fully robust: p^* exceeds the settlement cap for all cost assumptions shown. The Lerner index in 2026/27 ranges from 0.39 (at $c = \$200$) to 0.70 (at $c = \$100$); interior equilibria show limited price sensitivity to c.

For $K = 2$, the market clears at $\bar{p}$ in all seven delivery years, yielding Lerner indices of 0.54–0.69. The at-cap outcome is also produced by $K = 3$ in 2026/27 (where the VRR cap $\bar{p} = \$329$ is lower, meeting the equilibrium supply function sooner). The transition from $K = 2$ to $K = 3$ has a modest effect on the price-cost margin in 2023/24 (0.64 to 0.55) but almost none in 2025/26 (0.67 to 0.65), because in 2025/26 the supply function remains close to the cap throughout. Adding a fourth seller reduces the price-cost margin by 33–45 percentage points relative to $K = 3$, shifting the 2023/24 equilibrium from \$330 to \$215 and the 2026/27 equilibrium from the cap to \$228. The ODE (11) makes this intuitive: increasing K divides the denominator, forcing $s'(p)$ to be larger in absolute value at any given (p, s) pair, which means firms must offer more capacity at every price below the cap and the equilibrium

Table 5: Equilibrium Price and Price-Cost Margin by K (Baseline Calibration)

	2023/24 (Old VRR)			2025/26 (Old VRR)			2026/27 (New VRR)		
K	p^*	L	cap	p^*	L	cap	p^*	L	cap
2	412	0.64	✓	452	0.67	✓	329	0.54	✓
3	330	0.55		426	0.65		329	0.54	✓
4	215	0.30		261	0.42		228	0.34	
5	168	0.11		184	0.19		177	0.15	
7	151	0.01		152	0.01		152	0.01	
10	151	0.01		151	0.01		151	0.01	

Notes: Prices in \$/MW-day. $L = (p^* - c)/p^*$; $c = \$150$/MW-day. ✓ indicates the market clears at the VRR price cap $\bar{p}$.

Table 6: Equilibrium Price and Price-Cost Margin by Cost Assumption ($K = 3$)

	2023/24 (Old VRR)		2025/26 (Old VRR)		2026/27 (New VRR)	
c (\$/MW-day)	p^*	L	p^*	L	p^*	L
\$100	\$314	0.68	\$422	0.76	\$329	0.70
\$125	\$322	0.61	\$424	0.71	\$329	0.62
\$150	\$330	0.55	\$426	0.65	\$329	0.54
\$175	\$338	0.48	\$428	0.59	\$329	0.47
\$200	\$346	0.42	\$431	0.54	\$329	0.39

Notes: Prices in \$/MW-day. $K = 3$ throughout. For 2026/27, the Holmberg boundary condition is active for all c values shown, so p^* equals the VRR Point (a) cap (\$329/MW-day) in all rows; only the Lerner index varies. Source: SFE model calibrated to PJM planning parameters.

supply function shifts outward. With seven or more strategic sellers, equilibrium prices fall to within 0.5% of marginal cost ($c = \$150$/MW-day) in all seven years, with price-cost margins effectively zero ($L < 0.02$), consistent with the competitive limiting result $p^* \to c$ as $K \to \infty$ implied by equation (11).

The structural implication is direct: the observed 2026/27 at-cap outcome ($p^* = \$329$) is consistent with $K \leq 3$ but inconsistent with $K \geq 4$ (which would predict interior clearing at \$228 or below). This makes 2026/27 a useful natural experiment for establishing the effective number of strategic sellers.

Figure 2 shows the price-cost margin L as a function of the VRR slope scaling factor ($f = 1$ is the baseline; $f > 1$ is steeper demand).

Steeper VRR demand reduces equilibrium markups by increasing the $D'(p)$ term in the



Figure 2: Steeper VRR Demand Reduces Markups and Can Eliminate Cap-Binding
Notes: Source: SFE model with slope factor applied to the VRR quantity increment $(q_b - q_a)$, anchor prices held fixed. Factor = 1 is the calibrated baseline.

ODE, forcing a more competitive supply function. A doubling of the slope reduces the Lerner index by 20–30 percentage points in interior-clearing years. For 2026/27 at $K = 3$, the outcome remains at the price cap until the slope factor exceeds approximately 1.4, at which point the supply function clears below the cap without an external price constraint.

Figure 3 traces the price-cost margin L as fringe supply $\bar{Q}_f$ varies from 70% to 150% of its calibrated baseline. The fringe captures competitive imports and non-strategic capacity, so this comparative static approximates the effect of expanding CETL or reducing transmission congestion.

A 30% increase in fringe supply reduces the price-cost margin by 12–18 percentage points in interior-clearing years. For 2026/27, expanding the fringe at $K = 3$ reduces the margin from 0.54 to roughly 0.30 (a price drop from \$329 to approximately \$215/MW-day), suggesting that expanding import capacity would substantially affect equilibrium pricing even without structural remedies to seller concentration.



Figure 3: Expanding Competitive Fringe Substantially Reduces Markups
Notes: Source: SFE model with fringe supply $\bar{Q}_f$ scaled from 70% to 150% of the RSI-derived calibrated baseline for each benchmark year.

Capacity is traded separately in constrained LDAs. For each LDA, I calibrate $\bar{Q}_f = \text{CETL}$ and set each strategic seller's capacity at $\bar{q} = (\text{rel. req.} - \text{CETL})/K$. Table 7 reports the implied Lerner indices for all LDAs with valid CETL data.

Lerner indices range from 0.48 (DEOK in 2025/26) to 0.70 (PS and PS NORTH in 2025/26), with most LDAs above 0.60 in every year. In 2026/27, every LDA clears at or within \$0.50 of the price cap, confirming that the at-cap outcome is not an artifact of RTO aggregation. Figure 5 shows that LDAs with higher import penetration (CETL/rel. req.) systematically exhibit lower markups: a 10-percentage-point increase in import penetration is associated with a 4–6-point reduction in the price-cost margin.

Table 7: SFE Lerner Index by LDA and Delivery Year ($K = 3$, $c = \$150$/MW-day)

LDA	2021/22	2022/23	2023/24	2024/25	2025/26	2026/27	2027/28
ATSI	$0.67^{\dagger}$	$0.57^{\dagger}$	$0.62^{\dagger}$	$0.64^{\dagger}$	0.63	$0.54^{\dagger}$	$0.55^{\dagger}$
ATSI-Cleveland	$0.67^{\dagger}$	0.55	0.61	0.64	0.56	$0.54^{\dagger}$	$0.55^{\dagger}$
COMED	$0.71^{\dagger}$	$0.60^{\dagger}$	$0.65^{\dagger}$	$0.67^{\dagger}$	$0.67^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
DEOK	$0.68^{\dagger}$	$0.55^{\dagger}$	$0.60^{\dagger}$	$0.63^{\dagger}$	0.48	$0.54^{\dagger}$	$0.55^{\dagger}$
DOM	–	–	–	–	0.66	$0.54^{\dagger}$	$0.55^{\dagger}$
DPL SOUTH	$0.67^{\dagger}$	$0.58^{\dagger}$	$0.62^{\dagger}$	$0.65^{\dagger}$	0.67	$0.54^{\dagger}$	$0.55^{\dagger}$
EMAAC	$0.68^{\dagger}$	$0.61^{\dagger}$	$0.66^{\dagger}$	$0.68^{\dagger}$	$0.68^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
JCPL	–	–	–	–	–	$0.54^{\dagger}$	$0.55^{\dagger}$
MAAC	$0.66^{\dagger}$	$0.59^{\dagger}$	$0.64^{\dagger}$	$0.66^{\dagger}$	$0.67^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
PEPCO	$0.65^{\dagger}$	$0.61^{\dagger}$	$0.63^{\dagger}$	$0.65^{\dagger}$	–	$0.54^{\dagger}$	–
PL	$0.67^{\dagger}$	$0.60^{\dagger}$	$0.64^{\dagger}$	$0.66^{\dagger}$	0.65	$0.54^{\dagger}$	$0.55^{\dagger}$
PS	$0.70^{\dagger}$	$0.63^{\dagger}$	$0.67^{\dagger}$	$0.69^{\dagger}$	$0.70^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
PS NORTH	$0.70^{\dagger}$	$0.63^{\dagger}$	$0.67^{\dagger}$	$0.69^{\dagger}$	$0.70^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
SWMAAC	$0.63^{\dagger}$	$0.59^{\dagger}$	$0.59^{\dagger}$	$0.62^{\dagger}$	$0.68^{\dagger}$	$0.54^{\dagger}$	$0.55^{\dagger}$
BGE	$0.63^{\dagger}$	$0.56^{\dagger}$	$0.55^{\dagger}$	$0.58^{\dagger}$	0.68	0.54	$0.55^{\dagger}$
DAYTON	$0.68^{\dagger}$	$0.56^{\dagger}$	–	$0.62^{\dagger}$	–	–	–

Notes: $K = 3$ strategic sellers per LDA. $c = \$150$/MW-day (CC technology-average ACR, 2025 IMM SotM). Market structure calibrated using $\bar{Q}_f$ = CETL (competitive imports) and $\bar{q}$ = (rel. req. − CETL)/K (strategic sellers cover local gap). † Market clears at or within \$0.50 of the VRR price cap.

7 Allocative Implications of the Price Band

The settlement cap's allocative significance depends on its proximity to the investment threshold. In 2026/27, Net CONE is \$212.14/MW-day; the settlement cap at \$325/MW-day exceeds it by 53%, so the cap alone does not prevent new entry from being financially viable. The more substantive concern is informational: because the cap binds in consecutive years (2026/27 and 2027/28), potential entrants observe the cap rather than the unconstrained equilibrium price and cannot distinguish between a market that would have cleared at \$333 and one that would have cleared far above \$325. This uncertainty reduces the informativeness of the capacity price for investment decisions (Anderson and Xu, 2005), a concern amplified in constrained LDAs where local Net CONE values exceed the settlement cap (e.g., PS and PS NORTH Net CONE = \$369/MW-day in 2026/27).

The \$175/MW-day floor operates differently: it prevents price collapse in over-supplied conditions, functioning as an investment adequacy mechanism rather than a cost-reduction



Figure 4: All Locational Markets Exhibit High Markups, Especially Import-Constrained LDAs
Notes: Source: SFE model calibrated to PJM planning parameters and CETL data by LDA. †: market cleared at or within $0.50 of the VRR price cap. LDAs ordered by 2026/27 margin.

measure (Bresler and Keech, 2025). At the RTO level, the floor falls below Net CONE ($212.14) and does not guarantee full cost recovery. Combined with the cap, the settlement creates a price band ($175–$325) that is neither the competitive equilibrium ($c \approx$ $150) nor the SFE benchmark ($p^* \approx$ $329–$333). For $K = 3$, the SFE equilibrium falls above the band, so the cap truncates the price signal rather than confirming it. A formal welfare accounting—comparing deadweight losses from the truncated investment signal against consumer savings from lower cleared prices—is outside the scope of this paper; the observation here is that the cap is close enough to Net CONE to leave entry incentives broadly intact, and the remaining allocative concern is informational rather than direct cost recovery.



Figure 5: Higher Import Penetration Systematically Reduces Local Markups
Notes: Source: SFE model calibrated to PJM planning parameters and CETL data by LDA. Each point is one LDA-year observation; dashed lines are ordinary least squares (OLS) trends by year.

8 Evaluating the $21 Billion Claim

Pennsylvania's January 28, 2025 announcement stated that the settlement would save consumers "over $21 billion over the next two delivery years" (Office of Governor Josh Shapiro, 2025). The arithmetic is straightforward: (counterfactual price − $325) × cleared quantity × 2 years. Shapiro's stated counterfactual is "over $500/MW-Day," which represents the projected VRR Point (a) price under the pre-settlement calibration methodology (Bresler and Keech, 2025). But the VRR Point (a) price is not a strategic equilibrium price. It is the maximum of the administrative demand schedule: the price at which the VRR curve becomes perfectly inelastic. In equilibrium, the capacity market clears where supply meets the VRR schedule, which, as Section 6 shows, may occur anywhere in the range $[c, \bar{p}]$ depending on market structure. The VRR counterfactual therefore uses an administrative ceiling rather than a market-clearing benchmark.

The SFE model provides a structural alternative: p^*, the equilibrium price under strategic bidding against the *unmodified* VRR curve. In 2026/27, $p^* = \$329.17$/MW-day; in 2027/28, $p^* = \$333.44$/MW-day. Both equilibria fall at the respective VRR Point (a) caps because the Holmberg boundary condition is active for $K \leq 3$, but they are substantially below the \$500 figure in Shapiro's claim.

Table 8 compares the implied revenue transfer under two counterfactual scenarios for the 2026/27 and 2027/28 delivery years, using RTO-level cleared quantities from the published BRA results.

Table 8: Revenue Transfer Under Two Counterfactual Scenarios (RTO Level)

	Counterfactual price		Annual revenue transfer		Two-year
Scenario	2026/27	2027/28	2026/27	2027/28	total
VRR Point (a) [Shapiro]	\$500	\$500	\$8.57B	\$8.59B	\$17.16B
SFE equilibrium [this paper]	\$329	\$333	\$0.20B	\$0.41B	\$0.61B
Settlement cap	\$325	\$325	—	—	—

Notes: All prices in \$/MW-day UCAP. Annual revenue transfer = $(p_{\text{counterfactual}} - \$325) \times Q \times 365$, where $Q = 134{,}205$ MW (2026/27) and $Q = 134{,}478$ MW (2027/28). Source: PJM BRA clearing data and SFE model.

Using \$500/MW-day as the counterfactual and RTO-level quantities, the two-year revenue transfer is \$17.16 billion. The stated \$21 billion figure includes contributions from constrained LDAs. The structural SFE estimate implies a two-year revenue transfer of approximately \$612 million at the RTO level—roughly 35 times smaller—because the 2026/27 strategic equilibrium falls near the design ceiling, not because the settlement eliminates large rents. The two counterfactuals differ not because one is wrong, but because they answer different questions: the VRR counterfactual measures the gap between the design-level cap and the settlement cap, while the SFE counterfactual measures the reduction in the predicted clearing price attributable to the price band.

The findings rest on maintained assumptions whose validity cannot be fully tested. First, I assume $K = 3$ symmetric sellers with identical costs. Actual PJM suppliers differ in technology, cost structure, and contract positions, so the symmetric Lerner index should

be interpreted as a central estimate, not a precise measurement. Second, the Holmberg boundary condition is derived for stochastic-demand markets; in the deterministic BRA, it is imposed as an equilibrium selection criterion, and alternative selection rules would yield different equilibrium prices. Third, the static model treats capacity as exogenous and cannot quantify entry distortions from the settlement. A complete savings calculation should account for retirements accelerated by lower prices and entry decisions informed by the observed 2026/27 and 2027/28 clearing prices; the $21 billion figure and the SFE estimate both hold quantity fixed. Fourth, even if greenfield entry is infeasible within the 10-month lead time of the 2026/27 BRA, auction prices inform decisions beyond direct construction—retirement deterrence, demand response registration, bilateral contracting, and forward expectations for 2028/29 and beyond (Cramton and Stoft, 2005)—so the informational cost of suppressing the price signal extends beyond the settlement's two-year window. Fifth, I do not model TPS mitigation endogenously; the gap between predicted and actual prices in old-design years suggests mitigation effects the model does not capture. If TPS mitigation would have produced offer caps near the settlement cap in 2026/27 absent the settlement, the SFE-based transfer of $612 million overstates the settlement's true reduction in payments; the observed old-design gap between p^* and p_{actual} cannot be used to rule this out, because TPS screening in those years occurred with capacity margins of 9.9% and 11.7% where the test was much more likely to be triggered than in the at-cap 2026/27 and 2027/28 auctions, where RSI_3 was binding but TPS application is regime-dependent. These limitations bound the precision of the quantitative estimates but do not affect the qualitative finding that the settlement cap is binding under concentrated supply.

9 Conclusion

Three findings emerge from the calibrated SFE analysis. First, the settlement cap is binding under concentrated supply: with $K \leq 3$ pivotal suppliers, the SFE equilibrium for 2026/27

falls at the VRR Point (a) cap of \$329.17/MW-day, exceeding the settlement cap $\bar{p}_S = \$325$ by \$4.17/MW-day at the RTO level and by \$115–\$141/MW-day in constrained LDAs. Second, the \$21 billion savings figure depends on the counterfactual: using the SFE equilibrium rather than the VRR Point (a) price yields a two-year RTO transfer of approximately \$612 million, roughly 35 times smaller than the stated figure. Third, structural channels can reduce prices without truncating the signal: CETL expansion, VRR slope steepening, and entry sufficient to reach $K \geq 4$ each lower the SFE equilibrium through concentration or fringe supply rather than direct price truncation.

The model's contribution is evaluative rather than prescriptive. A temporary cap can reduce payments, but the comparative statics show that the underlying concentration and transmission conditions generating high equilibrium prices are what place the equilibrium at the cap in the first place. The structural channels identified in the comparative statics (CETL expansion, VRR slope, entry) would reduce equilibrium markups through market structure rather than by truncating the price signal; the model does not rank reforms or quantify their welfare consequences, and whether any particular change is warranted depends on regulatory objectives and cost–benefit considerations outside its scope. Natural extensions include an asymmetric-firm SFE, a dynamic model connecting markups to capacity adequacy, and an empirical structural model recovering firm-level costs from offer data.

References

Edward J. Anderson and Xinmin Hu. Finding supply function equilibria with asymmetric firms. *Operations Research*, 56(3):697–711, 2008.

Edward J. Anderson and Huifu Xu. Supply function equilibrium in electricity spot markets with contracts and price caps. *Journal of Optimization Theory and Applications*, 124(2): 257–283, 2005.

Joseph Bowring. Capacity markets in PJM. *Economics of Energy & Environmental Policy*, 2 (2):47–64, 2013.

Stu Bresler and Adam Keech. Consultation: Capacity market demand curve adjustments pursuant to proposed settlement. Special MC/TOA-AC Presentation, PJM Interconnection, February 2025. February 7, 2025.

Peter Cramton and Steven Stoft. A capacity market that makes sense. *Electricity Journal*, 18(7):43–54, 2005.

Federal Energy Regulatory Commission. PJM Interconnection, L.L.C. Docket No. ER25-1357, Order Accepting Tariff Revisions, 2025. Accepting PJM compliance filing for Capacity Market Demand Curve Adjustments Pursuant to Settlement.

Edward L. Glaeser and Erzo F. P. Luttmer. The misallocation of housing under rent control. *American Economic Review*, 93(4):1027–1046, 2003.

Richard J. Green and David M. Newbery. Competition in the British electricity spot market. *Journal of Political Economy*, 100(5):929–953, 1992.

Pär Holmberg. Supply function equilibrium with asymmetric capacities and constant marginal costs. *Energy Journal*, 28(2):55–82, 2007.

Pär Holmberg. Unique supply function equilibrium with capacity constraints. *Energy Economics*, 30(1):148–172, 2008.

Paul L. Joskow. Capacity payments in imperfect electricity markets: Need and design. *Utilities Policy*, 16(3):159–170, 2008.

Paul L. Joskow and Jean Tirole. Reliability and competitive electricity markets. *RAND Journal of Economics*, 38(1):60–84, 2007.

Paul D. Klemperer and Margaret A. Meyer. Supply function equilibria in oligopoly under uncertainty. *Econometrica*, 57(6):1243–1277, 1989.

Monitoring Analytics, LLC. Analysis of the 2026/2027 PJM RPM base residual auction. Report, Independent Market Monitor for PJM, 2025.

Monitoring Analytics, LLC. 2025 state of the market report for PJM. Annual Report, Independent Market Monitor for PJM, 2026.

Office of Governor Josh Shapiro. Governor Josh Shapiro reaches agreement with PJM to prevent unnecessary price hikes and save consumers over $21 billion on utility bills. Commonwealth of Pennsylvania Press Release, January 2025. Accessed March 2026. Available at https://www.pa.gov/governor/newsroom/2025-press-releases/gov-shapiro-agreement-pjm-prevent-price-hikes-save-consumers-ove.

Johannes P. Pfeifenberger, Kathleen Spees, Kevin Carden, and Nicholas Wintermantel. Second performance assessment of PJM's reliability pricing model. Technical report, The Brattle Group, 2011. Prepared for PJM Interconnection.

PJM Interconnection, L.L.C. *PJM Manual 20A: PJM Resource Adequacy Analysis*. PJM Interconnection, 2024.

PJM Interconnection, L.L.C. *PJM Manual 18: PJM Capacity Market*. PJM Interconnection, 2025.

Aleksandr Rudkevich, Max Duckworth, and Richard Rosen. Modeling electricity pricing in a

deregulated generation industry: The potential for oligopoly pricing in a poolco. *Energy Journal*, 19(3):19–48, 1998.

Ramteen Sioshansi and Shmuel Oren. How good are supply function equilibrium models: An empirical analysis of the ERCOT balancing market. *Journal of Regulatory Economics*, 31 (1):1–35, 2007.

Martin L. Weitzman. Prices vs. quantities. *Review of Economic Studies*, 41(4):477–491, 1974.