FAULT CURRENT STUDIO - ENGINEERING REPORT
BROWSER EXPORT - ENGINEERING REVIEW REQUIRED

===== SUMMARY =====
Project: Fault Current Studio advanced study
Method: sequence
Model status: BOUNDED_REDUCED_SEQUENCE_NETWORK
Captured UTC: 2026-10-26T00:00:00.000Z
Warning: ENGINEERING SCREENING ONLY - independently verify actual manufacturer, utility, installation, equipment settings and standards edition before professional use.
Report data provenance: Entered study inputs, isolated calculated method outputs. No external OEM certification or auto-selected breaker/PPE.

===== STUDY INPUTS =====
Input path: nominalLLV | Entered value: 13800
Input path: voltageFactor | Entered value: 1.1
Input path: faultType | Entered value: AG
Input path: positiveSequence.rOhm | Entered value: 0.12
Input path: positiveSequence.xOhm | Entered value: 0.94
Input path: negativeSequence.rOhm | Entered value: 0.14
Input path: negativeSequence.xOhm | Entered value: 0.98
Input path: zeroSequence.rOhm | Entered value: 0.33
Input path: zeroSequence.xOhm | Entered value: 1.45

===== EQUIPMENT DUTY =====
Calculated output path: status | Value: BOUNDED_REDUCED_SEQUENCE_NETWORK
Calculated output path: scope | Value: Single-source classical symmetrical-component voltage/impedance screen for initial steady phasors. Not full IEC 60909:2026. No positive/negative/zero transformer vector group correction, shunt/motor/IBR contribution, peak/interrupting duty, relay settings, fault minimum, multiple sources or detailed earthing design.
Calculated output path: voltageLLV | Value: 13800
Calculated output path: voltageFactor | Value: 1.1
Calculated output path: faultType | Value: AG
Calculated output path: sequenceA.positive.phase | Value: I1
Calculated output path: sequenceA.positive.realA | Value: 441.76544048834916
Calculated output path: sequenceA.positive.imagA | Value: -2523.30429567074
Calculated output path: sequenceA.positive.rmsA | Value: 2561.683288964558
Calculated output path: sequenceA.negative.phase | Value: I2
Calculated output path: sequenceA.negative.realA | Value: 441.76544048834916
Calculated output path: sequenceA.negative.imagA | Value: -2523.30429567074
Calculated output path: sequenceA.negative.rmsA | Value: 2561.683288964558
Calculated output path: sequenceA.zero.phase | Value: I0
Calculated output path: sequenceA.zero.realA | Value: 441.76544048834916
Calculated output path: sequenceA.zero.imagA | Value: -2523.30429567074
Calculated output path: sequenceA.zero.rmsA | Value: 2561.683288964558
Calculated output path: phaseA.a.phase | Value: A
Calculated output path: phaseA.a.realA | Value: 1325.2963214650474
Calculated output path: phaseA.a.imagA | Value: -7569.91288701222
Calculated output path: phaseA.a.rmsA | Value: 7685.049866893674
Calculated output path: phaseA.b.phase | Value: B
Calculated output path: phaseA.b.realA | Value: 2.2737367544323206e-13
Calculated output path: phaseA.b.imagA | Value: 0
Calculated output path: phaseA.b.rmsA | Value: 2.2737367544323206e-13
Calculated output path: phaseA.c.phase | Value: C
Calculated output path: phaseA.c.realA | Value: 0
Calculated output path: phaseA.c.imagA | Value: 1.1368683772161603e-13
Calculated output path: phaseA.c.rmsA | Value: 1.1368683772161603e-13

Calculated output path: groundResidualA | Value: 7685.049866893674
Calculated output path: maximumPhaseRmsA | Value: 7685.049866893674

===== ASSUMPTIONS & QA =====
Evidence / limitation: Release status | Value: BOUNDED METHOD, NOT A STANDARDS/DEVICE APPROVAL
Evidence / limitation: Warning | Value: ENGINEERING SCREENING ONLY - independently verify actual manufacturer, utility, installation, equipment settings and standards edition before professional use.
Evidence / limitation: Study method | Value: sequence
Evidence / limitation: Timestamp | Value: 2026-10-26T00:00:00.000Z
Evidence / limitation: outputs.scope | Value: Single-source classical symmetrical-component voltage/impedance screen for initial steady phasors. Not full IEC 60909:2026. No positive/negative/zero transformer vector group correction, shunt/motor/IBR contribution, peak/interrupting duty, relay settings, fault minimum, multiple sources or detailed earthing design.