

Contact ID Codes

Code	Zone	Event	Type	Class	Description
070		TEST	Unknown	Test/Misc.	Test-Restore
076		TEST	Unknown	Test/Misc.	Test - Cell Backup
100		MEDICAL	Zone	Medical	
101		MEDICAL	Zone	Medical	PENDANT TRANSMITTER
102		MEDICAL	Zone	Medical	
103		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
104		RESTORE	Zone	Test/Misc.	DSC CID RESTORE
105		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
106		ABORT	User	General Alarms	
109		TROUBLE	Zone	System Troubles	Tamper
110		FIRE	Zone	Fire Alarms	
111		FIRE	Zone	Fire Alarms	SMOKE
112		FIRE	Zone	Fire Alarms	COMBUSTION
113		FIRE	Zone	Fire Alarms	WATER FLOW
114		FIRE	Zone	Fire Alarms	HEAT
115		FIRE	Zone	Fire Alarms	PULL STATION
116		FIRE	Zone	Fire Alarms	DUCT
117		FIRE	Zone	Fire Alarms	FLAME
118		FIRE	Zone	Fire Alarms	NEAR ALARM
11F		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
120		PANIC(audible)	Zone	Panic Alarms	AUDIBLE
121		DURESS	Zone	Panic Alarms	
122		DURESS	Zone	Panic Alarms	SILENT
123		PANIC(audible)	Zone	Panic Alarms	AUDIBLE
124		DURESS	User	Panic Alarms	Silent
125		DURESS	User	Panic Alarms	Silent
130		BURG	Zone	Burglar Alarms	
131		BURG	Zone	Burglar Alarms	PERIMETER
132		BURG	Zone	Burglar Alarms	INTERIOR
133		BURG	Zone	Burglar Alarms	24 HOUR
134		BURG	Zone	Burglar Alarms	ENTRY/EXIT
135		BURG	Zone	Burglar Alarms	DAY/NIGHT
136		BURG	Zone	Burglar Alarms	OUTDOOR
137		TAMPER	Zone	Burglar Alarms	TAMPER
138		BURG	Zone	Burglar Alarms	NEAR ALARM
139		BURG	Zone	Burglar Alarms	
13E		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
140		ALARM	Zone	General Alarms	
141		ALARM	Zone	General Alarms	POLLING LOOP OPEN
142		TROUBLE	Zone	General Alarms	POLLING LOOP SHORT
143		TROUBLE	Zone	General Alarms	EXP MODULE FAILURE
144		TAMPER	Zone	General Alarms	SENSOR TAMPER
145		TAMPER	Zone	General Alarms	EXP MODULE TAMPER
145	906	TECHNICIAN	Zone	System Troubles	AES IP-Link Door Tamper
146		BURG	Zone	General Alarms	SILENT
150		ALARM	Zone	General Alarms	
151		ALARM	Zone	24 Hour Non-Burglary	GAS DETECTED
152		TROUBLE	Zone	24 Hour Non-Burglary	REFRIGERATION
153		TROUBLE	Zone	24 Hour Non-Burglary	LOSS OF HEAT

154		TROUBLE	Zone		WATER LEAKAGE
155		ALARM	Zone	24 Hour Non-Burglary	FOIL BREAK
156		ALARM	Zone	24 Hour Non-Burglary	DAY TROUBLE
157		TROUBLE	Zone	24 Hour Non-Burglary	LOW BOTTLED GAS LVL
158		TEMPERATURE	Zone	24 Hour Non-Burglary	HIGH TEMP
159		TEMPERATURE	Zone	24 Hour Non-Burglary	LOW TEMP
161		ALARM	Zone	24 Hour Non-Burglary	LOSS OF AIR FLOW
162		ALARM	Zone	24 Hour Non-Burglary	CARBON MONOXIDE DETECTED
163		TROUBLE	Zone	24 Hour Non-Burglary	TANK LEVEL
199		ABORT	User	Open/Close	After alarm open
1B0		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1BC		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1C1		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1CD		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1CF		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1D0		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1DD		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
1EE		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
200		SUPERVISORY	Zone	Fire Supervisory	FIRE SUPERVISORY
201		SUPERVISORY	Zone	Fire Supervisory	LOW WATER PRESSURE
202		SUPERVISORY	Zone	Fire Supervisory	LOW CO2
203		SUPERVISORY	Zone	Fire Supervisory	
204		SUPERVISORY	Zone	Fire Supervisory	LOW WATER LEVEL
205		SUPERVISORY	Zone	Fire Supervisory	PUMP ACTIVATED
206		SUPERVISORY	Zone	Fire Supervisory	PUMP FAILURE
210		SUPERVISORY	Zone	Fire Supervisory	Supervisory
213		TROUBLE	Zone		SPRINKLER TROUBLE
271		ALARM	Zone	General Alarms	
300		TROUBLE	Zone	System Troubles	SYSTEM TROUBLE
301		TRBL-AC	Unknown	System Troubles	
301	912	TRBL-AC	Zone	System Troubles	AES IP-Link AC Failure
302		TRBL-BAT	Unknown	System Troubles	
302	911	TRBL-BAT	Zone	System Troubles	AES IP-Link Low Battery
303		TROUBLE	Unknown	System Troubles	RAM CKSUM BAD
304		TROUBLE	Unknown	System Troubles	ROM CKSUM BAD
305		TECHNICIAN	Unknown	System Troubles	SYSTEM RESET
305	901	RESTORE	Zone	Special Codes	AES Radio Manual Reset
305	902	RESTORE	Zone	Special Codes	AES Radio Power-On Reset
306		TECHNICIAN	Unknown	System Troubles	PROGRAM CHANGED
307		TECHNICIAN	Unknown	System Troubles	SELF-TEST FAILURE
307	800	TROUBLE	Zone	Special Codes	AES Radio All OK
307	801	TRBL-BAT	Zone	System Troubles	AES Radio Low Battery
307	802	TECHNICIAN	Zone	System Troubles	RAM Data Error/Corrupt
307	803	TECHNICIAN	Zone	System Troubles	U11 RAM Chip Battery Bad
307	804	TECHNICIAN	Zone	System Troubles	AES Radio A to D Converter Faulted
307	805	TECHNICIAN	Zone	System Troubles	Modem Chip Failed or missing
307	806	TECHNICIAN	Zone	System Troubles	Timing Error btwn CPU and Modem
307	807	TECHNICIAN	Zone	System Troubles	Ram Chip Read/Write test Failure
307	808	TECHNICIAN	Zone	System Troubles	AES RAdio Modem Loopback Failed
307	809	TRBL-AC	Zone	System Troubles	AES Radio AC Fail or DC voltage LOW
308		TROUBLE	Unknown	System Troubles	SYSTEM SHUTDOWN
309		TRBL-BAT	Unknown	System Troubles	BATTERY TEST FAIL
309	910	TRBL-BAT	Zone	System Troubles	AES Radio Battery Low

310		TROUBLE	Zone	System Troubles	GROUND FAULT
311		TRBL-BAT	Unknown	System Troubles	BATTERY MISSING
312		TROUBLE	Unknown	System Troubles	POWER SUPPLY OVERCURRENT
313		TECHNICIAN	Unknown	System Troubles	SYSTEM ENGINEER RESET
314		TROUBLE	Unknown	System Troubles	Battery Charger Failure
315		TROUBLE	Zone	System Troubles	Trouble
320		TROUBLE	Zone	Sounder/Relay Troubles	SOUNDER/RELAY
321		TROUBLE	Unknown	Sounder/Relay Troubles	BELL 1
322		TROUBLE	Unknown	Sounder/Relay Troubles	BELL 2
323		TROUBLE	Unknown	Sounder/Relay Troubles	ALARM RELAY
324		TROUBLE	Unknown	Sounder/Relay Troubles	TROUBLE RELAY
325		TROUBLE	Unknown	Sounder/Relay Troubles	REVERSING
326		TROUBLE	Unknown	Sounder/Relay Troubles	NOTIFICATION APPLIANCE CKT #3
327		TROUBLE	Unknown	Sounder/Relay Troubles	NOTIFICATION APPLIANCE #4
328		RESTORE	Unknown	Sounder/Relay Troubles	SIGNAL SILENCED
330		TROUBLE	Zone	System Peripheral Troubles	SYSTEM PERIPHERAL
331		TROUBLE	Unknown	System Peripheral Troubles	POLLING LOOP OPEN
332		TROUBLE	Unknown	System Peripheral Troubles	POLLING LOOP SHORT
333		TECHNICIAN	Unknown	System Peripheral Troubles	EXPANDER MODULE FAIL
334		TROUBLE	Zone	System Peripheral Troubles	REPEATER FAILURE
335		TROUBLE	Unknown	System Peripheral Troubles	PRINT PAPER OUT
336		TROUBLE	Unknown	System Peripheral Troubles	PRINTER FAILURE
337		TROUBLE	Zone	System Peripheral Troubles	EXP MOD DC LOSS
338		TRBL-BAT	Zone	System Peripheral Troubles	EXP MOD LOW BAT
339		RESTORE	Zone	System Peripheral Troubles	EXP MOD RESET
340		TROUBLE	Zone		SYSTEM PERIPHERAL
341		TAMPER	Zone	System Peripheral Troubles	EXPANDER MODULE TAMPER
342		TRBL-AC	Zone	System Peripheral Troubles	EXP. MODULE AC LOSS
343		TROUBLE	Zone	System Peripheral Troubles	EXP. MODULE SELF TEST FAIL
344		TROUBLE	Zone	System Peripheral Troubles	RF RCVR JAM DETECTED
350		TECHNICIAN	Unknown	Communication Troubles	COMMUNICATION
350	951	TRBL-LINE	Zone	Communication Troubles	Primary Comm Path Failure
350	952	TRBL-LINE	Zone	Communication Troubles	Secondary Comm Path Failure
351		TRBL-LINE	Unknown	Communication Troubles	TELCO 1 FAULT
352		TRBL-LINE	Unknown	Communication Troubles	TELCO 2 FAULT
353		TROUBLE	Unknown	Communication Troubles	RADIO XMTR FAULT
353	906	TECHNICIAN	Zone	System Troubles	AES IP-Link UnitID Conflict
354		TECHNICIAN	Unknown	Communication Troubles	COMMUNICATION FAILED
354	906	SUPERVISORY	Zone	Communication Troubles	AES IP-Link IP Checkin Failure
354	907	TECHNICIAN	Zone	Communication Troubles	AES MultiNet Modem Failure
354	908	TECHNICIAN	Zone	Communication Troubles	AES IP-Link Modem Failure
354	915	TECHNICIAN	Zone	Communication Troubles	AES RADIO DIAGNOSTICS FAILED
355		TROUBLE	Unknown	Communication Troubles	RADIO SUPERVISION
355	906	TECHNICIAN	Zone	Communication Troubles	AES IP-Link RF Ping Failure
356		TROUBLE	Unknown	Communication Troubles	RADIO POLLING
356	903	TECHNICIAN	Zone	Communication Troubles	AES Radio Comm Failure
357		TROUBLE	Zone	Communication Troubles	LRR XMTR VSWR
358		TROUBLE	Zone	Communication Troubles	PERIODIC TEST FAILURE
361		TRBL-LINE	Unknown	Communication Troubles	
362		TRBL-LINE	Unknown	Communication Troubles	TELCO 2 FAULT
365	903	TECHNICIAN	Zone	System Troubles	AES Radio Failure
370		TROUBLE	Zone	Protection Loop	
370	009	TECHNICIAN	Zone	System Troubles	AES Radio Battery Charger Failure

370	010	TECHNICIAN	Zone	System Troubles	AES Radio Ground Fault
371		TECHNICIAN	Zone	Protection Loop	PRTCTN LOOP OPEN
372		TECHNICIAN	Zone	Protection Loop	PRTCTN LOOP SHORT
373		TRBL-FIRE	Zone	Protection Loop	
374		EXITFAULT	Zone	Protection Loop	
375		TRBL-SUP	Zone	Protection Loop	PANIC ZONE TROUBLE
376		TRBL-SUP	Zone	Protection Loop	HOLD-UP ZONE TROUBLE
379		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
380		TROUBLE	Zone	Sensor	SENSOR
381		TRBL-SUP	Zone	Sensor	LOSS OF SUPER-RF
382		TRBL-SUP	Zone	Sensor	LOSS OF SUPER-RPM
383		TAMPER	Zone	Sensor	SENSOR TAMPER
384		TRBL-SUP	Zone	Sensor	SENSOR LOW BATT
385		TRBL-FIRE	Zone	Sensor	SMOKE HI SENS.
386		TRBL-FIRE	Zone	Sensor	SMOKE LO SENS.
387		TROUBLE	Zone	Sensor	INTRUSION HI SENS.
388		TROUBLE	Zone	Sensor	INTRUSION LO SENS.
389		TRBL-SUP	Zone	Sensor	DET. SELF TEST FAIL
391		TRBL-SUP	Zone	Sensor	SENSOR WATCH FAILURE
392		TROUBLE	Zone	Sensor	DRIFT COMP. ERROR
393		TROUBLE	Zone	Sensor	MAINTENANCE ALERT
394		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
399		TROUBLE	Unknown	Sounder/Relay Troubles	Trouble
3F0		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
3F1		TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
400		OPEN	User	Open/Close	
401		OPEN	User	Open/Close	
402		OPEN	User	Open/Close	
403		OPEN	User	Open/Close	AUTO-O/C
404		OPEN	User	Open/Close	
405		OPEN	User	Open/Close	
406		ABORT	User	Open/Close	
407		OPEN	User	Open/Close	
408		CLOSE	User	Open/Close	QUICK-ARM
409		OPEN	User	Open/Close	KEYSWITCH
410		OPEN	User	Open/Close	
411		RESTORE	Unknown	Remote Access	REMOTE
412		RESTORE	Unknown	Remote Access	REMOTE SUCCESSFUL
413		RESTORE	Unknown	Remote Access	REMOTE UNSUCCESSFUL
414		AUTOLOG	Unknown	Remote Access	SYSTEM SHUTDOWN
415		AUTOLOG	Unknown	Remote Access	DIALER SHUTDOWN
416		AUTOLOG	Unknown	Remote Access	SUCCESSFUL UPLOAD
421		AUTOLOG	User	Access Control	ACCESS DENIED
422		AUTOLOG	User	Access Control	Access Report
423		AUTOLOG	Zone	Access Control	FORCED ACCESS
424		AUTOLOG	Unknown	Access Control	EGRESS DENIED
425		AUTOLOG	User	Access Control	EGRESS GRANTED
426		OPEN	Zone	Access Control	ACCESS DOOR PROPPED OPEN
427		TRBL-SUP	Zone	Access Control	ACCESS POINT DSM TROUBLE
428		TRBL-SUP	Zone	Access Control	ACCESS POINT RTE TROUBLE
429		TECHNICIAN	User	Access Control	ACCESS PROGRAM MODE ENTRY
430		TECHNICIAN	User	Access Control	ACCESS PROGRAM MODE EXIT
431		AUTOLOG	Unknown	Access Control	ACCESS THREAT LEVEL CHANGE

432	TRBL-SUP	Zone	Access Control	ACCESS RELAY/TRIGGER FAIL
433	AUTOLOG	Zone	Access Control	ACCESS RTE SHUNT
434	AUTOLOG	Zone	Access Control	ACCESS DSM SHUNT
440	CLOSE	Unknown	Test/Misc.	PARTIAL CLOSE
441	OPEN	User	Open/Close	STAY MODE
442	CLOSE	Unknown	Open/Close	KEYSWITCH ARMED STAY
450	OPEN	User	Open/Close	
451	OPEN	User	Open/Close	EARLY
452	OPEN	User	Open/Close	LATE
453	OPEN	User	Open/Close	Auto Disarm
454	TECHNICIAN	User	Open/Close	FAIL TO CLOSE
455	TECHNICIAN	Unknown	Open/Close	AUTO ARM FAIL
456	CLOSE	User	Open/Close	PARTIAL ARM
457	CLOSE	User	Open/Close	User Exit Error
458	ABORT	User	Open/Close	
459	CLOSE	User	Open/Close	RECENT CLOSE
460	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
461	AUTOLOG	Unknown	Open/Close	WRONG CODE ENTRY
462	AUTOLOG	User	Open/Close	LEGAL CODE ENTRY
463	AUTOLOG	User	Open/Close	RE-ARM AFTER ALARM
464	AUTOLOG	User	Open/Close	AUTO ARM TIME EXTENDED
465	AUTOLOG	Unknown	Open/Close	PANIC ALARM RESET
470	CLOSE	User	Open/Close	PARTIAL CLOSE
474	OPEN	Unknown		KEY SWITCH
481	OPEN	User		
482	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
491	CLOSE	User		
4B1	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
4B9	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
4C1	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
500	TECHNICIAN	Unknown		SYSTEM DISABLED
501	TECHNICIAN	Zone	System Disables	ACCESS READER DISABLE
510	TECHNICIAN	Unknown		SYSTEM DISABLED
520	BYPASS	Zone	Sounder/Relay Disables	SOUNDER/RELAY DISABLE
521	BYPASS	Unknown	Sounder/Relay Disables	BELL 1 DISABLE
522	BYPASS	Unknown	Sounder/Relay Disables	BELL 2 DISABLE
523	BYPASS	Unknown	Sounder/Relay Disables	ALRM RELAY DISABLE
524	BYPASS	Unknown	Sounder/Relay Disables	TRBL RELAY DISABLE
525	BYPASS	Unknown	Sounder/Relay Disables	RVRSNG RELAY DISABLE
526	TROUBLE	Unknown	Sounder/Relay Disables	NOTIFICATION APPLIANCE CKT #3
527	TROUBLE	Unknown	Sounder/Relay Disables	NOTIFICATION APPLIANCE CKT #4
531	TECHNICIAN	Unknown	System Peripheral Disables	MODULE ADDED
532	TECHNICIAN	Unknown	System Peripheral Disables	MODULE REMOVED
551	BYPASS	Unknown	Communication Disables	DIALER DISABLE
552	BYPASS	Unknown	Communication Disables	RADIO XMIT DISABLE
553	TECHNICIAN	Unknown	Communication Disables	REMOTE UPLOAD/DOWNLOAD
570	BYPASS	Zone	Bypasses	
571	BYPASS	Zone	Bypasses	FIRE BYPASS
572	BYPASS	Zone	Bypasses	24 HR ZONE BYPASS
573	BYPASS	Zone	Bypasses	BURG BYPASS
574	BYPASS	Zone	Bypasses	GROUP BYPASS
575	BYPASS	Zone	Bypasses	SWINGER BYPASS
576	AUTOLOG	Zone	Bypasses	ACCESS ZONE SHUNT

577	BYPASS	Zone	Bypasses	ACCESS POINT BYPASS
600	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
601	TEST	Unknown	Test/Misc.	TEST MANUALLY TRIG
602	TEST	Unknown	Test/Misc.	PERIODIC TEST
603	TEST	Line	Test/Misc.	PERIODIC RADIO TEST
604	TEST	Unknown	Test/Misc.	FIRE DRILL
605	TECHNICIAN	Unknown	Test/Misc.	STATUS REPORT
606	AUTOLOG	Unknown	Test/Misc.	LISTEN IN ACTIVE
607	TEST	Unknown	Test/Misc.	WALK TEST MODE
607 915	TEST	Unknown	Medical	AHJ INSPECTION STARTED
608	TECHNICIAN	Unknown	Test/Misc.	Abnormal Test
609	AUTOLOG	Unknown	Test/Misc.	VIDEO XMTR ACTIVE
60B	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
610	TEST	Unknown	Test/Misc.	TEST
611	AUTOLOG	Zone	Test/Misc.	POINT TESTED OK
612	AUTOLOG	Zone	Test/Misc.	POINT NOT TESTED
613	AUTOLOG	Zone	Test/Misc.	INTRUSION ZONE WALK TESTED
614	AUTOLOG	Zone	Test/Misc.	FIRE ZONE WALK TESTED
615	AUTOLOG	Zone	Test/Misc.	PANIC ZONE WALK TESTED
616	TROUBLE	Unknown	Test/Misc.	SERVICE REQUEST
621	AUTOLOG	Unknown	Event Log	EVENT LOG RESET
622	AUTOLOG	Unknown	Event Log	EVENT LOG 50% FULL
623	AUTOLOG	Unknown	Event Log	EVENT LOG 90% FULL
624	AUTOLOG	Unknown	Event Log	EVENT LOG OVERFLOW
625	AUTOLOG	Unknown	Event Log	TIME/DATE RESET
626	AUTOLOG	Unknown	Event Log	TIME/DATE WRONG
627	AUTOLOG	Unknown	Event Log	ENTER PROGRAM MODE
628	AUTOLOG	Unknown	Event Log	EXIT PROGRAM MODE
629	TECHNICIAN	Unknown	Event Log	1-1/3 DAY NO EVENT
630	AUTOLOG	Unknown	Scheduling	SCHEDULE CHANGE
631	AUTOLOG	Unknown	Scheduling	EXCEPTION SCHED. CHANGE
632	AUTOLOG	Unknown	Scheduling	ACCESS SCHEDULE CHANGE
634	TEST	Unknown	Test/Misc.	TEST
641	TROUBLE	Unknown	Personnel Monitoring	SENIOR WATCH TROUBLE
642	AUTOLOG	User	Personnel Monitoring	LATCH-KEY SUPERVISION
654	TECHNICIAN	Zone	Test/Misc.	No activity
655	TEST	Unknown	Test/Misc.	
667	TEST	Unknown	Test/Misc.	
680	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
692	TEST	Unknown	Test/Misc.	
698	TEST	Unknown	Test/Misc.	
699	TEST	Unknown	Test/Misc.	
6E5	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
6EE	TECHNICIAN	Unknown	Test/Misc.	UNDEFINED DSC CONTACT ID CODE
777	BURG	Zone	Burglar Alarms	Burg - Crash and Smash
900	TEST	Unknown	Test/Misc.	Test
912	RESTORE	Unknown	Special Codes	FIRE ALARM SILENCE
995	AUTOLOG	Zone		NON-CRITICAL RECEIVER MESSAGE
996	TECHNICIAN	Zone	System Troubles	DISK SPACE LOW
997	TECHNICIAN	Zone	System Troubles	RECEIVER MESSAGE
998	TECHNICIAN	Zone	System Troubles	UNKNOWN SIGNAL
999	TECHNICIAN	Zone	General Alarms	