

JANUARY 2026 FACILITY DEPARTMENT REPORT

1. Executive Summary

January 2026 marked a highly intensive operational month for the Facility Department, focused on reopening the Hub, major infrastructure upgrades, workspace expansion, furniture procurement, and emergency power restoration.

The month featured deep cleaning, installation of new furniture and workspaces, preparation and support for key programmes, and prolonged technical intervention due to a major power and cable theft incident. Despite challenges, the Facility Team ensured full restoration of power and water services before month end and prepared the Hub for full programme resumption.

2. Background

Following the year-end closure, January activities were centered on:

- Preparing the Hub for reopening
- Upgrading workspaces to accommodate increased users
- Supporting strategic programmes and government engagements
- Resolving critical power, solar, and water infrastructure failures

The Facility Department coordinated vendors, technicians, and internal teams to ensure safety, functionality, and readiness of the Hub.

3. Events & Programmes

Jan 15 – 17 | IHH Accelerate Programme

Venue: Pitch Hall & Workspace 1

- Hall and workspace setup for training and breakout sessions
- Seating arrangement, power distribution, and AC monitoring

- Janitorial support throughout the programme

Jan 18 – 22 | Federal Ministry of Housing, Urban Planning & Land Programme

Venue: Hub Facilities

- Multi-day government programme support
- Hall and workspace preparation
- Power management and AC servicing in the Big Hall
- Janitorial and security support throughout

Jan 28 | Learn2Earn Systems Installation

Venue: Workspace 1 (Upstairs)

- Setup and installation of **100 newly delivered systems**
- Furniture arrangement and power coordination for facilitators

Note:

Due to prolonged power and water outage between **Jan 25 – 31**, the Hub was **not open to general users**, and programme activities were limited to internal setups and technical work.

4. Facility Operations (Works & Maintenance)

January 3

- Deep cleaning of the entire Hub (offices, halls, restrooms, outdoor areas)

January 5

- Hub officially reopened for the year
- Servicing of the small generator

January 6

- Procurement of **74 petite office chairs**

January 8

- Intensive landscaping and gardening works carried out

January 9

- Delivery of **100 laptops** for Learn2Earn Programme

January 10

- Commenced work on Big Hall LED screen frame
- LED screen removed for structural adjustment

January 11

- Welding works continued
- Screen frame extended **2 inches forward** to improve fire-access safety

January 12

- Delivery of **19 ergonomic chairs**
- LED screen refitted after frame extension

January 13

- Delivery of wood/plywood boards for construction of new workspace

January 14

- Overnight furniture works for new workspace
- Relocation of items from American Corner to UNDP space

January 15

- Overnight completion of furniture works
- Installation of new booths and workspace tables
- Creation of alternative upstairs workspace

- IIH Accelerate Programme commenced

January 16

- Installation of hand dryers in restrooms
- Water heater switch installed in Facility Management Office
- MD visited with professionals for measurements and spatial analysis for future furniture placement

January 17

- IIH Accelerate Programme concluded

January 18

- Facility preparation for Federal Ministry programme

January 19 – 22

- Federal Ministry of Housing, Urban Planning & Land Programme
- AC repair and maintenance in the Big Hall (19th–20th)

January 21

- Delivery of **3 ergonomic chairs** and **109 petite office chairs**

January 22

- GridCrux commenced work on solar system
- Power began shutting down immediately after breaker was raised

January 23

- Continued GridCrux solar works
- Full power shutdown for diagnostics
- Electrician procured materials
- Furniture works continued in Workspace 1 (Learn2Earn)

- Welding of table frames completed

January 24

- GridCrux continued solar intervention
- Tables added to Workspace 1
- Electrical works concluded

January 25

- Total Hub power outage
- Multiple failed restoration attempts
- Suspected damaged breaker identified

January 26

- Power outage persisted

January 27

- Procurement of spanners and electrical materials

January 28

- New breakers installed
- Partial power restoration achieved
- Learn2Earn facilitators installed and configured new systems

January 29 – 30

- Discovered theft of armored cables
- Inability to pump water or restore full power across the Hub

January 31

- Procurement of replacement armored cables and materials
- Replacement completed

- Full restoration of power and water services

5. Janitorial & Security Summary

Janitorial Services

- Janitorial staff carried out daily cleaning across halls, offices, restrooms, and outdoor areas despite heavy construction works and prolonged technical disruptions.
- Pre-event and post-event cleaning support was consistently provided.
- Hygiene standards were maintained throughout workspace reconfiguration, electrical works, and emergency repairs.

Security Operations

- **Security operations during the month were unsatisfactory and failed to meet required standards.**
- **A serious security breach occurred**, resulting in the **theft of armored electrical cables** within the facility.
- This incident **could only have happened due to negligence and failure of duty by the security personnel on post**, particularly during night surveillance.
- The theft caused:
 - Total power outage across the Hub
 - Inability to pump water
 - Suspension of Hub operations
 - Emergency expenditure to replace stolen infrastructure
 - Reputational damage to the Facility Department and IIH
- This level of failure is **unacceptable** and **cannot be overlooked**.

- **Appropriate disciplinary action must be taken**, and the matter **should be escalated for investigation**, including **possible prosecution**, to serve as a deterrent against future negligence.
- Immediate reinforcement of security supervision, accountability measures, and stricter monitoring is required.

Overall Assessment:

While janitorial services remained dependable, the **security lapse recorded in January represents a grave failure of responsibility**. Urgent corrective action is required, as continued negligence poses a serious risk to IIH assets, operations, and safety.

6. Challenges & Mitigations

- **Extended power outage:**
 - Caused by damaged breakers and theft of armored cables
 - Mitigated through replacement of breakers and stolen cables
- **Solar system instability:**
 - Immediate shutdown after breaker activation
 - GridCrux engaged for diagnostics and corrective works
- **Water supply disruption:**
 - Linked to power outage and cable theft
 - Fully restored after electrical repairs
- **Increased facility demand:**
 - Addressed through creation of new workspaces and procurement of chairs

7. Outcomes & Achievements

- Hub successfully reopened and stabilized after major outage

- New workspaces and booths created to support growing user numbers
- Over **200 chairs** procured and deployed
- LED screen safety improved with extended frame
- Hand dryers and water heater installed
- Learn2Earn infrastructure upgraded with 100 new systems
- Full power and water restored by month end

8. Recommendations

- Improve power infrastructure security to prevent cable theft
- Increase backup power capacity and monitoring
- Continue phased workspace expansion
- Implement preventive maintenance schedule for solar and electrical systems

9. Conclusion

January 2026 was a demanding but productive month for the Facility Department. Despite severe power challenges, the team successfully restored operations, expanded workspaces, supported key programmes, and strengthened the Hub's infrastructure. The Hub is now fully functional and better prepared for increased activity in the coming months.