

ILORIN INNOVATION HUB SPACE ALLOCATION (DEC 2023)			
Area	Suggested Use/Change	Comments/Reason	Party Responsible
Ground Floor			
Reception	Remove Square Storage Block	It serves no real purpose and takes up valuable space. Proposal for reception to be along large wall to the left	KWSG
Restaurant	Open workspace & VIP Lounge	The proposed restaurant area is too large, and is valuable workspace. We want people to be seen working immediately you step into the building.	IHS
Kitchen	Cateteria (Eating Room)	There's no need for food to be cooked within the premises, since the restaurant is now additional workspace. The cafeteria will be a place with a microwave and refrigerator for members to warm food and eat	IHS
Kitchen Store	Additional toilets	The existing toilets are not adequate for the building, especially during large events. This space is close to existing toilets	IHS
Multi-Purpose Hall	Moveable partitioning into two or three sections		IHS
Auditorium/Pitch Room		Wait for Space Finish's Suggestions	IHS
Ground Floor Office Suite 1	Allianz Francais?		KWSG
Ground Floor Office Suite 2	IHS Office Space, etc		KWSG
Ground Floor Workspace			KWSG
Ground Floor Meeting Room	DB Box has been placed here, and is not convenient. Meeting room needs to be moved.	Ask Space Finish and Contractor to discuss this	KWSG
Coffee Lounge	Converted into workspace, coffee stand to be placed against wall		IHS (to be deducted from KWSG BOQ)
Space beside Coffee Stand	Extended workspace area		IHS (to be deducted from KWSG BOQ)
Open Space Adjacent to Ground Floor offices	Additional toilets, Possible American Corner, IT/Server Room, Electronics Store		KWSG
First Floor			
First Floor Workspace	Glass segmentation/partitioning		KWSG
First Floor Walkway	To be used as additional workspace		KWSG
First Floor Corner Space/Relaxation area	Kept as workspace, games like table tennis, snooker to be scattered around building		KWSG
First Floor Exec Offices	MD, Partner Offices		KWSG
Outside			
Outside (Front)	More Trees/Green area	Large tree cut down by contractor was not authorised	KWSG
Outside (Back)	Increase parking space from 30 to 50. Consultant asked to redesign landscape plan		KWSG/IHS additional
Side Outdoor Sitting	Move soak away farther from building to allow roofed area to be used for outdoor sitting area		
Roof/Drainage		Needs to be redone, retrofitting suggestion already discussed with IHS Team	KWSG
Generator House	Should be moved to the front of building beside transformer	To reduce the cost of wiring (underground armored cables) and to keep power infrastructure together. Power in front, water and tanks at the back	KWSG
Miscellaneous			
Elevators	IHS to provide one in front, suggesting one more smaller one at the back		IHS
Solar System Battery Room	Need to figure out where this will be, top candidate is IT/Server Room area		IHS
Air Conditioning	The existing plan for air conditioning will not be ideal, and we are proposing a quick switch to a central system.		IHS (to be deducted from KWSG BOQ)
Drainage		This needs to be double checked from the roof to the gutters and outlet behind building	KWSG