Biax Experiment

For current calibrations - gpfs/group/cjm38/default/Calibrations/ Revised: 30 Nov. 2021

Exp. Name: p5729

Operator(s): Wood, Affinito

Temperature (°C):

Relative Humidity (%):

Date/Time: 13/05/2022

Hydraulics start: 5320.9 Hydraulics end: 5328.8

Data Logger/Control File: 16-chan

 ${\bf Purpose/Description:}\ {\bf Measure\ changes\ in\ perm\ in\ response\ to\ NS/PP\ oscillations\ of\ sawcut}$

sample roughened with 120/80 grit. Onboard DCDTs on A/B intensifiers. Sample Block Used and Thickness with **no** Sample: SDS Vessel 5x5 cm

Material: Westerly Granite

Benchtop Sample Thickness (mm): 32.5

Load Cells: Contact Area: $0.0022231311 m^2$

Load cell name	Calibrations (mV/kN)	Target stress (MPa)	Init. Voltage	Volt. @ load
44mm Solid Horiz	129.984 (V/MPa): 0.289	4, 8.25, 18	0.048	1.20389, 2.43201, 5.24949
44mm Solid Vert	120.364 (V/MPa): 0.2676	0	0	0.

Vessel Pressures:

Pore Fluid:H2O

Calibrations (V/MPa)	Pressures (MPa)	Init. Voltage	Volt. @ load
Pc: 0.1456	2, 8.25, 12	0.029	0.3202, 1.2302, 1.7762
PpA: 1.5177	2.6, 1.4	0.112	4.05802, 2.23678
PpB: 1.483	2.6	-0.076	3.7798

$Displacement\ Transducers$

Name	$Gain\ (mm/V)$
Horiz. Load-point	0.658
Vert. Load-point	3.51
Horiz. On-Board	0.416

Horizontal Servo Settings			
P:	D_{atten} :		
I:	Feedback:		
D:	E-gain:		
Vertical Servo Settings			
Vertical	! Servo Settings		
P:	$Servo\ Settings$ D_{atten}		

Chilled water at HPS	Chiller Unit	Proc. water @ Chiller		
1. Temp In (°F):	6. Panel Temp (°F):	10. Temp In (°F):		
2. Pres. In (psi):	7. Panel Pres. (psi):	11. Pres. In (psi):		
3. Temp Out (°F):	8. Near Pres. In (psi):	12. Temp Out (°F):		
4. Pres. Out (psi):	9. Near Pres. Out (psi):	13. Pres. Out (psi):		
5. Flow (lpm):				
Hyd. Power Supply (HPS)				
14. Tank Temp (°C):	15. Temp. Out (°C):	16. Pres. Out (psi):		

Experiment Notes

- $\#~150~\mathrm{NS}$ to $10~\mathrm{kN}$
- $\#~1850~\mathrm{Pc}$ to $2~\mathrm{MPa}$
- #~2100 saturate PpA to 1-1.5 MPa
- $\#~7000~\mathrm{NS}$ to 9.25 MPa, Pc to 8.25 MPa
- # 22200 PpB, A to 2.6 MPa. PpA to 1.4 MPa. On-board Pp DCDTs have opposite sign of respective LVDTs.
- $\#~44000~\mathrm{Start}$ PpB oscillations and acoustics. First oscillation is practice.
- $\#~1119800~\mathrm{PpB}$ oscillation [0.2, 0.4, 0.6, 0.8, 1.0] MPa and repeat, acoustics run2.
- # 2277000 PpB/A to 0 MPa, Pc to 0 MPa.
- #~2281900 NS to 10 kN.