Biax Experiment

For current calibrations - gpfs/group/cjm38/default/Calibrations/ Revised: 30 Nov. 2021

Exp. Name: p5708

Operator(s): Wood Ko Affinite

Operator(s): Wood, Ke, Affinito Temperature (°C):

Relative Humidity (%):

Date/Time: 22/04/2022

Hydraulics start: 5249.7 Hydraulics end: 5256

Data Logger/Control File: 16-chan

 $\textbf{Purpose/Description:} \ \ \text{measure perm of sawcut westerly granite L-block sawcut and roughened with } 80/120 \ \text{grit.} \ \ \text{Sample Block}$

Used and Thickness with no Sample: SDS Vessel $5x5~\mathrm{cm}$

Sample Block Used and Thickness with ${f no}$ Sample: SDS Vessel 5x5 cm

Material: Westerly Granite

Benchtop Sample Thickness (mm): 32.5

Load Cells: Contact Area: $0.0022231311 m^2$

Load cell name	Calibrations (mV/kN)	Target stress (MPa)	Init. Voltage	Volt. @ load
44mm Solid Horiz	129.984	4, 9.25, 13, 18	0.107	1.26289, 2.77999, 3.86363, 5.30849
	(V/MPa): 0.289	4, 9.29, 19, 10		
44mm Solid Vert	120.364	0	0	0.
	(V/MPa): 0.2676	U		

Vessel Pressures:

Pore Fluid:H20

Calibrations (V/MPa)	Pressures (MPa)	Init. Voltage	Volt. @ load
Pc: 0.1456	2, 8.25, 12, 12	-0.273	0.0182, 0.9282, 1.4742, 1.4742
PpA: 1.5177	2.6, 1.4	-0.068	3.87802, 2.05678
PpB: 1.483	2.6	-0.488	3.3678

$Displacement\ Transducers$

Name	$Gain\ (mm/V)$
Horiz. Load-point	0.658
Vert. Load-point	3.51
Horiz, On-Board	0.416

Horizontal Servo Settings		
P:	D_{atten} :	
I:	Feedback:	
D:	E-gain:	
Vertical Servo Settings		
P:	D_{atten}	
I:	Feedback:	
D:	E-gain:	

Chilled water at HPS	Chiller Unit	Proc. water @ Chiller		
1. Temp In (°F): 60	6. Panel Temp (°F): 69	10. Temp In (°F): 82		
2. Pres. In (psi): 6	7. Panel Pres. (psi): 48	11. Pres. In (psi): 2		
3. Temp Out (°F): 80	8. Near Pres. In (psi): 2	12. Temp Out (°F): 50		
4. Pres. Out (psi): 2	9. Near Pres. Out (psi): 5	13. Pres. Out (psi): 8		
5. Flow (lpm): 15				
Hyd. Power Supply (HPS)				
14. Tank Temp (°C): 51.8	15. Temp. Out (°C): 15	16. Pres. Out (psi): 2500		

Experiment Notes

- #~800 apply 10 kN
- $\#~2600~\mathrm{Pc}$ to $2~\mathrm{MPa}$
- # 3800 saturate, PpA
- $\#~20000~\mathrm{NS}$ to 9.25 MPa, Pc to 8.25 MPa
- $\#~23000~\mathrm{PpB}$ to 1 MPa, adjust PID
- $\#~76000~\mathrm{PpB}$ to 2.6 MPa, PpA to 1.4 MPa
- $\#~310000~\mathrm{NS}$ to 13 MPa, Pc to 12 MPa
- $\#~501000~\mathrm{NS}$ to 18 MPa
- $\#~659000~\mathrm{NS}$ to 13 MPa
- $\#~815000~\mathrm{Pc}$ to $8.25~\mathrm{MPa},~\mathrm{NS}$ to $9.25~\mathrm{MPa}$