



- NOTES:
1. CLEAN TANK COMPLETELY AFTER WELDING.
 2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST.
 3. SECOND TEST TANK AFTER SILLS ARE WELDED.

STEEL TANK & FABRICATING CORP.

COLUMBIA CITY, INDIANA 46725
800-852-9102/260-248-8971/FAX 260-248-8973

DESCRIPTION: 550 GAL FLAMESHIELD SKID TANK WITH 300° WRAP				FOR: AVALON PETROLEUM KANKAKEE, IL			
QUANTITY:	ONE (1)	CAPACITY:	550 GAL.	PAINT:	T.B.D./BLAST IF REQ'D		
DIAMETER:	47"	LENGTH:	72"	LABEL:	UL-142	DRAWN BY:	AMK
MATERIAL:	MCS	HEADS:	INNER 12GA, OUTER 12GA.	SHELL:	INNER 12GA, OUTER 12GA.	SCALE:	N.T.S.
CUSTOMER ORDER #:	-	STAFFED ORDER #:	-	FILENAME:	FSDW550ULSKDT47D.DWG	SHEET	1 OF 1