



NOTES:

1. CLEAN TANK COMPLETELY AFTER WELDING.
2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST.
3. SECOND TEST TANK AFTER SILLS ARE WELDED.

STEEL TANK & FABRICATION CORP.

COLUMBIA CITY, INDIANA 46725
800-852-9102/260-248-8971/FAX 260-248-8973

DW2000ULSKT64D

DESCRIPTION:

DOUBLE WALL UL-142 SKID TANK
W/345° WRAP

FDR:

STOCK

QUANTITY	TWO (2)	CAPACITY	2000 GAL.	PAINT	WHITE ENAMEL/PRIMER/BRUSH BLAST
DIAETER	64"	LENGTH	144"	DRAWN BY	AMK
MATERIAL	MCS	HEADS	7 GA/10 GA	SHELL	7 GA/10 GA
CUSTOMER ORDER #	-	STACCD ORDER #	-	SCALE	N.T.S.
FILENAME	DW2000ULSKT64D.DWG	SHEET	1 OF 1		