



- NOTES:
1. CLEAN TANK COMPLETELY AFTER WELDING.
  2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST.
  3. SECOND TEST TANK AFTER SILLS ARE WELDED.

# STEEL TANK & FABRICATING CORP.

COLUMBIA CITY, INDIANA 46725  
800-852-9102/260-248-8971/FAX 260-248-8973

DW516ULSKT46D

DESCRIPTION:				FOR:			
516 GAL. DOUBLE WALL SKID TANK WITH 345° WRAP				AVALON PETROLEUM KANKAKEE, IL			
QUANTITY:	ONE (1)	CAPACITY:	516 GAL.	PAINT:	WHITE DURETHANE/BLAST SURFACE		
DIAMETER:	46"	LENGTH:	72"	DRAWN BY:	AMK	DATE:	12/30/15
MATERIAL:	MCS	HEADS:	12 GA.	SHELL:	12 GA.	SCALE:	N.T.S.
CUSTOMER ORDER #:	-	STAFCD ORDER #:	-	FILENAME:	DW516ULSKT46D.DWG	SHEET 1 OF 1	