



- NOTES:
1. CLEAN TANK COMPLETELY AFTER WELDING.
 2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE TESTING.
 3. SECOND TEST TANK AFTER SILLS ARE WELDED.

FSDW1000ULSKT64D

STEEL TANK & FABRICATING CORP.

COLUMBIA CITY, INDIANA 46725
800-852-9102/260-248-8971/FAX 260-248-8973

DESCRIPTION: 1000 GAL FLAMESHIELD SKID TANK
WITH 300° WRAP

FOR: **AVALON PETROLEUM**
KANKAKEE, IL

QUANTITY:	ONE (1)		CAPACITY:	1000 GAL.		PAINT:	T.B.D./BLAST IF REQ'D				
DIAMETER:	64"	LENGTH:	72"	LABEL:	UL-142	DRAWN BY:	AMK	DATE:	3/10/18	CHECKED BY:	-
MATERIAL:	MCS	HEADS:	7 GA. INNER 10 GA. OUTER	SHELL:	10 GA. INNER 12 GA. OUTER	SCALE:	N.T.S.				
CUSTOMER ORDER #:	-		STACD ORDER #:	-		FILENAME:	FSDW1000ULSKT64D.DWG			SHEET 1 OF 1	