



NOTES

- 1. SECOND TEST TANK AFTER SILLS ARE WELDED
- 2. CLEAN TANK COMPLETELY AFTER WELDING
- 3. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST

EIGHT(8) WELDS  
EQUALLY SPACED  
START 2" FROM  
END

STEEL TANK & FABRICATING CORP.

COLUMBIA CITY, INDIANA, 46725  
800-852-9102/219-248-8971/FAK 248-8973

QUANTITY	ONE (1)	CAPACITY	1500 GAL	PAINT	T.B.D./BLAST IF REQ'D
DESCRIPTION	1500 GAL FLAMESHIELD SKID TANK WITH 300° WRAP	FDR	AVALLON PETROLEUM KANKAKEE, IL		
DIAMETER	64"	LENGTH	108"	LABEL	UL-142
MAT'L	MCS	HEADS	INNER-7 GA OUTER-10 GA	SHELL	INNER-7 GA OUTER-10 GA
		DRAWN BY	AMK	DATE	3/10/18
		CUSTOMER ORDER #	-	STAFCD ORDER #	-
				CK'ED BY	-