



- NOTES:
1. CLEAN TANK COMPLETELY AFTER WELDING.
  2. INSPECT TANK FOR UNDERCUT & CONCAVE WELDS BEFORE SECOND TEST.
  3. SECOND TEST TANK AFTER SILLS ARE WELDED.
- FSDW2000ULSKT64D

STEEL TANK & FABRICATING CORP.

COLUMBIA CITY, INDIANA 46725  
800-852-9102/260-248-8971/FAX 260-248-8973

DESCRIPTION: 2000 GAL FLAMESHIELD SKID TANK WITH 300° WRAP				FOR: AVALON PETROLEUM KANKAKEE, IL	
QUANTITY:	DNE (1)	CAPACITY:	2000 GAL.	PAINT:	T.B.D/BLAST IF REQ'D
DIAMETER:	64"	LENGTH:	144"	LABEL:	UL-142
MATERIAL:	MCS	HEADS:	INNER 7GA. OUTER 10GA.	SHELL:	INNER 7GA. OUTER 10GA.
		SCALE: N.T.S.			
CUSTOMER ORDER #:	-	STAFCD ORDER #:	-	FILENAME:	FSDW/2000ULSKT64D.DWG
					SHEET 1 OF 1