

TOTAL
ASSETS
TRACKED
156



UNDER
WARRANTY
89



AMC
ACTIVE
112

NEEDS
SERVICE
8

Digital Asset Registry

Asset ID	Asset Name	Category	Property	Location	Install Date	Warranty Expiry
AST-001	DG Set 500KVA	MEP	Apex Tower	Basement	12-Aug-2019	11-Aug-2024 (Expired)
AST-002	Daikin Chiller 100TR	HVAC	Meridian Park	Terrace	05-Jan-2021	04-Jan-2026
AST-003	Schindler Passenger Lift	Lifts	Apex Tower	Lift Shaft	20-Feb-2019	19-Feb-2024
AST-004	VRV Unit Outdoor	HVAC	Crystal Tower	Roof	10-Mar-2022	09-Mar-2027
AST-005	Fire Pump 75HP	Fire Safety	Apex Tower	Pump Room	15-Jun-2020	14-Jun-2025
AST-006	STP Blower	Plumbing	Meridian Park	STP Area	22-Jul-2021	21-Jul-2026

AST-001

DG Set 500KVA
Cummins Power

SPECIFICATIONS

Model No: #C500D5

Fuel Type: HSD

Tank Capacity: 990L

WARRANTY STATUS

Expired - 11 Aug 2024

[View Certificate PDF](#)

AMC DETAILS

TechServe Solutions

Valid till Aug 2025

Terms: 24/7 breakdown support,
Quarterly PPM.

MAINTENANCE LOGS

28-May-2024


Quarterly PPM completed. Oil and filters changed.

15-Feb-2024

Emergency breakdown call. Fuel line airlock cleared.

20-Nov-2023

Quarterly PPM completed. Battery check performed.



SCAN TO LOG SERVICE

[Download Maintenance Report](#)