

FT/EIC *****

Requirements for Electrical Installations

BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	Installation Address	
Client Address		
Client Postcode	Postcode	

Distribution board details - Complete in every case	Complete only if the distribution board is not connected directly to the origin of the installation
SPD Details: Type(s)* T1 ☐ T2 ☐ T3† ☐ N/A ☐	Overcurrent protective device for the distribution circuit: Supply to distribution board is from
Location	No. of phases BS(EN) Type Rating A
Designation	Nominal voltage V RCD BS(EN) Type Rating IΔn mA
No. of ways	

[illegible]

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

FT/EIC *****

Requirements for Electrical Installations

BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name 	Installation Address 	
Client Address 	Client Postcode 	
		Installation Postcode

Distribution board details - Complete in every case Location Designation No. of ways ☐ Supply polarity confirmed ☐ Phase sequence confirmed No. of phases SPD: ☐ Operational status confirmed ☐ Not applicable	Complete only if the distribution board is not connected directly to the origin of the installation Associated RCD (if any): BS (EN) Z_{db} Ω Operating at IΔn ms I_{pr} kA No. of poles Time delay (if applicable)
---	---

[illegible]

Details of circuits and/or installed equipment vulnerable to damage when testing				Date(s) dead testing To	
				Date(s) live testing To	
Test instrument serial number(s)	Loop impedance	Insulation resistance	Continuity	RCD	E/Electrode
Tested by: Name (capital letters)			Signature		
Position	Date				