Power sector: Emissions from Electricity Generation

Jeremy Freeman[1,4], Ali Rouzbeh Kargar[1,4], Heather D. Couture[2,4], Madison Alvara[1,4], Pierre Christian[1,4], Zoheyr Doctor[1,4], Jeyavinoth Jeyaratnam[1,4], Jordan Lewis[1,4], Hannes Koenig[1,4], Tiffany Nakano[3,4], Aaron Davitt[1,4], Christy Lewis[1,4], and Gavin McCormick[1,4]
1) WattTime, 2) Pixel Scientia Labs, 3) Global Energy Monitor, 4) Climate TRACE

1. Introduction

The sector which contributes the most to human-caused climate change is the energy sector. Depending on the data source, from 2015 to 2020, the energy sector contributed, on average, ~76% of global anthropogenic CO_2 emissions, or between 33 and 37 $GtCO_2$ per year (Ge and Friedrich, 2020; Climate Watch, 2022; IEA, 2023). Within the energy sector, electricity generation by combustion power plants (plants which burn fossil fuels, biomass, and/or waste to generate electricity) is responsible for the majority of GHG emissions. This sub-sector alone accounts for an average of ~15 $GtCO_2$, representing ~31% of total global GHG emissions from 2015 to 2020 (Ge and Friedrich, 2020).

The environmental impact of combustion power plants goes beyond GHGs: they also release other harmful pollutants into the air and water which pose a major health hazard to people, animals, and ecosystems (Vohra et al., 2021). Along with GHG emissions, Climate TRACE is providing and tracking the following non-GHG air pollutants associated with combustion power plants: sulfur dioxide (SO_2), nitrogen oxides (NO_X), and particulate matter smaller than 2.5 microns (PM2.5).

Despite the need for timely, accurate emissions data, current approaches to monitoring and estimating power plant emissions remain fragmented and uneven in quality. Reporting requirements differ widely across jurisdictions: some countries publish detailed, high-frequency generation and emissions data at the unit level, while many others report little or nothing at the facility scale, and the data that does exist varies in completeness, timeliness, and methodology. This patchwork makes it difficult to compare emissions consistently across regions, to track changes with the recency that climate and air-quality decisions demand, and to hold individual facilities accountable where reporting is weakest or absent. A timely global facility-level approach is therefore needed to fill these gaps.

Climate TRACE has developed a novel approach to independently track individual power plants' emissions: we use proxy signals in visible satellite imagery (i.e., water vapor plumes co-released with emissions) and a harmonized power plant database pulling from several inventories (see Table 1 below) to estimate power plant electricity generation, which can be translated to emissions. This

effort builds on our previously published work by Couture et al. (2024): "Estimating Carbon Dioxide Emissions from Power Plant Water Vapor Plumes Using Satellite Imagery and Machine Learning". Where available and deemed good quality by a series of data validation tests, we publish electricity generation data from reporting entities (see Table 3). We obtained satellite imagery (Landsat 8 C2, Sentinel-2, and PlanetScope PSScene) for each power plant from 2015 to most recently available imagery, then trained machine learning (ML) models on reported electricity generation data, rather than emissions, as generation is far more widely-available at hourly resolution to align with satellite imagery. Our models are thus designed to estimate electricity generation first and foremost; we then apply power plant specific emissions factors to infer CO_2, SO_2, NO_X, and PM2.5 emissions.

In addition to estimating power plant emissions, we also provide emission reducing solutions (ERS) to understand how changing certain practices and retrofitting equipment can drive the most impact, mainly how solar power generation can reduce power plants emissions. This is discussed further in section 2.4 "Emissions Reducing Solutions."

Overall, Climate TRACE tracks power plant assets and provides monthly GHG (CO_2) and non-GHG (SO_2, NO_X, and PM2.5) within 2-3 months of recorded activity. We then publish at both the country and the asset level. At the asset level, we publish electricity generation, capacity, capacity factor, emissions intensity, emissions, fuel type, geolocation, and plant names for over 11,500 individual power plant assets that represent 96% of total power plant GHG emissions. The country level totals are then the sum of these asset-level estimates plus estimates for the remaining set of plants based on the harmonized database of sources in Table 1 (but which lack metadata sufficient to publish at the facility-level).

2. Materials and Methods

2.1 Overview

Climate TRACE has published monthly electricity generation, carbon emissions, and non-GHG air pollutants - sulfur dioxide (SO_2), nitrogen oxides (NO_X) and particulate matter (PM 2.5) emissions at both the country level and at the asset level for global coverage of combustible power plants for years 2015 to present, published monthly with an approximately two-month lag. We focus on combustible, also called thermal, power because this is the set of power plants that burn fuel to generate electricity and therefore directly generate emissions. Combustible power can be broken into three general categories: fossil (e.g. coal, gas, oil), waste (e.g. municipal garbage, tires) and biomass (e.g. trees, biogas). Burning biomass for power represents ~4% of carbon emissions for the power sector 2015-present, but since biomass carbon emissions are encompassed by Climate TRACE forestry and land use sectors, we subtract biomass-related carbon emissions out from our overall CO_2 emissions estimates to avoid double-counting. However, we continue to provide monthly biomass-related carbon emissions via the "other_4" column of our published asset-level data, which can be summed with the CO_2 column to get total combustible CO_2

emissions. Note that our capacity, capacity factor, electricity generation and non-GHG air pollutant emissions estimates (SO_2, NO_X, and PM2.5) do include biomass, however, because these are not accounted for by the other Climate TRACE sectors.

2.2 Plant Catalog

The foundation of our approach is a harmonized global catalog of combustion power plants, which defines the set of assets for which we estimate electricity generation and emissions. Because no single public dataset provides complete, consistent global coverage of plant locations, capacities, fuels, and operating characteristics, we assemble this catalog by combining several complementary inventories into a single unified database (Table 1). The construction of this harmonized inventory follows the approach described in Couture et al. (2024), Appendix A.1.

The sources in Table 1 provide plant- and unit-level metadata drawn from inventories such as the U.S. EIA-860/860M, the WRI Global Power Plant Database (GPPD), the S&P Global/Platts World Electric Power Plant (WEPP) database, and the Global Energy Monitor (GEM) coal, oil-and-gas, and bioenergy trackers, supplemented by other sources (e.g., company disclosures, press releases). The specific metadata fields contributed by each source vary by dataset and country, as summarized in Table 1. Reported electricity generation from grid operators and regulators, used to estimate plant activity rather than to define the catalog, is described separately in Section 2.3.1 (Table 3).

This harmonized metadata is what the downstream generation and emissions methods depend on: capacity and fuel type anchor the baseline capacity-factor method, cooling tower and flue gas desulfurization attributes determine which plants are eligible for the RS+ML proxy-signal approach, geolocation enables retrieval of satellite imagery, and fuel type and unit characteristics drive the plant-specific emissions factors applied to estimated generation. With the plant catalog assembled, the following sections describe how we estimate monthly electricity generation for each plant in it and convert those estimates to emissions.

Table 1 Datasets employed to create a harmonized Global Combustion Power Plant Inventory

Dataset Name [reference]	Plant Metadata Used	Published (use varying by source/country)
ENTSO-E (European Network of Transmission System Operators	operation start/end dates, capacity	Source Level Data, Aggregated into Country

Dataset Name [reference]	Plant Metadata Used	Published (use varying by source/country)
for Electricity) (ENTSO-E, n.d.)		Level Data
USA CAMPD (Clean Air Markets Program Data) (U.S. EPA, n.d.)	operation start/end dates, capacity	Source Level Data, Aggregated into Country Level Data
US Energy Information Administration EIA-860, EIA-860m (U.S. EIA, n.d.)	Plant Name, Unit Fuel Type, Location, Unit Capacity, Unit Operating Dates, Unit Cooling type, Unit Pollution Control Tech SO_2	Source Level Data, Aggregated into Country Level Data
World Resources Institute (WRI) Global Power Plant Database (GPPD) (World Resources Institute, n.d.)	Plant Name, Plant Fuel Type, Location, Plant Capacity, Plant Operating Dates	Source Level Data, Aggregated into Country Level Data
S&P Global/Platts World Electric Power Plant (WEPP) database (S&P Global Commodity Insights, n.d.)	Unit Fuel Type, Unit Capacity, Unit Operating Dates, Unit Cooling Type, Unit Pollution Control Tech SO_2	The source level dataset is proprietary and is used internally only.
Global Energy Monitor (GEM) Global Coal Plant Tracker (GCPT), Global Oil and Gas Plant Tracker (GGPT), and Global Bioenergy Power Tracker (GBPT) (Global Energy Monitor, n.d.)	Plant Name, Unit Fuel Type, Location, Unit Capacity, Unit Operating Dates	Source Level Data, Aggregated into Country Level Data
Other Sources (e.g., press releases, newspaper articles, company websites)	All	Source Level Data, Aggregated into Country Level Data

2.3 Methods to Ascertain Electricity Generation

We employ three types of methods to estimate electricity generation: reported electricity generation data, baseline country and fuel specific average capacity factor, and remote sensing machine learning derived inference. Each of these are described in the sections below. For any individual power plant asset and month, one or more of these methods may have an estimate and the final activity estimate is an ensemble combining the electricity generation activity estimates. A map of the power plants and the underlying model types is displayed below in Figure 1.




Figure 1: Asset-level Climate TRACE carbon dioxide emissions estimates for January 1, 2025, to December 31, 2025, color-coded by the model types underlying each estimate: emissions based on the baseline country-, and fuel-averages alone (gray), baseline combined with remote sensing inference (yellow), baseline combined with reported data (blue), or baseline combined with both reported data and remote sensing inference (green). Each dot represents one powerplant, sized according to the amount of carbon emissions, ranging from roughly 80 to nearly 33,500,000 metric tons of CO_2.

We publish electricity generation and emissions at monthly resolution from January 2015 to present, with an approximately two-month lag. Rather than distributing annual totals evenly across months (dividing by twelve), we scale each plant's monthly generation — and therefore its emissions — by estimated monthly electricity demand. Monthly demand is estimated for each country, year, and month as the average of two approaches: a Synthetic Electricity Demand profile adapted by WattTime from Mattsson et al. (Mattsson et al., 2021), and an Estimated Load Profile produced by TransitionZero (Hampp, n.d.; Brinkerink et al., 2021). Monthly resolution improves recency and captures seasonal patterns, at the cost of higher uncertainty than annual estimates, driven both by fewer remote-sensing observations per month and by uncertainty in the monthly-demand scaling.

Table 2 reports the share of global asset-level CO_2 emissions attributed to each combination of activity-estimation methods, broken down by region. Each cell gives that region-and-method combination's percentage of the worldwide 2025 total; a region's row total reflects its overall contribution to global power-sector emissions, while the "Global" row gives the worldwide method mix.

Table 2 Regional breakdown of global power-sector CO_2 emissions by activity-estimation methods underlying the assets' estimates (2025); cells are percentages of the global total. See Sections 2.3.1 and 2.3.4 for how reported generation data is used and ensembled with the baseline and RS+ML methods.

Region	Baseline Only	Baseline + RS/ML Inference	Baseline + Reported	Baseline + RS/ML Inference + Reported
Asia	29.7	26.9	10.7	3.7
North America	3.2	0.7	4.1	6.3
Europe	4.3	1.5	1.3	1.7
Africa	2.6	1.1	0.0	0.0
Oceania	0.1	0.0	0.4	0.6
South America	0.4	0.0	0.5	0.1
Global	40.4	30.1	17.1	12.4

2.3.1 Reported Electricity Generation Data

Climate TRACE uses electricity generation data from reporting entities (see Table 3 for the list); to inform power plant activity estimates where the data is available, we have linked it to the asset, and the data passes validation. The validation process runs at the linked entity facility - month level and evaluates the reported electricity data for completeness (e.g. missed hours or days of reporting), and consistency with other available data. For reporting entities that publish net generation (gross generation - station own use), we convert it to gross generation. Some reporting entities only provide data for a subset of the power plant; a common case is that only units above a reporting threshold are reported. In other cases the reporting entity combines all power generated by a single fuel on a plant into one reported value. When the linked facility data only applies to a subset of the power plant, we use the data to estimate the applicable subset of the power plant and rely on the other methods described in section 2.3 to estimate the remaining subset where a reported data estimate is not available.

The uncertainty of electricity generation is evaluated based on the estimated uncertainty of the net to gross correction combined with a constant uncertainty that reflects the unmeasured uncertainty of the reported generation process related to potential errors, omissions, miscategorization, and incorrect linkage to the asset.

Where a linked reporting facility has reported generation but data is not available for the month being estimated, a reported generation gap filling imputation is performed based on the average of the reported data in the same month for the prior three years and the following year where available. This most commonly occurs in the case where a reporting entity has a delay in reporting. The uncertainty of the gap-filled data is estimated based on the number of months of data available and the evaluated RMSE when compared to historical data.

Table 3 Reported activity data sources used.

Country/Region	Publishing Entity	Dataset [reference]
ARG	Compañía Administradora del Mercado Mayorista Eléctrico (CAMMESA)	Post-Operative Report - Monthly (CAMMESA, n.d.)
AUS (NEM)	Australian Energy Market Operator	DISPATCH_UNIT_SCADA (AEMO, n.d.)
AUS (WEM)	Australian Energy Market Operator	Facility SCADA (AEMO, n.d.)
BRA	ONS - Operador Nacional do Sistema Elétrico	Generation per Power Plant on an Hourly Basis (Operador Nacional do Sistema Elétrico, n.d.)
CAN (Alberta)	Alberta Electric System Operator	Historical Generation Data (CSD) (Alberta Electric System Operator, n.d.)
CAN (Ontario)	Independent Electricity System Operator	Hourly Generator Energy Output and Capability Report (Independent Electricity System Operator, n.d.)
CHL	Coordinador Eléctrico Nacional	Actual Generation (Coordinador Eléctrico Nacional, n.d.)
COL	XM Compañía De Expertos En Mercados	National Dispatch (XM Compañía de Expertos en Mercados, n.d.)
DOM	Organismo Coordinador del Sistema Eléctrico Nacional Interconectado (OC)	POST-DELIVERY PER DAY (Organismo Coordinador, n.d.)
Europe	European Network of Transmission System Operators for Electricity (ENTSO-E)	Actual Generation per Generation Unit [16.1.A] (ENTSO-E, n.d.)
IND	Central Electricity Authority, Ministry of Power, Government of India	National Power Portal - Daily and Monthly Generation Reports (Central Electricity Authority, n.d.)
GBR	Elexon	Actual Generation Output Per Generation Unit (B1610) (Elexon, n.d.)
JPN	Organization for Cross-regional Coordination of Transmission Operators (OCCTO)	Unit-by-unit power generation performance disclosure system (OCCTO, n.d.)
KOR	Korea Electric Power Corporation	Power statistics - Monthly Electricity Statistics (Korea Electric Power Corporation, n.d.)

Country/Region	Publishing Entity	Dataset [reference]
MYS	Suruhanjaya Tenaga Malaysia	DAILY SYSTEM GENERATION SUMMARY (last accessed January 2026; page no longer available) (Suruhanjaya Tenaga, n.d.)
NGA	Nigerian Independent System Operator (NISO)	GENCO Hourly Generation (Nigerian Independent System Operator, n.d.)
NIC	El Centro Nacional de Despacho de Carga (CNDC)	Post-Dispatch Energy (MWh) (Centro Nacional de Despacho de Carga, n.d.)
PAN	Empresa De Transmisión Eléctrica, S.A. (ETESA)	Daily Post-Dispatch (ETESA, n.d.)
PER	Comité de Operación Económica del Sistema (COES)	Daily Executed Dispatch (COES, n.d.)
TUR	Epias Transparency Platform (EPIAS)	Real-Time Generation and Injection Quantity (EPİAŞ, n.d.)
TWN	Taiwan Power Company	Concise Monthly Report (Taiwan Power Company, n.d.)
UAE (Dubai)	Dubai Electricity and Water Authority	DEWA Gross Power Generation (page no longer found) (Dubai Electricity and Water Authority, n.d.)
USA	U.S. Environmental Protection Agency (EPA)	Clean Air Markets Program Data (CAMPD) (U.S. EPA, n.d.)
USA	U.S. Energy Information Administration	Form EIA-923 detailed data with previous form data (EIA-906/920) (U.S. EIA, n.d.)

2.3.2 Baseline Method

Climate TRACE's baseline approach for estimating electricity generation at individual power plants is to synthesize the unit-level capacity, fuel, and prime mover information contained in our harmonized power plant inventory for each plant (see Couture et al 2024, Appendix A.1) with EIA and EMBER Yearly Electricity Data country-level annual estimates of capacity and generation by fuel type to calculate the annual average fuel-specific capacity factor in each year reported for each country in the world. We then assume the same capacity factors within each country for each part of the plant with the associated fuel-type. The baseline method that applies to all power plants is needed because 1) the RS+ML approach, despite the satellite's global coverage, cannot estimate generation everywhere: some plants lack the structures that release a detectable plume, some are obscured by clouds or other imaging conditions, and in very hot or humid regions the plume is

harder to distinguish and is removed by our filters; and 2) the reported generation data is not available for all power plants and months in the time period. This baseline method captures the average behavior of the plant type but lacks asset level detail and is therefore reported with higher uncertainties; however, it is helpful as it is applicable to every power plant in the world.

2.3.3 Remote Sensing & Machine Learning Method (RS+ML)

Climate TRACE leverages remote-sensing (RS) proxy signals to estimate monthly electricity generation at individual power plants. We train machine-learning (ML) models to learn the association between electricity generation and the water-vapor plumes released from a power plant's stacks (in layman's terms, the exhaust pipes of a power plant) and cooling towers. We focus on three structures: flue gas desulfurization (a common pollution control for coal; Figure 3), wet natural draft cooling towers (the large hyperbolic structures seen primarily at coal plants; Figure 3), and mechanical draft cooling towers (fan-like structures found across coal and gas plants; Figure 4). Figure 2 provides an overview of this RS+ML proxy-signal approach, and Figure 3 shows an example applied to two observations of a single power plant, detecting plumes from its stacks and flue gas desulfurization.

Mechanical draft cooling towers are an additional proxy signal we are continuing to develop. Because their water-vapor plumes are fainter and harder to detect than those of natural draft towers, we apply a stricter temperature and humidity filter (cooler, wetter conditions produce larger, more visible plumes), and these models perform somewhat less well than the natural draft and FGD models.

For a more detailed explanation of this proxy-signal approach, referred to as "RS+ML" throughout this document, see Couture et al. (2024). The structures that produce these water-vapor plume signals do not exist at every power plant; however, the roughly 4% of plants worldwide that do have them account for nearly half (43%) of carbon dioxide emissions from all non-biomass combustion (fossil and waste) power generation over 2015–2025.




Figure 2: Diagram of RS+ML-enabled proxy signal modeling for monitoring power plant activity to estimate emissions.




Figure 3: ML predictions on the James H. Miller Jr. power plant at low vs. high generation on two observation dates, using PlanetScope PSScene imagery. Separate natural draft cooling tower (NDT) and flue gas desulfurization (FGD) models predicted on NDT (blue) and FGD stacks (red) patches. These predictions were ingested by

subsequent models to estimate generation, then CO_2, SO_2, NO_X, and PM2.5, for the plant. © 2023 IEEE (Hobbs et al., 2023).



Figure 4: Examples of mechanical draft cooling structures (source: Google Maps).

2.3.4 Ensemble Electricity Generation Estimate

Our final published electricity generation estimates are an ensemble of the reported generation estimates (where available), the baseline method estimate, and the RS/ML-enabled proxy signal estimates (where possible). The ensemble process combines all available sources of reported generation, any applicable RS+ML model inference predictions, and the baseline model in a weighted ensemble. Each prediction has a point estimate, a root mean square error uncertainty converted to a mean squared error (MSE), and a confidence level. Each prediction is combined in a weighted ensemble, where each is weighted proportionally to its inverse mean squared error, normalized by the total inverse mean squared error of all available estimates, shown in equations (1) and (2):

$$w_i = \frac{1/\mathrm{MSE}_i}{\sum_{j=1}^{k} 1/\mathrm{MSE}_j} \quad (1)$$

$$\hat{y} = \sum_{i=1}^{k} w_i \hat{y}_i \quad (2)$$

The uncertainty and confidence of the final estimate are combined with the same weighting.

To enable the user to understand what models were used in each power plant emissions estimate, the Climate TRACE asset-level data provides a flag in the "other1" column to indicate if the estimate leveraged: the baseline model (denoted by "a"), the remote sensing and machine learning approach (denoted by "i"), reported generation (denoted by "r"), and/or gap filled reported generation (denoted by "g"). If the plant was non-operational in the period (e.g. the plant is retired or has not yet begun commercial operation), the estimated generation is reported as 0 (denoted in

"other1" by "o"). These flags are presented in descending order of the model weight in the final ensemble.

2.3.5 Emissions Estimation

Once monthly electricity generation is estimated for each unit (Section 2.3), we convert generation to emissions by applying unit-level emission factors (EFs) — the mass of a pollutant emitted per unit of electricity generated. Multiplying a unit's estimated generation by its EF yields that unit's emissions, which are then summed to the plant level. We estimate EFs for CO_2 and for the non-GHG air pollutants SO_2, NO_X, and PM2.5. The unit attributes these EFs depend on — fuel type, boiler and combustion technology, prime mover, and pollution-control equipment — are drawn from the harmonized plant catalog.

2.3.5.1 CO_2 emission factors (carbon intensity)

For coal- and gas-fired units, we apply linear-regression models to estimate each unit's average CO_2 EF, with separate models for coal-fired units, combined-cycle natural gas units, and simple-cycle natural gas units. Model features capture the main drivers of a unit's carbon intensity: unit capacity, coal type, co-generation/CHP, and technology class (subcritical, supercritical, ultra-supercritical) for coal; capacity and turbine class for combined-cycle gas; and capacity, age, co-generation/CHP, and turbine class for simple-cycle gas. The models are trained on datasets combining annual plant-level electricity generation, annual plant-level total CO_2 emissions, and power-plant attributes, restricted to plants that are homogeneous across the relevant attributes; records with unreasonably large or small emission factors are excluded as likely data-quality errors. To assess uncertainty, we fit four regression models across independent folds: the point estimate for each unit's CO_2 EF is the average of the four predictions, and the uncertainty is the RMSE expressed as a percentage of the average EF on each model group's test set. The plant-level CO_2 EF is then derived from the combined unit-level activity and CO_2 emissions. For all other units, we retain CO_2 EFs based on country, fuel type, and prime mover, with an estimated uncertainty of ±25% and lower reported confidence.

2.3.5.2 Non-GHG emission factors (SO_2, NO_X, PM2.5)

These are estimated at the unit level based on fuel type, boiler type, and pollution-control technology. Emission factors are sourced from the EMEP/EEA air pollutant emission inventory guidebook and the EIA Electric Power Annual, and pollution-control efficiencies primarily from US EPA AP-42. Because controls reduce emissions only when operated, in the absence of pollution-control information we generally assume a unit lacks controls, yielding higher (conservative) estimates; the exception is coal units with missing SO_2 control information, for which we assume the most prevalent control type in the region when fewer than half of the region's units lack that information, to avoid introducing bias.

2.3.5.2.1 Primary PM2.5 (filterable and condensable)

We model primary PM2.5 as the sum of filterable PM2.5 (solid particles emitted from the stack) and condensable PM2.5 (vapors that condense into particles as the flue gas cools after leaving the stack; see the FGD stacks, shown as red patches, in Figure 3), modeled separately, each with its own uncontrolled emission factor and control efficiencies. Uncontrolled emission factors are assigned at the unit level by fuel, coal rank, and combustion technology, mainly from US EPA AP-42 (U.S. EPA, n.d.); the exception is filterable PM2.5 from biomass, oil-fired turbines and engines, gas engines, and process gas, which comes from the EMEP/EEA Guidebook (European Environment Agency, 2023). For coal, uncontrolled filterable PM2.5 scales with ash content and uncontrolled condensable PM2.5 with sulfur content (AP-42 Section 1.1). Coal ash content and heating value are taken from country- and rank-specific coal-quality data where available, and from typical values for each coal rank elsewhere (IPCC, 2006); country-specific sulfur content is used only where it is below the rank default. The country-level coal-quality data were compiled from national coal grades and standards (India (Ministry of Coal (India), n.d.), Indonesia (ESDM (Indonesia), n.d.), Vietnam (Ministry of Science and Technology (Vietnam), 2020)), US EIA coal-receipt data (U.S. EIA, n.d.), geological-survey and peer-reviewed coalfield studies (China (Hussain and Luo, 2019), South Africa (Jeffrey, 2005), Australia (Mutton, 2003)), plant-operator data (Laos (Hongsa Power Company Limited, n.d.)), and international coal-trading specifications (globalCOAL, n.d.).

Filterable and condensable PM2.5 are then each reduced according to the unit's pollution-control equipment, using PM2.5-specific control efficiencies from AP-42 (U.S. EPA, n.d.). Particulate controls — electrostatic precipitators (ESPs), fabric filters, and multiclones — remove filterable PM2.5, while ESPs and multiclones do not remove condensable PM2.5, which passes through them as vapor. Wet flue-gas desulfurization (FGD) and wet scrubbers remove part of both components. Dry and semi-dry FGD systems and fabric filters also remove part of the condensable fraction; this is not yet included in our estimates and will be added in a future update. Where no particulate control is recorded for a solid-fuel unit, the control most common for that fuel is assumed; where no SO_2 control is recorded for a coal unit, the country's most common SO_2 control technology is assumed, consistent with our SO_2 estimates.

2.3.5.2.2 Uncertainty and validation

Emission-factor uncertainty is derived from the variability of uncontrolled factors across boiler types and from the regression-model residuals, with confidence scores assigned by data availability. Estimated emissions are validated against reported data, including European Beyond Fossil Fuels data, US CAMPD (SO_2, NO_X) and eGRID (PM2.5), and Australia's National Pollutant Inventory. For PM2.5 specifically, estimates were validated against reported plant-level data — primary PM2.5 from the US NEI, and filterable PM2.5 from Australia's NPI and Canada's reported data — and at the country level our global power-sector PM2.5 total is within 4% of EDGAR v8.1 (downloaded 1 September 2026) (European Commission JRC, n.d.), with our totals for China and India (the two largest PM2.5-emitting countries) each within 5% of EDGAR. Further validation is presented in Section 3.1.

2.3.6 Country-Level Emissions Estimation

In addition to the facility-level estimates described above, we publish country-level emissions totals. Country-level emissions are built directly from the same plant-level modeling pipeline: every combustion power plant in our harmonized inventory receives a monthly electricity generation estimate from the ensemble of reported, RS+ML-inferred, and baseline methods (section 2.3.4), and plant-specific emissions factors are applied to each estimate to obtain monthly CO_2, SO_2, NO_X, and PM2.5 emissions. The country-level total for a given pollutant, country, and month is then the sum of the estimated emissions of all plants located in that country.

This sum includes two groups of plants. The first is the subset of plants with sufficient metadata (e.g., geolocation, fuel, capacity) to be published individually at the asset level, which together account for approximately 96% of global power-sector GHG emissions. The second is the remaining set of plants drawn from the harmonized database that are estimated but lack the metadata required to publish at the facility level; these are included in the national totals even though they are not released as individual assets. Including both groups ensures the country totals reflect complete national coverage rather than only the facility-reported portion.

Country-level totals reflect fossil- and waste-fuel electricity generation only. Emissions from biomass combustion are excluded from the national totals to avoid over-counting with the Climate TRACE forestry and land-use sector, though they are broken out separately at the source level (via the "other_4" column).

2.4 Emissions Reducing Solutions

Beyond quantifying emissions, Climate TRACE publishes Emissions Reducing Solutions (ERSs): data-driven estimates of how targeted interventions could reduce power-sector emissions, intended to help identify high-impact opportunities. The four strategies considered are two related to supply side and two related to demand side. Supply side ERSs include (i) retiring or displacing generation from highly-emitting plants, (ii) matching highly-emitting generation with new clean generation. Demand side ERSs includes deploying (iii) cool roofs and (iv) increasing the adoption of LED lighting. Here we focus on strategies i and ii in section 2.4.1 with both demand-side strategies are discussed in 6.1.

Quantifying the emissions impact of either strategy requires estimating how the grid responds to a change in generation, captured through marginal emissions rates. The following subsections describe the underlying models — the Marginal Operating Emissions Rate (MOER) and Marginal Build Emissions Rate (MBER), combined into a Combined Marginal Emissions Rate (CMER) — and how they are applied to individual power plants.

2.4.1 Model Description

An emissions mitigation intervention, such as that employed by an emission reduction solution (ERS), can influence power grid emissions through two main pathways:

1. By altering the operation of existing grid assets - power plants - thereby changing their emissions profile;
2. By incentivizing structural changes (such as new generators built or old generators being retired) in the grid itself, leading to a longer-term change in the emissions output of the grid

When the interventions in question are changes in load, or the total electricity demand at a point in time, the first pathway is encapsulated in the marginal operating emissions rate (*MOER*), which is defined as the change in emissions per load keeping the grid structure constant, and the second in the marginal build emissions rate (*MBER*), which is the change in emissions per load due to structural changes in the grid. The total emissions change due to an intervention is in general a nontrivial combined effect of the *MOER* and the *MBER*. The Greenhouse Gas Protocol (GHGP) in the Guidelines for Grid-Connected Electricity Projects proposed a method to estimate this combined effect through the formula (Broekhoff et al., 2007),

$$CMER = \omega MBER + (1-\omega) MOER \qquad (3)$$

Where *CMER* is the combined marginal emissions rate, capturing both the operational, *MOER,* and structural, *MBER*, effects of the ERS on the grid, while ω is a weighting parameter. While in principle different interventions could warrant different values of ω, the GHGP recommended that a single ω=½ be used uniformly across all regions, project types, and time periods.

A key ERS in this sector is to build additional clean generators in the region. For each highly-emitting asset (i.e., with emissions rate over the region's CMER), a clean plant can be built to match its generation over a specified period (e.g., monthly or annually). While this new clean generation competes economically with the highly-emitting asset, the variability of clean energy generation means its generation profile is unlikely to align with that of the displaced asset. Therefore it is not expected for the asset's capacity factor (and thus emissions) to fall to zero as a result of this intervention. Instead, the new clean generation displaces emissions at the *system* or *regionally aggregated* level, which can be estimated to be the generation multiplied by the region's CMER.

Regardless of the ERS chosen, a CMER dataset for each region at a monthly cadence would be necessary. This dataset can be constructed through the GHGP formula from separate datasets of MOER and MBER models averaged with an ω parameter of ½.

2.4.2 Marginal Operating Emissions Rate (MOER) Model

The MOER dataset used to quantify the grid response in this ERS is obtained from the WattTime API at a 5-minutes cadence, which is then aggregated monthly (https://docs.watttime.org/). The main component of a MOER model is a regression estimator of the increase in emissions in a particular region due to a change in electrical load, assuming that no structural changes in the power grid occur (Siler-Evans, Azevedo, & Morgan, 2012; Deetjen & Azevedo, 2019; Callaway,

Fowlie, & McCormick, 2018). This component, which is referred to as the Short-Run Marginal Emissions Rate (*SRMER*), can be estimated by a regression model:

$$\Delta Emissions = (SRMER)(\Delta Load) + Controls \qquad (4)$$

where *ΔEmissions* is the change in emissions and *ΔLoad* is the change in electricity load in a particular region. The set of *Controls* are variables that are chosen to ensure that the *SRMER* is well-identified, i.e., that the *SRMER* is indeed a measure of the rate of change of emissions *due to* the change in load (and not due to unrelated factors such as changes in temperature). Examples of these variables include the locational marginal pricing (LMP) of electricity, generation by fuel type, and weather data. In more sophisticated models, the implementation of the control variables can also be extended from mere additional constants to nonlinear functions, such as pre-binning the dataset to slices based on the control variables.

In data-rich regions, it is also possible to train a curtailment model - when energy consumption is purposely reduced - that augments the model with curtailment predictions. For example, low LMP is often indicative of available curtailed energy. In these regions, a curtailment probability model can be trained, and the MOER can then be estimated as:

$$MOER = (1 - P)\,SRMER \qquad (5)$$

Where *P* is the probability for curtailment. In regions where no curtailment model is available, *P* is set to 0 as a default value.

In regions where emissions datasets are unavailable, this regression can be modified to be:

$$\Delta Generation_{fuel} = \beta_{fuel}(\Delta Load) + Controls \qquad (6)$$

where $\Delta Generation_{fuel}$ is the change in generation for a particular fuel type, and β_{fuel} a measure of the change in the generation of said fuel type due to the change in load. Since the emissions per load of a particular fuel type (the carbon intensity of the fuel type) is known, once the regressions are done for all the main fuel types in the region, the SRMER can then be constructed from the β_{fuel}'s measured.

In regions where historical generation by fuel type datasets are not available, the MOER can still be produced by leveraging the principle that similar grids evolve similarly. The annual fuel mix percentages of electricity generation and the electricity demand can be used to group similar grids together. From each group, a representative data-rich power grid can then be chosen to serve as a proxy for the behavior of other grids in the group. In the WattTime implementation of this algorithm, this technique is used for Brazil, Chile, India, Japan, Korea, Malaysia, Nicaragua, Peru, The Philippines, Singapore and Turkey. For regions that lack electricity load data, the real-time load is modelled using weather data via the approach detailed in Mattsson et al (2021).

2.4.3 Marginal Build Emissions Rate (MBER) Model

The MBER encapsulates the changes in emissions due to structural changes in the power grid (e.g., new renewable power generation being built) that is incentivized by changes in electrical load. Unlike the MOER, which measures emissions rates of currently existing power plants, the MBER estimates the emissions effect of future power plants. The GHGP proposes that the MBER can be estimated by the following algorithm (Broekhoff et al., 2007):

1. Collect the operation start year, capacity, generation (or capacity factor), and carbon intensity of power generators in a region at an annual level;
2. Multiply the carbon intensity with the generation to obtain the CO_2 emissions of each generator;
3. Starting from the generators with the most recent operation start year to the oldest, identify the smallest set of start years that accounts for at least 20% of total generation in the region;
4. If there are less than five generators with these start years, add generators from successively older start years until there are five generators in the group;
5. Compute the MBER as the sum of the CO_2 emissions of each unit in the group divided by the sum of the generation of each unit in the group.

This method can be modified from annual to hourly by changing the period in step 1 from annually to hourly to obtain the hourly MBER. In this ERS, this hourly implementation is further aggregated monthly to obtain monthly MBER values. In regions where generation or capacity factor by fuel types are not readily available at an hourly level, demand and weather data can be used to model these inputs and enable the calculation of hourly MBER. More information on specific data sources used and modeling details can be found in the Global Energy Monitor wiki (https://www.gem.wiki/MBERs_methodology).

2.4.4 Incorporating CMERs into ERS

For the case where clean generation is added to the grid, we consider solar power generation sources and assume they are (a) co-located with the existing power plant, and (b) match the generation of the power plant. Here, the existing power plant is not retired, but the addition of non-fossil generation will lower the emissions in aggregate of the power grid. The net emissions reduction is:

$$R_{Solar} = (CMER) \times LOAD \quad (7)$$

where *LOAD* is again the existing load supplied by the power plant. Note that in principle, the amount of clean generation to be added to the grid is independent of the parameters of the existing power plant, and could be an arbitrary fraction of the load of the highly-emitting asset in question. The hourly CMER is aggregated monthly using typical solar generation profiles. In regions where historical renewable profiles are not available, these are generated by physics-informed simulations with weather data reanalysis as inputs (see implementation at renewables.ninja for simulations of solar power generation globally).

2.4.5 Applying ERS to Power Plants to Estimate Emissions Reduction

We apply the solar power generation ERS and the associated CMERs to individual power generation assets by the strategy parameters defined in the Table S4. The solar strategy adds load equal to the existing power generation by setting the "induced_activity_conversion_rate" parameter to -1 so that net emissions are *reduced* by R_{Solar}. The distribution of emissions reduced for all assets is shown in Figure 5. We note one exception for an asset in Democratic Republic of the Congo where the solar CMER is low enough that the emissions reductions are negligible (< 3%) when solar generation is added (see Section 6.1). In this single edge case, we suggest shutting down the plant, which zeroes out the plant's direct emissions, but induces emissions according to a CMER that is weighted with a flat-in-time generation profile rather than a solar generation profile.




Figure 5: Histogram of CO_2 equivalent (100-year GWP) emissions reduced per year for electricity-generation assets under the solar-generation strategy.

3. Results

Final monthly emissions estimates for CO_2, SO_2, NO_X, and PM2.5 are generated for more than 38,000 power plants worldwide. For the more than 11,500 assets with sufficient metadata to be reported individually — which together represent approximately 96% of total power plant GHG emissions — we publish electricity generation, capacity, capacity factor, emissions intensity, emissions, fuel type, geolocation, and plant names at the asset level, monthly within 2–3 months of recorded activity. The country-level totals, published at the same cadence, are the sum of these asset-level estimates plus estimates for the remaining plants in the harmonized database of sources (Table 1) that lack metadata sufficient to publish at the facility level.

3.1 Validation

In Table 4, we compared our modeled emissions against reported emissions CO_2, SO_2, NO_X, and PM2.5. For CO_2, we compared annual Climate TRACE estimates against reported CO_2 emissions from the USA (CAMPD, also used for monthly comparisons; and EGRID), India (CEA), Australia (NGER), Europe (EU ETS), Brazil, Canada, Chile, Israel, Malaysia, Mexico, South Africa, South Korea, and Taiwan. For non-GHG air pollutants, we compared Climate TRACE estimates against annual reported SO_2 and NO_X data from Australia (National Pollutant Inventory), the USA (CAMPD and EGRID), and Canada (GHGRP), as well as PM2.5 reported data from the USA (National Emissions Inventory), Australia (National Pollutant Inventory), and Canada (GHGRP). Based on our comparisons, the US NEI values represent primary PM2.5 (filterable + condensable), while the Australian and Canadian values represent filterable PM2.5 only; each source is therefore compared on the basis it most likely reports. Reported PM2.5 values implying physically implausible emission rates (below a fuel-specific minimum per MWh generated) were excluded from the PM2.5 comparison. A Pearson correlation and root mean squared error were used to compare across all plants successfully matched against the reported data sources mentioned above. All comparisons show a positive correlation with statistically significant p-values (alpha=0.01). Monthly estimates, while more challenging, also do not show any major loss in performance.

Table 4 Overall asset-level validation against reported emissions data

	CO_2		**SO_2**	**NO_X**	**$PM_{2.5}$**
	annual n=22,882	monthly n=174,452	annual n=10,101	annual n=10,101	annual n=7,341
Pearson Correlation (R)	0.95 ($p<0.01$)	0.96 ($p<0.01$)	0.71 ($p<0.01$)	0.77 ($p<0.01$)	0.64 ($p<0.01$)
Root Mean Squared Error (RMSE)	0.96 $MtCO_2$	0.055 $MtCO_2$	1,752 tSO_2	2,034 tNO_X	212 $tPM_{2.5}$
Value Range	0 - 36.52 $MtCO_2$	0 - 1.98 $MtCO_2$	0 - 37,952 tSO_2	0 - 34,830 tNO_X	0 - 7,769 $tPM_{2.5}$

Climate TRACE publishes asset-level (facility-scale) data from January 1, 2019 through the present (with an approximately two-month lag from the current month), so electricity generation and emissions were validated over the same period, subject to data availability (more recent years are sometimes incomplete). For the asset-level validation, Climate TRACE generation estimates were compared against facility-level reported electricity generation — reported at hourly, daily, or monthly resolution depending on the source and summed to monthly and annual totals — from the United States (EIA-923 and CAMPD), Europe (ENTSO-E), India (NPP), Turkiye (EPIAS), the United Kingdom (BSC), Australia (NEM and WEM), South Korea (KEPCO), Japan (OCCTO), Argentina (CAMMESA), Brazil (ONS), Canada (IESO and AESO), Chile (CEN), the Dominican

Republic (OC), Colombia (XM), Malaysia (SETC), Nigeria (NISO), Nicaragua (CNDC), Panama (CND), Peru (COES), Taiwan (TEPC) and UAE Dubai (DEWA). Results are shown in Table 5.

Table 5 demonstrates the results of the possible combinations of the three types of activity estimation models in the ensemble over the set of plants where we have the data to run each type of model on the predictive performance for monthly and annual capacity factor, electricity generation, and carbon dioxide emissions. The increase in performance as more informed models are available is clear. While we recognize and caution that the use of the reported generation data in the ensemble and the evaluation of performance represent data leakage in the electricity generation and capacity factor columns for the last two rows, the data is presented for completeness. The evaluation of the model performance for the carbon dioxide columns is not affected in the same way.

Table 5 Asset-level validation against reported data over the same set of plants, comparing four methods: average-based baseline only; ensembled baseline and RS/ML inference; ensembled baseline and reported data; and an ensemble of the baseline, RS/ML inference, and reported data.

	CAPACITY FACTOR		**ELECTRICITY GENERATION**		**CO_2**	
Method	annual n=5,166	monthly n=65,951	annual n=5,166	monthly n=65,951	annual n=22,882	Monthly n=174,452
Baseline only	R: 0.35 (p<0.01) RMSE: 0.22	R: 0.28 (p<0.01) RMSE: 0.27	R: 0.84 (p<0.01) RMSE: 2.27 TWh	R: 0.78 (p<0.01) RMSE: 232.31 GWh	R:0.89 (p<0.01) RMSE: 1.29 $MtCO_2$	R: 0.81 (p<0.01) RMSE:0.12 $MtCO_2$
Ensembled baseline and RS/ML inference	R: 0.65 (p<0.01) RMSE: 0.18	R: 0.58 (p<0.01) RMSE: 0.23	R: 0.91 (p<0.01) RMSE: 1.73 TWh	R: 0.86 (p<0.01) RMSE: 186.93 GWh	R: 0.91 (p<0.01) RMSE: 1.2 $MtCO_2$	R: 0.85 (p<0.01) RMSE: 0.11 $MtCO_2$
Ensembled baseline and reported data	R: 0.92 (p<0.01) RMSE: 0.08	R: 0.92 (p<0.01) RMSE: 0.10	R: 0.98 (p<0.01) RMSE: 0.69 TWh	R: 0.97 (p<0.01) RMSE: 72.73 GWh	R: 0.94 (p<0.01) RMSE: 0.96 $MtCO_2$	R: 0.96 (p<0.01) RMSE: 0.057 $MtCO_2$
Ensembled baseline, RS/ML inference, and reported data	R: 0.95 (p<0.01) RMSE: 0.07	R: 0.94 (p<0.01) RMSE: 0.09	R: 0.99 (p<0.01) RMSE: 0.63 TWh	R: 0.98 (p<0.01) RMSE: 67.04 GWh	R:0.96 (p<0.01) RMSE: 0.87 $MtCO_2$	R:0.96 (p<0.01) RMSE: 0.055 $MtCO_2$

Since asset-level reporting mechanisms do not include power plants below a certain capacity threshold and the majority of countries do not report on individual power plants, in order to validate

Climate TRACE country-total estimates, we compare against EDGAR 2025 GHG release (EDGAR_2025_GHG) 1.A.1.a Main Activity Electricity and Heat Production emissions for January 1, 2015, through December 31, 2024; see Figures 6 and 7 below for the comparison.




Figure 6: Parity plot of country-level annual CO_2 emissions from electricity generation, Climate TRACE versus EDGAR (EDGAR_2025_GHG, category 1.A.1.a, Main Activity Electricity and Heat Production), 2015–2024. Each point is one country-year (n = 1,664), colored by UNFCCC classification (Annex I: industrialized countries and economies in transition; non-Annex I: developing countries). The dashed line indicates 1:1 agreement and the shaded band ±25%. Pearson correlation coefficient (R), significance (p), and root-mean-square error (RMSE) are shown.




Figure 7: Detail of the comparison in Figure 6, restricted to country-years emitting up to 400 $MtCO_2$ per year.

Climate TRACE's country-level CO_2 estimates agree closely with EDGAR ($R = 0.997$, $p < 0.01$), with the large majority of country-years falling within ±25% of the 1:1 line and the relationship holding across roughly six orders of magnitude in national emission magnitude. Some disparity is expected and does not indicate error in either dataset. In particular, EDGAR's 1.A.1.a category reports emissions from both electricity and heat production, whereas Climate TRACE estimates emissions from electricity and combined heat and power generation specifically. This scope difference introduces a systematic upward offset in EDGAR, and we therefore expect greater disparity in countries and regions where heat only production — such as district heating — accounts for a larger share of fuel combustion in the 1.A.1.a Main Activity Electricity and Heat Production sector. The overall RMSE is dominated by the largest emitters, but the strong correlation across the full range of countries indicates that these two independently derived estimates are broadly consistent.

3.1.1 Verifying modeled ERS emissions estimates

The CMER used in the emissions estimates has been demonstrated to be consistent with direct observations of emissions changes obtained from natural experiments. The MOER was validated in ERCOT using changes in the potential of wind generation in Steinsultz et al. (2024). As wind output fluctuates, the other fuel types in the region adjust to maintain the balance between load and generation, producing a net effect comparable to random variations in load. By treating wind fluctuations as exogenous shocks, the MOER can be estimated empirically without the need of a true randomized controlled trial on the power grid. In this case, the estimation was performed by the following regression:

$$\Delta Emissions = (MOER)\Delta W + Controls \quad (8)$$

where ΔW are changes in the wind generation potential, and the set of controls are chosen to ensure the regression is well-identified. This study found that the MOER measured by the statistical regression technique is consistent with the validation data obtained from the wind regression (see Figure 8).




Figure 8: Comparison of the MOER measured using a variety of models against natural experiments from wind generation (top); the model used in this ERS is labelled as "Statistical", and subplots labelled "Heat Rate", "Dispatch", "Average", and "LMP" are alternative MOER models. The close alignment between the "Statistical" model with the empirical data ("Benchmark MEF") indicates that the Statistical MOER used in this ERS reliably captures real-world emissions impacts. The "Dispatch" model also performed well on this validation test, but can only be utilized in a limited number of grids. See Steinsultz et al., 2024 for details.

Another validation study carried out across several U.S. balancing authorities (TVA, ISONE, DUK, CPLE, CAISO, and FPL; represented by the solid colored bars in Figure 9) further found the MOER model to be consistent with direct observations of emissions changes (Christian et al. 2025a). This study follows a similar approach to Steinsultz et al. (2024), but instead employs nuclear outages as the exogenous shocks. A machine learning model was first trained to predict the emissions of a region with a substantial share of nuclear generation. The model's predictions (the "Statistical" legend label, grey-hatched bar in Figure 9) were then compared against observed emissions during periods of nuclear outages (solid bars in Figure 9). Because the total generation and load has to remain balanced during the outage, the difference between the prediction and the observed emissions provides an estimate of the emissions change due to a load increase equivalent to the nuclear generation loss. The result of this study, shown in Figure 9, demonstrated that the MOER model ("Statistical" legend label in Figure 9) employed in this ERS is consistent with the MOER measured by this natural experiment.




Figure 9: Comparison of the MOER measured using a variety of models against natural experiments from nuclear outages; the model used in this ERS is labelled as "Statistical" (Christian et al., 2025a). Empirically observed emissions rate measured during nuclear outages for each balancing authority are the left-most solid colored bars for each Shock ID that occurred in each Balancing Authority (BA; 95% confidence interval included), separated by the black dashed-lines: TVA = dark blue bar; ISONE = green bar; DUK = purple bar; CPLE = pink bar; CAISO = yellow bar; and FPL = light blue bar. The hatched bars to the right of each solid bar represent different predicted emissions corresponding to different emissions models: Statistical (MOER) model = grey-hatched bar; AVERT = orange-hatched bar; Cambium Mid-case = light blue-hatched bar; and AOER = green-hatched bar.

The CMER constructed using the GHGP weighting parameter method has been validated using a similar method in Christian et al. 2025b, where exogenous load shocks are used to empirically estimate the MOER in PJM, ERCOT, MISO, SPP, ISONE, and NYISO. As shown in Figure 10, the empirical validation signal aligns closely with the CMER ("Model LRMER"), indicating that this formulation of the CMER reliably captures the real-world emissions impacts of load interventions. Christian et al (2025b) also validated the choice of ω=½ recommended by the GHGP guidelines. Comparing a weighting parameter of 0, ½, and 1, this study found that a weighting parameter of ½ to be the most consistent with the empirical validation signal and has the lowest error (see Figure 11).




Figure 10: Comparison of the CMER utilized in this ERS ("Model LRMER") and the empirical validation dataset of the emissions effect of load interventions ("Empirical Validation"). The close agreement between the CMER and the empirical validation signal demonstrates that the CMER reliably captures the real-world emissions impacts of load interventions. Cambium LRMER and AOER refers to other models for computing emissions (see Christian et al., 2025b for details).




Figure 11: The error on the measured CMER signal (compared to an empirical validation baseline) for different weighting parameters (Christian et al., 2025b). Blue bar: weight = 1/2 (LRMER Error 29.73 lbs/MWh); Orange bar: weight = 0 (LRMER Error -249.72 lbs/MWh); Green bar: weight = 1 (LRMER Error 309.18 lbs/MWh).

4. Discussion

In this work, we present Climate TRACE's approach to estimating emissions from combustion power generation at the individual-plant level and globally. We publish monthly electricity generation alongside CO_2 and the non-GHG air pollutants SO_2, NO_X, and PM2.5, together with each plant's metadata at both the country and asset levels from 2015 to present, with an approximately two-month lag. These estimates are produced through a weighted ensemble of three methods — reported generation where available and validated, RS+ML-enabled proxy signal inference where detectable plume producing structures are present, and a globally applicable baseline method for all plants. In total, we model more than 38,000 power plants and publish asset-level estimates for the more than 11,500 with sufficient metadata, which together account for approximately 96% of global fossil- and waste-fuel power-sector CO_2 emissions in 2025 (13.32 $GtCO_2$), with new data published monthly within two to three months of recorded activity.

Several limitations should be noted. Because the RS+ML proxy-signal approach is only applicable to the share of plants with detectable plume-producing structures, and reported generation is available only for a subset of countries and facilities, the baseline method is applied to the majority of plants by count but accounts for about 40% of global power-sector emissions (see Table 2); the remaining ~60% are estimated using the ensemble methods that incorporate baseline, RS+ML inference, and/or reported generation. This baseline assigns country- and fuel-specific annual-average capacity factors and therefore cannot capture plant-level variation, seasonality, or dispatch behavior, resulting in higher uncertainty for these estimates. The RS+ML approach is itself constrained by imagery availability and by atmospheric conditions. Because all pollutant estimates are derived by applying plant-specific emissions factors to estimated generation, uncertainty in both the generation estimates and the emissions factors propagates to the final CO_2, SO_2, NO_X, and PM2.5 values. Ongoing work focuses on expanding reported-data coverage and extending the proxy-signal approach to a larger share of plants to progressively reduce reliance on the baseline method.

4.1 Discussion on ERS

Beyond quantifying emissions, these estimates support Emissions Reducing Solutions (ERS) — strategies for using the data to reduce power-sector emissions (Section 2.4). Here we discuss two such strategies and the practical considerations that affect their applicability.

Retiring highly-emitting power generators would be the optimal method to reduce the emissions in this sector, especially in regions where the CMER is relatively low. However, several practical barriers limit the widespread implementation of this ERS. The power grid must continuously balance load and generation, meaning that any loss of generation must be compensated by increased output from other generators. In regions with sufficient unused capacity, this can be achieved by raising the capacity factors of existing generators. In contrast, if available capacity is insufficient, new generation assets must be developed to replace the retired capacity. Retiring highly-emitting but serviceable generators is also unattractive from a cost perspective. In practice, instead of wholesale retirement, these plants might be kept online but run less: as new renewable

capacity comes onto the grid, these plants are progressively displaced, with their activity and capacity factors declining over time rather than dropping to zero at a single retirement date. Consequently, this retirement strategy is likely only viable in regions with ambitious clean energy targets and either ample unused clean capacity or a strong commitment to rapidly building new clean generators.

On the other hand, matching highly-emitting generators with new clean generation is a more broadly applicable strategy. While this generation matching requirement is novel, the underlying concept builds on prior discussions of clean energy matching in the context of load matching, where new clean generation is built to match specific loads or emissions associated with those loads. Moreover, numerous power grids are rapidly increasing clean energy investments even in the absence of explicit matching requirements, reflecting a broader commitment to clean energy investments. In some regions, policy measures (e.g., renewable energy targets) and market forces (e.g., the lower operating costs of clean energy) can drive the construction of clean generators, even without this ERS. In such cases, this ERS can be rendered non-additional, as it would not produce further emissions reductions beyond those that would have occurred anyway. However, it should be noted that additionality is not a binary. Even in regions where some of the emissions avoidance of this ERS is non-additional, its adoption might still drive some incremental emissions avoidance.

5. Conclusion

Climate TRACE provides the data that makes it possible to answer questions that drive impactful, precise climate action. Whether the priority is to reduce greenhouse gas emissions or air pollution, or both, these questions can be directly answered by plots above and the data continually updated on climatetrace.org. Coupled with Climate TRACE data on other sectors - manufacturing, shipping and aviation, etc. - a life cycle analysis is possible along the entire supply chain, of which power generation is just one piece. This enables businesses, investors, governments, and even consumers to quantify the greenhouse gas and/or air pollution footprint(s) of products and compare the trade-offs between one supply chain vs. another. With this information and the lines of thinking enabled by it, we can make climate action faster and easier by uncovering how to slash the maximum total emissions on a global scale with the fastest and easiest actions possible.

Future work includes improving electricity generation, and thus emissions, estimates by incorporating additional data sources and alternate modeling approaches to improve the baseline model as well as expand the set of plants to which we can apply remote sensing and machine learning via additional proxy signals (e.g. heat signatures via thermal satellite imagery). Non-GHG air pollutant emissions estimates, while new and carrying high uncertainties given technology differences across the world, offer an additional lens to explore the intersections between industry, climate change, and environmental justice at high spatial and temporal resolution. We look forward to collaborating to drive increased accuracy and actionable insights.

6. Metadata

Country-level emissions estimates for electricity generation are available for download at ClimateTRACE.org, and the following table summarizes this data.

Table S1 General dataset information for "country-climate-trace_electricity-generation_{VERSION}.csv"**.**

General Description	Definition
Sector definition	*Electricity Generation*
UNFCCC sector equivalent	*1.A.1.a.i Electricity Generation, 1.A.1.a.ii Combined Heat and Power Generation*
Temporal Coverage	*January 1, 2015 – present (2 month lag from current month)*
Temporal Resolution	*Monthly*
Data format(s)	*CSV*
Coordinate Reference System	*EPSG:4326, decimal degrees*
Number of sources available for download and percent of global emissions	*11,543 unique sources across January 1, 2019 - present (2 month lag from current month); totaling 13.32 $GtCO_2$ in 2025, representing 96% of all fossil/waste fuel power plant emissions in 2025.*
Ownership	*Ownership data was obtained from Global Energy Monitor (GEM) and the U.S. Energy Information Administration (EIA) for the U.S.*
What emission factors were used?	*Carbon intensity values for combinations of energy source and prime mover technology were modeled based on CO_2 emission factors (carbon intensity) data. Non-GHG air pollutant emissions factors for SO2 and NO_X were sourced from the EMEP/EEA air pollutant emission inventory guidebook 2023; PM2.5 emission factors were sourced from the US EPA's AP-42, supplemented by the EMEP/EEA guidebook for biomass and engine and turbine fuels.*
What is the difference between a "NULL / none / nan" versus "0" data field?	*"0" values are for true non-existent emissions. If we know that the sector has emissions for that specific gas, but the gas was not modeled, this is represented by "NULL/none/nan"*
total_CO2e_100yrGWP and total_CO2e_20yrGWP conversions	*Climate TRACE uses IPCC AR6 CO_2e global warming potentials (GWPs). CO_2e conversion guidelines are here: https://www.ipcc.ch/report/ar6/wg1/downloads/report/IPCC_AR6_WGI_FullReport_small.pdf.*
Do the estimates include emissions from biomass fuels?	*No, due to concerns of overcounting since biomass is accounted for by the Climate TRACE forestry and land use sector. Electricity CO_2 emissions reported at the country level are from fossil/waste fuel electricity generation only. Emissions resulting from biomass are not included in the country totals but are available at the source-level for 2019-present year (2 month lag from current month), via the "other_4" column, and upon request at the country level for 2015-present year (2 month lag from current month). For plants that burn both fossil/waste and biomass, emissions are appropriately broken out based on the power plant's capacity of each fuel type.*

Source-level emissions estimates for electricity generation are available for download at ClimateTRACE.org, and the following two tables summarize this data.

Table S2: Asset level metadata description for asset-climate-trace_electricity-generation_{VERSION}.csv. Note, fields marked with an asterisk (*) indicate fossil/waste fuel CO_2 emissions, and GWP are broken out separately from biomass fuel to avoid double-counting emissions from the Climate TRACE forestry sector. Capacity, capacity factor, generation, SO_2 emissions, NO_X emissions, PM 2.5 emissions do include biomass, however (they include all combustible fuels – fossil, waste, biomass).

Data attribute	Definition
sector	*Electricity Generation*
asset definition	*Each asset is an individual power plant.*
start_date	*[string] Gregorian time period start in YYYY-MM-DD format. For example, for the month of January 2024,* start_date *is* "2024-01-01".

Data attribute	Definition
end_date	*[string] Gregorian time period end as a string in YYYY-MM-DD format. For example, for the month of January 2024,* end_date *is* "2024-01-31".
asset_identifier	*[string] Unique identifier for assets (power plants). For example, use the* asset_identifier *column in* asset *to match to* ownership*'s* asset_id *column.*
model_number	*[string] Date results were produced*
asset_name	*[string] Power plant name*
iso3_country	*[string] ISO 3166 Alpha-3 country code*
location	*[shapely.Point] Coordinates x,y (longitude, latitude) for the power plant's location*
type	*[string] power plant fuel type. note: multiple fuel types are listed in order of prevalence for power plants that burn more than one type of fuel.*
capacity description	*[integer] power plant fossil/waste/biomass fuel capacity in MW sourced from harmonized power plant database described in Table 1, representing the instantaneous maximum electricity the power plant is capable of generating under normal conditions.*
capacity_units	*megawatts (MW)*
capacity_factor description	*[float] Climate TRACE estimated power plant average fossil/waste/biomass fuel utilization rate for a given plant and time period calculated as generation / capacity * hours in time period*
capacity_factor_units	*Proportion of power plant utilization multiplied by number of hours in time period, (MWh per MW capacity) on a scale from 0 to 1*
activity_description	*[integer] Climate TRACE estimated power plant total fossil/waste/biomass fuel generation in MWh for a given power plant and time period.*
activity_units	*megawatt-hour (MWh)*
CO2_emissions_factor	*[float] Carbon intensity values for combinations of energy source and prime mover technology were modeled based on CO_2 emission factors (carbon intensity) data*
CH4_emissions_factor	*NaN (CH_4 not tracked for electricity generation)*
N2O_emissions_factor	*NaN (N_2O not tracked for electricity generation)*
SO2_emissions_factor	*[float] We estimate emission factors for SO_2 and NO_X at the power plant unit-level based on fuel type, boiler type, and pollution control technology, according to guidance provided in the 2023 EMEP/EEA air pollutant emission inventory guidebook, 2023 EIA Electric Power Annual, and the US EPA's AP-42.*
NOX_emissions_factor	
PM2_5_emissions_factor	*[float] Primary PM2.5 (filterable + condensable) emission factor, estimated at the unit level from US EPA AP-42 emission factors (supplemented by the 2023 EMEP/EEA air pollutant emission inventory guidebook for biomass and engine and turbine fuels) and PM2.5-specific control efficiencies, based on fuel type, coal quality, boiler type and pollution control technology (see Section 2.3.5).*
CO2_emissions	*[integer] Climate TRACE estimated power plant total CO_2 emissions from fossil/waste fuels* for a given time period.*
CH4_emissions	*NaN (CH_4 not tracked for electricity generation)*
N2O_emissions	*NaN (N_2O not tracked for electricity generation)*
SO2_emissions	*[integer] Climate TRACE estimated power plant total SO_2 emissions from fossil/waste/biomass fuels for a given time period.*
NOX_emissions	*[integer] Climate TRACE estimated power plant total NO_X emissions from fossil/waste/biomass fuels for a given time period.*
PM2_5_emissions	*[integer] Climate TRACE estimated power plant total primary PM 2.5 emissions (filterable + condensable) from fossil/waste/biomass fuels for given time period.*
total_CO2e_100yrGWP	*[integer] Climate TRACE estimated power plant total fossil/waste fuel* CO_2 100-year global warming potential (GWP), rounded to the nearest integer for a given time period. Since CO_2* is *the only gas currently tracked, this is equal to* CO2_emissions.
total_CO2e_20yrGWP	*[integer] Climate TRACE estimated power plant total fossil/waste fuel* CO_2 20-year global warming potential (GWP), rounded to the nearest integer for a given time period. Since CO_2 is the only gas currently tracked, this is equal to* CO2_emissions.
other1_description	*[string] Describes what capacity factor and activity estimation methods were included in the ensemble. These flags are presented in descending order of the model weight in the final ensemble.*
other1_units	a *= baseline activity model;* i *= RS+ML inference approach, r = reported generation, g = gap filled reported generation, o = plant was not operational in the period*
other2_description	*[integer] power plant biomass-only capacity in MW sourced from harmonized power plant database described in Table 1, representing the instantaneous maximum electricity from biomass the power plant is capable of under normal conditions.*
other2_units	*megawatts (MW)*
other3_description	*[integer] Climate TRACE estimated power plant total biomass-only generation in*

Data attribute	Definition
	MWh for a given power plant and time period.
other3_units	*megawatt-hour (MWh)*
other4_description	*[integer] Climate TRACE estimated power plant total CO_2 emissions from biomass-only* in metric tons (tonnes) for a given time period.*
other4_units	*metric tons (tonnes) abbreviated tCO_2*
other5_description	*[float] capacity factor*
other5_units	*Unitless proportion of power plant utilization, MW per MW, on a scale from 0 to 1*
other6	*N/A (not used)*
other7_description	*[float] grid marginal operating emissions intensity*
other7_units	*tCO_2 per MWh*

Table S3 describes source level metadata description confidence and uncertainty for "confidence-climate-trace_electricity-generation_{VERSION}.csv" and "uncertainty-climate-trace_electricity-generation_{VERSION}.csv"**.**

Confidence is defined on a 5-point scale from very low to very high

Data attribute	Confidence Definition	Uncertainty Definition
type	Confidence in fuel type reported. Set to 4 = High for all plants because data is sourced from the harmonized power plant inventory as described in Table 1	N/A
capacity_description	Confidence in capacity reported. Set to 4 = High for all plants because data is sourced from the harmonized power plant inventory as described in Table 1	Uncertainty in capacity reported. Estimated at 3% for all plants
capacity_units	megawatts (MW)	megawatts (MW)
capacity_factor_description	Capacity factor is electricity generation divided by power plant capacity. The confidence is the weighted ensemble of the confidence where the underlying models take the following confidence: 5 = Very high (reported generation) 4 = High (NDT model inference and gap-filled reported generation) 3 = Medium (FGD and MDT model inference) 2 = Low (baseline model) 1 = Very Low (not used)	For reported data: uncertainty is the weighted ensemble RMSE from the underlying uncertainty from each model in the ensemble
capacity_factor_units	on a scale from 0 to 1 (proportion)	on a scale from 0 to 1 (proportion)
activity_description	average between capacity and capacity factor confidences, resulting in some set to 4="high" (those modeled with ML+satellites and with some amount of NDT) and the remaining majority set to 3="medium."	uncertainty was calculated as the square root of the sum of the squared fractional uncertainties for capacity and capacity factor, assuming independent random errors. Thus, for electricity generation $g = cf$ for capacity c and capacity factor f with independent random errors ϵ_c and ϵ_f respectively, the electricity generation uncertainty $\epsilon_g = g\sqrt{(\epsilon_c/c)^2 + (\epsilon_f/f)^2}$.
activity_units	Megawatt-hour (MWh)	Megawatt-hour (MWh)
CO2_emissions_factor	3 = "medium" for units where the linear regression model is applicable 2 = "low" for units where country-fuel-prime mover average models are used.	Model specific uncertainty from cross validation results for the linear regression models and 25% of the CO_2 emissions factor, for units where

Data attribute	Confidence Definition	Uncertainty Definition
		country-fuel-prime mover average models are used.
CH4_emissions_factor	N/A	N/A
N2O_emissions_factor	N/A	N/A
SO2_emissions_factor	We assign the confidence score based on the data availability and our fallback approach. If we are able to match the data attributes required for both, uncontrolled EF and pollution control efficiency, without applying our fallback strategy described above, we assign a confidence score of 3 ("medium"). If we have to rely on other fuel types to obtain control efficiencies or average across all boiler types of the unit's fuel to obtain the uncontrolled EF, we assign a confidence score of 2 ("low"). In all other cases, we assign a confidence score of 1 ("very low").	To obtain the uncertainty value, we calculate the standard deviation across a boiler type's uncontrolled EFs associated with a fuel that belongs to the unit's fuel type class. For example, we calculate the standard deviation across the EFs of all coals, e.g., lignite, subbituminous, etc. per boiler type. If we are able to match the boiler type from our database to a boiler type available in the source data, we report this standard deviation as the uncertainty. If that match is not available, we calculate the standard deviation across all EFs associated with the fuel type class and report this standard deviation as the uncertainty.
NOX_emissions_factor		
PM2_5_emissions_factor		
CO2_emissions	taken as the average between the confidence scores for capacity, capacity factor, and CO_2 emissions factor.	For capacity c, capacity factor f, and CO_2 emissions factor e, with uncertainties ϵ_c ,ϵ_f ,ϵ_e respectively, CO_2 emissions uncertainty ϵ_m for CO_2 emissions m are propagated as the square root of the sum of the squared fractional uncertainties of each of these three factors: $\epsilon_m = m\sqrt{(\epsilon_c/c)^2+(\epsilon_f/f)^2+(\epsilon_e/e)^2}$
CH4_emissions	N/A	N/A
N2O_emissions	N/A	N/A

Data attribute	Confidence Definition	Uncertainty Definition
SO2_emissions	taken as the average between the confidence scores for capacity, capacity factor, and each pollutants emissions factor	For capacity c, capacity factor f, and emissions factor e, with uncertainties ϵ_c ,ϵ_f ,ϵ_e respectively, emissions uncertainty ϵ_m for emissions m are propagated as the square root of the sum of the squared fractional uncertainties of each of these three factors: $\epsilon_m = m\sqrt{(\epsilon_c/c)^2+(\epsilon_f/f)^2+(\epsilon_e/e)^2}$
NOX_emissions		
PM2_5_emissions		
total_CO2e_100yrGWP	same as CO_2 emissions, since the GWP factor for CO_2 is 1	same as CO_2 emissions, since the GWP factor for CO_2 is 1
total_CO2e_20yrGWP	same as CO_2 emissions, since the GWP factor for CO_2 is 1	same as CO_2 emissions, since the GWP factor for CO_2 is 1

6.1 Emission Reduction Solutions Information

With electricity generation, the majority of assets received the ERS "Replace activity with solar generation" strategy while one asset received the ERS "Shut down electricity generation" strategy.

Democratic Republic of the Congo edge case- Shut down electricity generation asset

Shutting down electricity generation assets targets the energy sector, which is the largest contributor to global CO_2 emissions. This strategy relies on identifying high-emitting power generators in a region using a combined marginal emissions rate (CMER) and asset-level emissions data. This strategy was applied to the power plant edge case identified in the Democratic Republic of the Congo since replacing power generation with the solar CMER produced negligible emissions reductions.

Replace activity with solar generation

Table S4 highlights the ERS solar renewable generation applied to the majority of power plants to reduce emissions.

Table S4: Electricity generation solar renewable generation strategy metadata

Data attribute	Definitions
strategy_name	Replace activity with solar generation
strategy_description	Replace activity with solar generation
mechanism	add
max_activity_affected_ratio	1
co2_emissions_factor_new_to_old_ratio	0

ch4_emissions_factor_new_to_old_ratio	0
n2o_emissions_factor_new_to_old_ratio	0
confidence	medium
exponential_decay_emissions_factor	FALSE
exponential_decay_activity	FALSE
induced_sector_1	electricity-generation
induced_sector_1_activity_conversion_rate	-1

Deploy cool roofs

Electricity used in buildings is a large share of power-sector demand, and air conditioners and electric fans account for nearly 20% of the electricity used in buildings worldwide, or about 10% of global electricity consumption (IEA, 2018). Light-coloured or reflective "cool roofs" cool buildings passively by reflecting more sunlight. Cool roof surfaces can be 28–30°C cooler than conventional roofs on hot afternoons, lowering indoor air temperatures by 2–3°C (Project Drawdown, 2026) and reducing the electricity needed for cooling. Modelling across climates shows the largest savings in hot climates with high cooling loads (Synnefa, Santamouris and Akbari, 2007).

The strategy is modelled as a reduction in electricity-generation activity. Following the Climate TRACE buildings methodology, buildings account for 18% of indirect emissions from electricity and heat production (Climate TRACE, 2025). Cooling is taken as 20% of that demand, and cool roofs are assumed to cut cooling electricity by 10%. The share of generation activity affected is therefore roughly 49 Mt CO_2e a year against current asset-level total electricity generation emissions of about 13.32 Gt. Because ERS data are annual, the seasonality of cooling demand does not affect the estimate.

Cool roofs are a cheap, proven technology. They have been widely applied in the United States, where installed area exceeded 232 million m² by 2023, and piloted through programs such as New York City's CoolRoofs initiative and the Global Cool Cities Alliance (Project Drawdown, 2026; US EPA, n.d.). Benefits are concentrated in warmer climates, and global emissions impact is modest. Wider adoption could be supported by building codes and industry best practice.

Table S5: Deploy cool roofs strategy metadata

Data attribute	Definitions
strategy_name	Deploy cool roofs

strategy_description	Using cool roofs in hot climates can reduce energy use by 10-20%.
mechanism	subtract
max_activity_affected_ratio	0.0036
co2_emissions_factor_new_to_old_ratio	0
ch4_emissions_factor_new_to_old_ratio	0
n2o_emissions_factor_new_to_old_ratio	0
confidence	high
exponential_decay_emissions_factor	FALSE
exponential_decay_activity	FALSE
induced_sector_1	NA
induced_sector_1_activity_conversion_rate	NA

Achieve 90% adoption of LED lighting

Lighting is a significant share of global electricity demand. Light-emitting diodes (LEDs) consume far less electricity than incandescent or fluorescent lamps for the same light output. Switching to LED lighting lowers electricity demand and therefore reduces generation, and emissions, at fossil-fuel power plants.

About half of lamps in use worldwide (50.5%) are already LEDs, avoiding an estimated 0.36 Gt CO_2e each year. Raising adoption to roughly 90% of lamps would avoid 0.62–0.65 Gt CO_2e a year in total (Project Drawdown, 2025). The strategy models only the additional reduction beyond current adoption: $(0.64 - 0.36) \approx 0.28$ Gt CO_2e, which is about 2% of current asset-level total electricity generation emissions of about 13.32 Gt. It is represented by removing 2% of electricity-generation activity, with very high confidence given the maturity of the technology.

LEDs are a mature, cost-saving technology. Adoption varies widely between countries. That shows high adoption is achievable, and countries that lag can make meaningful reductions by matching those that have largely converted to LEDs.

Table S6: Achieve 90% adoption of LED lighting strategy metadata

Data attribute	Definitions

strategy_name	Deploy LED lighting
strategy_description	Replace incandescent, halogen, fluorescent, and other inefficient lighting with high-efficiency LEDs, targeting 90% of installed lighting.
mechanism	subtract
max_activity_affected_ratio	0.02
co2_emissions_factor_new_to_old_ratio	0
ch4_emissions_factor_new_to_old_ratio	0
n2o_emissions_factor_new_to_old_ratio	0
confidence	very high
exponential_decay_emissions_factor	FALSE
exponential_decay_activity	FALSE
induced_sector_1	NA
induced_sector_1_activity_conversion_rate	NA

Permissions and Use: All Climate TRACE data is freely available under the Creative Commons Attribution 4.0 International Public License, unless otherwise noted below.

Data citation format:
Freeman, J., Rouzbeh Kargar, A., Couture, H.D., Alvara, M., Christian, P., Doctor, Z., Jeyaratnam, J., Lewis, J., Koenig, H., Nakano, T., Davitt, A., Lewis, C., and McCormick, G. (2026). *Power sector: Emissions from Electricity Generation.* WattTime, USA; Pixel Scientia Labs, USA; and Global Energy Monitor, USA. Climate TRACE Emissions Inventory. https://climatetrace.org [Accessed date]

Geographic boundaries and names (iso3_country data attribute): The depiction and use of boundaries, geographic names and related data shown on maps and included in lists, tables, documents, and databases on Climate TRACE are generated from the Global Administrative Areas (GADM) project (Version 4.1 released on 16 July 2022) along with their corresponding ISO3 codes, and with the following adaptations:

- HKG (China, Hong Kong Special Administrative Region) and MAC (China, Macao Special Administrative Region) are reported at GADM level 0 (country/national);
- Kosovo has been assigned the ISO3 code 'XKX';
- XCA (Caspian Sea) has been removed from GADM level 0 and the area assigned to countries based on the extent of their territorial waters;

- XAD (Akrotiri and Dhekelia), XCL (Clipperton Island), XPI (Paracel Islands) and XSP (Spratly Islands) are not included in the Climate TRACE dataset;
- ZNC name changed to 'Turkish Republic of Northern Cyprus' at GADM level 0;
- The borders between India, Pakistan and China have been assigned to these countries based on GADM codes Z01 to Z09.

The above usage is not warranted to be error free and does not imply the expression of any opinion whatsoever on the part of Climate TRACE Coalition and its partners concerning the legal status of any country, area or territory or of its authorities, or concerning the delimitation of its borders.

Disclaimer: The emissions provided for this sector are our current best estimates of emissions, and we are committed to continually increasing the accuracy of the models on all levels. Please review our terms of use and the sector-specific methodology documentation before using the data. If you identify an error or would like to participate in our data validation process, please contact us.

7. Errata

See the "Known Issues" section of the changelog hosted on the Climate TRACE GitHub repo for each release for information on errata and known issues for each monthly data update published.

7.1 Methodology updates

The methodology has evolved through several updates since our 2024 journal article (based on 2023 Climate TRACE data); the current methodology is described in full in Sections 2.2–2.4. The list below records when each major change was introduced.

- **Sep 2024** — Added non-GHG air pollutant (SO_2, NO_X, PM2.5) emission estimates (Section 2.3.5); introduced monthly-resolution estimates (2015–present) scaled by estimated monthly demand; added the mechanical-draft cooling-tower RS+ML proxy signal (Section 2.3.3).
- **Mar 2025** — Began the ongoing monthly data-release schedule (60-day lag).
- **Aug 2025** — Introduced reported electricity generation data for Brazil (ONS), Europe (ENTSO-E), and the US (CAMPD) (Section 2.3.1).
- **Oct 2025** — Expanded reported generation to India (NPP) and Australia/NEM (Section 2.3.1).
- **Nov 2025** — Introduced Emissions Reducing Solutions (ERS) (Section 2.4).
- **Sep 2026** — Expanded reported generation to ~18 additional entities (Table 3); introduced the inverse-MSE weighted ensemble of reported, baseline, and RS+ML estimates (Section 2.3.4); introduced regression-based CO_2 carbon-intensity emission factors for coal and gas units (Section 2.3.5).
- **Oct 2026** — Updated the PM2.5 methodology to model primary PM2.5 as separate filterable and condensable components (Section 2.3.5).

8. References

1. Ge, M.; Friedrich, J. 4 Charts Explain Greenhouse Gas Emissions by Countries and Sectors; World Resources Institute: Washington, DC, USA, 2020. Available online: https://www.wri.org/blog/2020/02/greenhouse-gas-emissions-by-country-sector (accessed on 6 June 2023).
2. Climate Watch. Climate Watch Historical GHG Emissions; World Resources Institute: Washington, DC, USA, 2022. Available online: https://www.climatewatchdata.org/ghg-emissions (accessed on 1 July 2023).
3. IEA (International Energy Agency). Greenhouse Gas Emissions from Energy Data Explorer; IEA: Paris, France, 2023. Available online: https://www.iea.org/data-and-statistics/data-tools/greenhouse-gas-emissions-from-energy-data-explore (accessed on 1 July 2023).
4. Vohra, K.; Vodonos, A.; Schwartz, J.; Marais, E.A.; Sulprizio, M.P.; Mickley, L.J. Global mortality from outdoor fine particle pollution generated by fossil fuel combustion: Results from GEOS-Chem. *Environ. Res.* 2021, *195*, 110754. https://doi.org/10.1016/j.envres.2021.110754
5. Mattsson, N.; Verendel, V.; Hedenus, F.; Reichenberg, L. An autopilot for energy models —Automatic generation of renewable supply curves, hourly capacity factors and hourly synthetic electricity demand for arbitrary world regions. *Energy Strategy Rev.* **2021**, *33*, 100606. https://doi.org/10.1016/j.esr.2020.100606
6. Hampp, J. Euronion/Synde. GitHub. Available online: https://github.com/euronion/synde (accessed on 23 August 2021).
7. Brinkerink, M.; Ó Gallachóir, B.; Deane, P. Building and Calibrating a Country-Level Detailed Global Electricity Model Based on Public Data. *Energy Strategy Rev.* **2021**, *33*, 100592. https://doi.org/10.1016/j.esr.2020.100592
8. Hobbs, M.; Kargar, A.R.; Couture, H.; Freeman, J.; Söldner-Rembold, I.; Ferreira, A.; Jeyaratnam, J.; O'Connor, J.; Lewis, J.; Koenig, H.; et al. Inferring carbon dioxide emissions from power plants using satellite imagery and machine learning. In Proceedings of the IEEE International Geoscience and Remote Sensing Symposium, Pasadena, CA, USA, 16–21 July 2023.
9. Broekhoff, D.; et al. Guidelines for Quantifying GHG Reductions from Grid-Connected Electricity Projects; World Resources Institute: Washington, DC, USA, 2007. Available online: https://ghgprotocol.org/sites/default/files/2022-12/Guidelines%20for%20Grid-Connected%20Electricity%20Projects.pdf.
10. Callaway, D.; Fowlie, M.; McCormick, G. Location, location, location: The variable value of renewable energy and demand-side efficiency resources. *J. Assoc. Environ. Resour. Econ.* **2018**, *5*, 39–75.

11. PJM Interconnection. Marginal Emission Rate—A Primer; 2021. Available online: https://www.pjm.com/-/media/DotCom/etools/data-miner-2/marginal-emissions-primer.ashx.
12. Christian, P.; Cofield, J.; Koebrich, S.; McCormick, G. Causal emissions factor benchmarks during contingent nuclear outages. *Environ. Res. Commun.* **2025a**, *7*, 055001. https://doi.org/10.1088/2515-7620/add1b3
13. Christian, P.; Steinsultz, N.; McCormick, G. On Empirical Validation of Marginal Build Emissions Rates; SSRN Working Paper; **2025b**. Available online: https://ssrn.com/abstract=5425615.
14. Deetjen, T.A.; Azevedo, I.L. Reduced-order dispatch model for simulating marginal emissions factors for the United States power sector. *Environ. Sci. Technol.* **2019**, *53*, 10506–10513.
15. Siler-Evans, K.; Azevedo, I.L.; Morgan, M.G. Marginal emissions factors for the U.S. electricity system. *Environ. Sci. Technol.* **2012**, *46*, 4742–4748.
16. Steinsultz, N.; Christian, P.; Cofield, J.; McCormick, G.; Sofia, S. Validating locational marginal emissions models with wind generation. *Environ. Res. Energy* **2024**, *1*, 035008. https://doi.org/10.1088/2753-3751/ad72f6
17. Couture, H.D.; Alvara, M.; Freeman, J.; Davitt, A.; Koenig, H.; Rouzbeh Kargar, A.; O'Connor, J.; Söldner-Rembold, I.; Ferreira, A.; Jeyaratnam, J.; et al. Estimating Carbon Dioxide Emissions from Power Plant Water Vapor Plumes Using Satellite Imagery and Machine Learning. *Remote Sens.* **2024**, *16*, 1290. https://doi.org/10.3390/rs16071290
18. Operador Nacional do Sistema Elétrico (ONS). Generation per Power Plant on an Hourly Basis; ONS: Brasília, Brazil. Available online: https://dados.ons.org.br/
19. European Network of Transmission System Operators for Electricity (ENTSO-E). Actual Generation per Generation Unit [16.1.A]; ENTSO-E Transparency Platform. Available online: https://transparency.entsoe.eu/
20. U.S. Environmental Protection Agency (EPA). Clean Air Markets Program Data (CAMPD); U.S. EPA Office of Air and Radiation: Washington, DC, USA. Available online: https://campd.epa.gov/
21. Central Electricity Authority (CEA), Ministry of Power, Government of India. National Power Portal—Daily and Monthly Generation Reports; CEA: New Delhi, India. Available online: https://npp.gov.in/
22. Australian Energy Market Operator (AEMO). DISPATCH_UNIT_SCADA; AEMO National Electricity Market (NEM): Melbourne, Australia. Available online: https://www.aemo.com.au/
23. U.S. Energy Information Administration (EIA). Form EIA-860 and EIA-860M, Annual Electric Generator Report; EIA: Washington, DC, USA. Available online: https://www.eia.gov/electricity/data/eia860/

24. World Resources Institute (WRI). Global Power Plant Database; WRI: Washington, DC, USA. Available online: https://datasets.wri.org/datasets/global-power-plant-database
25. S&P Global Commodity Insights. World Electric Power Plants (WEPP) Database; S&P Global: New York, NY, USA. Available online: https://www.spglobal.com/commodityinsights/
26. Global Energy Monitor (GEM). Global Coal Plant Tracker, Global Oil and Gas Plant Tracker, and Global Bioenergy Power Tracker; GEM: San Francisco, CA, USA. Available online: https://globalenergymonitor.org/
27. Compañía Administradora del Mercado Mayorista Eléctrico (CAMMESA). Post-Operative Report—Monthly; CAMMESA: Buenos Aires, Argentina. Available online: https://www.cammesa.com/
28. Australian Energy Market Operator (AEMO). Facility SCADA; AEMO Wholesale Electricity Market (WEM): Perth, Australia. Available online: https://data.wa.aemo.com.au/#facility-scada
29. Alberta Electric System Operator (AESO). Historical Generation Data (CSD); AESO: Calgary, Canada. Available online: https://www.aeso.ca/
30. Independent Electricity System Operator (IESO). Hourly Generator Energy Output and Capability Report; IESO: Toronto, Canada. Available online: https://www.ieso.ca/
31. Coordinador Eléctrico Nacional (CEN). Actual Generation; CEN: Santiago, Chile. Available online: https://portal.api.coordinador.cl/documentacion?service=sipubv2
32. XM Compañía de Expertos en Mercados. National Dispatch; XM: Medellín, Colombia. Available online: https://www.xm.com.co/
33. Organismo Coordinador del Sistema Eléctrico Nacional Interconectado (OC). Post-Delivery per Day; OC: Santo Domingo, Dominican Republic. Available online: https://www.oc.org.do/
34. Elexon. Actual Generation Output per Generation Unit (B1610); Elexon: London, UK. Available online: https://www.elexon.co.uk/
35. Organization for Cross-Regional Coordination of Transmission Operators (OCCTO). Unit-by-Unit Power Generation Performance Disclosure System; OCCTO: Tokyo, Japan. Available online: https://www.occto.or.jp/
36. Korea Electric Power Corporation (KEPCO). Power Statistics—Monthly Electricity Statistics; KEPCO: Naju, South Korea. Available online: https://home.kepco.co.kr/
37. Suruhanjaya Tenaga (Energy Commission of Malaysia). Daily System Generation Summary; Suruhanjaya Tenaga: Putrajaya, Malaysia. Available online: https://www.st.gov.my/
38. Nigerian Independent System Operator (NISO). GENCO Hourly Generation; NISO: Abuja, Nigeria. Available online: https://www.niso.ng/

39. Centro Nacional de Despacho de Carga (CNDC). Post-Dispatch Energy (MWh); CNDC: Managua, Nicaragua. Available online: https://www.cndc.org.ni/
40. Empresa de Transmisión Eléctrica, S.A. (ETESA). Daily Post-Dispatch; ETESA: Panama City, Panama. Available online: https://www.etesa.com.pa/
41. Comité de Operación Económica del Sistema (COES). Daily Executed Dispatch; COES: Lima, Peru. Available online: https://www.coes.org.pe/
42. Enerji Piyasaları İşletme A.Ş. (EPİAŞ). Real-Time Generation and Injection Quantity; EPİAŞ Transparency Platform: Istanbul, Türkiye. Available online: https://seffaflik.epias.com.tr/
43. Taiwan Power Company (Taipower). Concise Monthly Report; Taipower: Taipei, Taiwan. Available online: https://www.taipower.com.tw/
44. Dubai Electricity and Water Authority (DEWA). DEWA Gross Power Generation; DEWA: Dubai, UAE. Available online: https://www.dewa.gov.ae/
45. U.S. Energy Information Administration (EIA). Form EIA-923, Power Plant Operations Report (with EIA-906/920 predecessor data); EIA: Washington, DC, USA. Available online: https://www.eia.gov/electricity/data/eia923/
46. U.S. Environmental Protection Agency (EPA). AP-42: Compilation of Air Emissions Factors, Fifth Edition, Volume I, Chapter 1: External Combustion Sources and Chapter 3: Stationary Internal Combustion Sources; U.S. EPA: Research Triangle Park, NC, USA. Available online: https://www.epa.gov/air-emissions-factors-and-quantification/ap-42-compilation-air-emissions-factors-stationary-sources
47. European Environment Agency (EEA). EMEP/EEA Air Pollutant Emission Inventory Guidebook 2023, Chapter 1.A.1 Energy Industries; EEA: Copenhagen, Denmark, 2023. Available online: https://www.eea.europa.eu/publications/emep-eea-guidebook-2023
48. European Commission, Joint Research Centre (JRC). Emissions Database for Global Atmospheric Research (EDGAR); JRC: Ispra, Italy. Available online: https://edgar.jrc.ec.europa.eu/
49. Intergovernmental Panel on Climate Change (IPCC). 2006 IPCC Guidelines for National Greenhouse Gas Inventories, Volume 2: Energy, Chapter 1, Tables 1.1–1.2; IGES: Hayama, Japan, 2006.
50. Ministry of Coal, Government of India. Coal Grades. Available online: https://coal.gov.in/major-statistics/coal-grades
51. Kementerian Energi dan Sumber Daya Mineral (ESDM), Republic of Indonesia. Harga Batubara Acuan (HBA) and Harga Patokan Batubara (HPB), reference coal qualities; ESDM: Jakarta, Indonesia.
52. Ministry of Science and Technology, Vietnam. TCVN 8910:2020, Commercial Coal – Specifications; Hanoi, Vietnam, 2020.

53. U.S. Energy Information Administration (EIA). Electric Power Annual, Table 7.2: Receipts and Quality of Coal Delivered for the Electric Power Industry; EIA: Washington, DC, USA. Available online: https://www.eia.gov/electricity/annual/
54. Hussain, R.; Luo, K. The Geological Availability and Emissions of Sulfur and SO_2 from the Typical Coal of China. Aerosol and Air Quality Research 2019, 19, 559–570. https://doi.org/10.4209/aaqr.2018.08.0281
55. Jeffrey, L.S. Characterization of the Coal Resources of South Africa. Journal of the Southern African Institute of Mining and Metallurgy 2005, 105(2), 95–102.
56. Mutton, A.J. (compiler). Queensland Coals: Physical and Chemical Properties, Colliery and Company Information, 14th ed.; Queensland Department of Natural Resources and Mines: Brisbane, Australia, 2003.
57. Hongsa Power Company Limited. Hongsa Mine Mouth Power Project – Key Mine Facts (lignite specifications); hosted by the Department of Mineral Resources, Thailand.
58. globalCOAL. Standard Coal Trading Agreement (SCoTA), coal quality specifications by origin; globalCOAL: London, UK.
59. Climate TRACE (2025) Estimating global high-resolution onsite building emissions: Building sector methodology. Climate TRACE Coalition. Available at: https://github.com/climatetracecoalition/methodology-documents/tree/main/2025/Buildings (Accessed: 27 July 2026).
60. IEA (2018) The Future of Cooling: Opportunities for energy-efficient air conditioning. Paris: International Energy Agency. Available at: https://www.iea.org/reports/the-future-of-cooling (Accessed: 27 July 2026).
61. Project Drawdown (2026) Deploy cool roofs. Drawdown Explorer. Available at: https://drawdown.org/explorer/use-cool-roofs (Accessed: 27 July 2026).
62. Synnefa, A., Santamouris, M. and Akbari, H. (2007) 'Estimating the effect of using cool coatings on energy loads and thermal comfort in residential buildings in various climatic conditions', Energy and Buildings, 39(11), pp. 1167–1174. Available at: https://doi.org/10.1016/j.enbuild.2007.01.004 (Accessed: 27 July 2026).
63. US EPA (n.d.) Using cool roofs to reduce heat islands. Washington, DC: United States Environmental Protection Agency. Available at: https://www.epa.gov/heatislands/using-cool-roofs-reduce-heat-islands (Accessed: 27 July 2026).
64. Project Drawdown (2025) Deploy LED lighting. Drawdown Explorer. Available at: https://drawdown.org/explorer/deploy-led-lighting (Accessed: 8 July 2026).