



General Maintenance

Client Name	Holiday Inn Express Dublin City Centre	Job No	206
Client Site	Austinbrook Ltd 28-32 O'Connell Street Dublin 1 D01 T2X2		
Client Contact	Darren Murray		
Date	17/08/2023	PPM Visit	2 of 2

Asset No		Plant Item	
Comments		Satisfactory	No
Requires Attention			

Repair Required	No		
Engineers Name	Des Cleere	Engineers Signature	



General Maintenance

Client Name	Holiday Inn Express Dublin City Centre	Job No	206
Client Site	Austinbrook Ltd 28-32 O'Connell Street Dublin 1 D01 T2X2		
Client Contact	Darren Murray		
Date	17/08/2023	PPM Visit	2 of 2

Asset No	021	Plant Item	Mcc panel
Comments	Mcc panel located in plant room. Checked and tightened electrical connections, 400v, 125amp, 3 phase panel, 230v/24v control Panel good condition, tidy and drawings in panel	Satisfactory	Yes
Requires Attention	No		

Repair Required	No		
Engineers Name	Des Cleere	Engineers Signature	