HOLIDAY INN EXPRESS O'CONNELL ST

M1421 Holiday Inn Express O'Connell Street Dublin 1 Ireland Contact: Joe



Crystal Air

Unit 3 Butterstream, Business Park, Kildare

Ireland Tel: 0035345893228

E-mail: service@crystalair.ie

J15006

Job is Completed

SCHEDULED	JOB LEAD	CREW
24/07/2023, 08:00	Brandon Myers	

CLOSED BY OFFICE: Yes

JOB DETAILS

CLOSED BY: Livia/Quarterly Payment Plan OFFICE JOB DESCRIPTION: Job 1 on PPM

Major Visit 1 on Bedroom Extract Fans, 1st visit on these units, please tag.

JOB TYPE: PPM

APPRENTICE REQUIRED/PRESENT: Yes

MATERIALS USED: CUSTOMER PURCHASE ORDER NUMBER: PO Number For Invoicing MATERIALS TO BE QUOTED: INVOICING CODE: Maintenance (M)

JOB DESCRIPTION

As per request to complete on this PPM visit duct work in bathroom for extracts have been cleaned and noted if working or not. Listed below are issues highlighted:

First Floor - No extraction being provided:

Rooms: 107, 108, 111, 112, 113, 114, 115, 116, 117, 118, 119, 120, 121, 122, 123, 124, 125

No extraction with restrictions: (Damper closed)

Rooms: 109, 110, 136

Second Floor - No extraction is being provided:

Rooms: 204, 206, 207, 208, 209, 210, 211, 215, 216, 217, 218, 219, 220, 222, 223, 224, 225

No extraction with restrictions: (Damper closed) Rooms: 213, 212, 221, 233 & 234 (Flexi pipe to short)

Third Floor - No extraction is being provided:

Rooms: 308, 310, 311, 312, 313, 314, 315, 316, 317, 318, 319, 321, 324, 325

No extraction with restrictions: (Damper closed)

Rooms: 307, 309, 320, 323

Fourth Floor - No extraction is being provided:

Rooms: 407, 408, 410, 411, 415, 416, 417, 419, 420, 421, 422, 423, 424, 425, 427, 428

No extraction with restrictions: (Damper closed)

Rooms: 409, 413, 414

Fifth Floor - No extraction is being provided:

Rooms: 501, 502, 507, 508, 509, 510, 512, 513, 514, 515, 516, 517, 521, 522, 523, 526, 528, 531

No extraction with restrictions: (Damper closed)

Rooms: 511, 519

Crystal Air

Sixth Floor - No extraction is being provided:

Rooms: 602, 605, 630, 631

No extraction with restrictions: (Damper closed)

Rooms: 611

Speaking with Joe on site one of the main extracts is out of service which would provide the solution to lack of extraction. Crystal Air does not look after the operation or maintenance of this plant.

ASSETS

NAME	SERIAL NUMBER	MAKE	MODEL	MANUFACTURER
45920 Bedroom 102	N/A	N/A	N/A	N/A
45922 Bedroom 104	N/A	N/A	N/A	N/A
45924 Bedroom 106	N/A	N/A	N/A	N/A
45925 Bedroom 107	N/A	N/A	N/A	N/A
45927 Bedroom 109	N/A	N/A	N/A	N/A
45928 Bedroom 110	N/A	N/A	N/A	N/A
45929 Bedroom 111	N/A	N/A	N/A	N/A
45932 Bedroom 114	N/A	N/A	N/A	N/A
45933 Bedroom 115	N/A	N/A	N/A	N/A
45934 Bedroom 116	N/A	N/A	N/A	N/A
45935 Bedroom 117	N/A	N/A	N/A	N/A
45936 Bedroom 118	N/A	N/A	N/A	N/A
45938 Bedroom 120	N/A	N/A	N/A	N/A
45943 Bedroom 125	N/A	N/A	N/A	N/A
45945 Bedroom 127	N/A	N/A	N/A	N/A
45946 Bedroom 128	N/A	N/A	N/A	N/A
45948 Bedroom 130	N/A	N/A	N/A	N/A
45951 Bedroom 133	N/A	N/A	N/A	N/A
45952 Bedroom 134	N/A	N/A	N/A	N/A
45957 Bedroom 205	N/A	N/A	N/A	N/A
45960 Bedroom 208	N/A	N/A	N/A	N/A
45961 Bedroom 209	N/A	N/A	N/A	N/A
45962 Bedroom 210	N/A	N/A	N/A	N/A
45966 Bedroom 214	N/A	N/A	N/A	N/A
45967 Bedroom 215	N/A	N/A	N/A	N/A
45969 Bedroom 217	N/A	N/A	N/A	N/A

Crystal Air

NAME	SERIAL NUMBER	MAKE	MODEL	MANUFACTURER
45971 Bedroom 219	N/A	N/A	N/A	N/A
45973 Bedroom 221	N/A	N/A	N/A	N/A
45976 Bedroom 224	N/A	N/A	N/A	N/A
45979 Bedroom 227	N/A	N/A	N/A	N/A
45980 Bedroom 228	N/A	N/A	N/A	N/A
45982 Bedroom 230	N/A	N/A	N/A	N/A
45985 Bedroom 233	N/A	N/A	N/A	N/A
45986 Bedroom 234	N/A	N/A	N/A	N/A
45988 Bedroom 302	N/A	N/A	N/A	N/A
45989 Bedroom 303	N/A	N/A	N/A	N/A
45990 Bedroom 304	N/A	N/A	N/A	N/A
45992 Bedroom 306	N/A	N/A	N/A	N/A
45994 Bedroom 308	N/A	N/A	N/A	N/A
45995 Bedroom 309	N/A	N/A	N/A	N/A
45996 Bedroom 310	N/A	N/A	N/A	N/A
46001 Bedroom 315	N/A	N/A	N/A	N/A
46003 Bedroom 317	N/A	N/A	N/A	N/A
46005 Bedroom 319	N/A	N/A	N/A	N/A
46008 Bedroom 322	N/A	N/A	N/A	N/A
46009 Bedroom 323	N/A	N/A	N/A	N/A
46010 Bedroom 324	N/A	N/A	N/A	N/A
46011 Bedroom 325	N/A	N/A	N/A	N/A
46014 Bedroom 328	N/A	N/A	N/A	N/A
46021 Bedroom 401	N/A	N/A	N/A	N/A
46023 Bedroom 403	N/A	N/A	N/A	N/A
46026 Bedroom 406	N/A	N/A	N/A	N/A
46027 Bedroom 407	N/A	N/A	N/A	N/A
46034 Bedroom 414	N/A	N/A	N/A	N/A
46035 Bedroom 415	N/A	N/A	N/A	N/A
46039 Bedroom 419	N/A	N/A	N/A	N/A
46044 Bedroom 424	N/A	N/A	N/A	N/A
46045 Bedroom 425	N/A	N/A	N/A	N/A
46046 Bedroom 426	N/A	N/A	N/A	N/A

NAME	SERIAL NUMBER	MAKE	MODEL	MANUFACTURER
46049 Bedroom 429	N/A	N/A	N/A	N/A
46051 Bedroom 431	N/A	N/A	N/A	N/A
46053 Bedroom 433	N/A	N/A	N/A	N/A
46757 Bedroom 502	N/A	N/A	N/A	N/A
46758 Bedroom 503	N/A	N/A	N/A	N/A
46759 Bedroom 504	N/A	N/A	N/A	N/A
46761 Bedroom 506	N/A	N/A	N/A	N/A
46762 Bedroom 507	N/A	N/A	N/A	N/A
46763 Bedroom 508	N/A	N/A	N/A	N/A
46764 Bedroom 509	N/A	N/A	N/A	N/A
46766 Bedroom 511	N/A	N/A	N/A	N/A
46768 Bedroom 513	N/A	N/A	N/A	N/A
46769 Bedroom 514	N/A	N/A	N/A	N/A
46771 Bedroom 516	N/A	N/A	N/A	N/A
46774 Bedroom 519	N/A	N/A	N/A	N/A
46776 Bedroom 521	N/A	N/A	N/A	N/A
46777 Bedroom 522	N/A	N/A	N/A	N/A
46780 Bedroom 525	N/A	N/A	N/A	N/A
46781 Bedroom 526	N/A	N/A	N/A	N/A
46782 Bedroom 527	N/A	N/A	N/A	N/A
46784 Bedroom 529	N/A	N/A	N/A	N/A
46787 Bedroom 601	N/A	N/A	N/A	N/A
46790 Bedroom 604	N/A	N/A	N/A	N/A
46792 Bedroom 606	N/A	N/A	N/A	N/A
46794 Bedroom 608	N/A	N/A	N/A	N/A
46795 Bedroom 609	N/A	N/A	N/A	N/A
46796 Bedroom 610	N/A	N/A	N/A	N/A
46797 Bedroom 611	N/A	N/A	N/A	N/A
46799 Bedroom 613	N/A	N/A	N/A	N/A
46802 Bedroom 616	N/A	N/A	N/A	N/A
46804 Bedroom 618	N/A	N/A	N/A	N/A
46806 Bedroom 620	N/A	N/A	N/A	N/A
46809 Bedroom 623	N/A	N/A	N/A	N/A

NAME	SERIAL NUMBER	MAKE	MODEL	MANUFACTURER
46810 Bedroom 624	N/A	N/A	N/A	N/A
46811 Bedroom 625	N/A	N/A	N/A	N/A
46812 Bedroom 626	N/A	N/A	N/A	N/A
46813 Bedroom 627	N/A	N/A	N/A	N/A
46814 Bedroom 628	N/A	N/A	N/A	N/A
46815 Bedroom 629	N/A	N/A	N/A	N/A
46816 Bedroom 630	N/A	N/A	N/A	N/A
46817 Bedroom 631	N/A	N/A	N/A	N/A

WORK DETAILS

ASSET TASKS

ASSET TASKS			
NAME	DESCRIPTION	QTY	
Tasks for asset 46027 Bedroom 407 - N/A			
Crystal Air Extract Fan	PPM Visit on Extract Fan		

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 45986 Bedroom 234 - N/A		
Crystal Air Extract Fan	PPM Visit on Extract Fan	

Notes: No Extraction flexi pipe is to short

Extract Fans.pdf

Tasks for asset 45992 Bedroom 306 - N/A		
Crystal Air Extract Fan	PPM Visit on Extract Fan	

Notes: Running

Extract Fans.pdf

Tasks for asset 45989 Bedroom 303 - N/A		
Crystal Air Extract Fan	PPM Visit on Extract Fan	

Extract Fans.pdf

Tasks for asset 46813 Bedroom 627 - N/A		
Crystal Air Extract Fan	PPM Visit on Extract Fan	

Notes: Running

Extract Fans.pdf

Tasks for asset 46787 Bedroom 601 - N/A		
Crystal Air Extract Fan	PPM Visit on Extract Fan	

Crystal Air

Notes: Running

Extract Fans.pdf

Tasks for asset 46804 Bedroom 618 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46797 Bedroom 611 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction damper closed

Extract Fans.pdf

Tasks for asset 46005 Bedroom 319 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45973 Bedroom 221 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction damper closed

Extract Fans.pdf

Tasks for asset 46763 Bedroom 508 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 45957 Bedroom 205 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46790 Bedroom 604 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45966 Bedroom 214 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Crystal Air

Notes: Running

Extract Fans.pdf

Tasks for asset 45985 Bedroom 233 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction flexi pipe to short

Extract Fans.pdf

Tasks for asset 46817 Bedroom 631 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Extract Fans.pdf

Tasks for asset 46762 Bedroom 507 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 46764 Bedroom 509 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 45943 Bedroom 125 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 45945 Bedroom 127 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46003 Bedroom 317 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45951 Bedroom 133 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 46011 Bedroom 325 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Extract Fans.pdf

Tasks for asset 46795 Bedroom 609 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46809 Bedroom 623 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46001 Bedroom 315 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46806 Bedroom 620 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46045 Bedroom 425 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45934 Bedroom 116 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46023 Bedroom 403 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 45927 Bedroom 109 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Extract Fans.pdf

Tasks for asset 46794 Bedroom 608 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46051 Bedroom 431 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46810 Bedroom 624 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45996 Bedroom 310 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45994 Bedroom 308 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45922 Bedroom 104 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46034 Bedroom 414 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Crystal Air

Extract Fans.pdf

Tasks for asset 46046 Bedroom 426 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45924 Bedroom 106 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46784 Bedroom 529 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45920 Bedroom 102 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45948 Bedroom 130 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46761 Bedroom 506 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45929 Bedroom 111 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45960 Bedroom 208 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Crystal Air

Extract Fans.pdf

Tasks for asset 46768 Bedroom 513 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46009 Bedroom 323 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Extract Fans.pdf

Tasks for asset 46053 Bedroom 433 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45946 Bedroom 128 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Extract Fans.pdf

Tasks for asset 46759 Bedroom 504 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45962 Bedroom 210 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46044 Bedroom 424 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46769 Bedroom 514 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Crystal Air

Extract Fans.pdf

Tasks for asset 46758 Bedroom 503 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45976 Bedroom 224 - N/A

Crystal Air Extract FanPPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46774 Bedroom 519 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Extract Fans.pdf

Tasks for asset 45971 Bedroom 219 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45967 Bedroom 215 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46799 Bedroom 613 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46771 Bedroom 516 - N/A

Crystal Air Extract FanPPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45979 Bedroom 227 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 45969 Bedroom 217 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46021 Bedroom 401 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45982 Bedroom 230 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46802 Bedroom 616 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45933 Bedroom 115 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46815 Bedroom 629 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45928 Bedroom 110 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Extract Fans.pdf

Tasks for asset 45990 Bedroom 304 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 46049 Bedroom 429 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46814 Bedroom 628 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46792 Bedroom 606 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45936 Bedroom 118 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46816 Bedroom 630 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46812 Bedroom 626 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45995 Bedroom 309 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction damper closed

Extract Fans.pdf

Tasks for asset 46010 Bedroom 324 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Crystal Air

Extract Fans.pdf

Tasks for asset 45938 Bedroom 120 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46776 Bedroom 521 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46039 Bedroom 419 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 45980 Bedroom 228 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46781 Bedroom 526 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46757 Bedroom 502 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46782 Bedroom 527 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45952 Bedroom 134 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 45988 Bedroom 302 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46796 Bedroom 610 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 45961 Bedroom 209 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46014 Bedroom 328 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46766 Bedroom 511 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction dampers closed

Extract Fans.pdf

Tasks for asset 45925 Bedroom 107 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No extraction

Extract Fans.pdf

Tasks for asset 46008 Bedroom 322 - N/A

Crystal Air Extract FanPPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Tasks for asset 46026 Bedroom 406 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Crystal Air

Extract Fans.pdf

Tasks for asset 45932 Bedroom 114 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 45935 Bedroom 117 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 46035 Bedroom 415 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 46811 Bedroom 625 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 46777 Bedroom 522 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: No Extraction

Extract Fans.pdf

Tasks for asset 46780 Bedroom 525 - N/A

Crystal Air Extract Fan PPM Visit on Extract Fan

Notes: Running

Extract Fans.pdf

Crystal Air