

HOLIDAY INN EXPRESS O'CONNELL ST

M1421 Holiday Inn Express
O'Connell Street
Dublin 1
Ireland



Crystal Air
Unit 3
Butterstream, Business Park, Kildare
Ireland
Tel: 0035345893228
E-mail: service@crystalair.ie

J22804

JOB DETAILS

Job is Completed

SCHEDULED	JOB LEAD	CREW
12/03/2025, 08:00	Brendan Long	

CLOSED BY OFFICE: Yes	CLOSED BY: Jessica	OFFICE JOB DESCRIPTION: Q2500304 - Holiday Inn Express - Recommendation to replace main PCB and inverter board to system 1 following j22616 where boards failed when unit was tested on site
JOB TYPE: Service Repair	MATERIALS USED: PO75609	MATERIALS TO BE QUOTED:
APPRENTICE REQUIRED/PRESENT: No	CUSTOMER PURCHASE ORDER NUMBER: PO Number For Invoicing	INVOICING CODE: Service (SR)

JOB DESCRIPTION

Q2500304 - Holiday Inn Express - Recommendation to replace main PCB and inverter board to system 1 following J22616 where boards failed when unit was tested on site:
Changed out PCB and inverter PCB and re charged system 16.7kg Full Charge to test operation. Tested unit operation and left system operating without fault.

WORK DETAILS

NAME	DESCRIPTION	QTY
H&S Short Risk Assessment & Method Statement Sign Off	Risk Assessment to be completed in advance of any works carried out	
Service Call	Task to be added to call out to allow Engineers Submit Pictures	
All Removable Panels Securely Fastned Prior to Leaving Site on all HVAC Assets	Task is assigned for Engineer to Double Check that all removeable Panels are securely fixed.	