PORTABLE FIRE FIGHTING EQUIPMENT TEST REPORT									
	ENGINEER		MICHEAL HALPENNY			′		SITE NAME: THE HOLIDAY INN	
M	ASTERFIRE DATE PAS		0	5/07/202	23	1	ı	ADDRESS :O CONNELL STREET UPPER DUBLIN  LOCATION:	
L.V.	LIFE SAFETY SYSTEMS FAIL							LOCATION:	
	REPLACE							ACCESS: Joe 085-1148122 /maintenance@hiexdublincc.com	
	ALI	LISTED EQUIP	VIENT	SERVIC	ED IN	СОМРІ	IANCE	WITH I.S.291:2015	
EXTINGUISHER NUMBER:	EXTINGUISHER LOCATION:	EXTINGUISHER TYPE:	SERVICED	YEAR OF MANUFACTURE	<b>WEIGHT (KG)</b>	PRESSURE RELEASE DEVICE	YEAR OF T/D/R	COMMENTS:	
1	6TH FLOOR AT LIFTS	2KG CO2	٧	2016	4.9	٧			
2	6TH FLOOR AT LIFTS	6L FOAM	٧	2016	9.3	٧			
3	O/S ROOM 628	2KG CO2	٧	2016	4.9	٧			
4	O/S ROOM 628	6L FOAM	٧	2016	9.3	٧			
5	O/S ROOM 625	2KG CO2	٧	2016	4.9	٧			
6	O/S ROOM 625	6L FOAM	٧	2016	9.3	٧			
7	O/S ROOM 619	2KG CO2	٧	2016	4.9	٧			
8	O/S ROOM 619	6L FOAM	٧	2016	9.3	٧			
9	O/S ROOM 614	2KG CO2	V	2016	4.9	٧			
10	O/S ROOM 614	6L FOAM	V	2016	9.3	٧			
11	5TH FLOOR O/S ROOM 514	2KG CO2	V	2016	4.9	V			
12	5TH FLOOR O/S ROOM 514	6L FOAM	V	2016	9.3	V			
13	O/S ROOM 521	2KG CO2	V	2016	4.9	V			
14	O/S ROOM 521	6L FOAM	V	2016	9.3	V			
15	O/S ROOM 525	2KG CO2	V	2016	4.9	V			
16	O/S ROOM 525	6L FOAM	V	2018	9.3	V			
17	•		V	2016		V			
	O/S ROOM 528	2KG CO2	V		4.9	1			
18	O/S ROOM 528	6L FOAM	1	2016	9.3	V			
19	AT LIFTS	2KG CO2	V	2016	4.9	V			
20	AT LIFTS	6L FOAM	V	2016	9.3	V			
21	4TH FLOOR AT LIFTS	2KG CO2	V	2016	4.9	V			
22	4TH FLOOR AT LIFTS	6L FOAM	V	2016	9.3	V			
23	O/S ROOM 430	2KG CO2	V	2016	4.9	V			
24	O/S ROOM 430	6L FOAM	V	2016	9.3	V			
25	O/S ROOM 425	2KG CO2	V	2016	4.9	V			
26	O/S ROOM 425	6L FOAM	٧	2016	9.3	V			
27	O/S ROOM 409	2KG CO2	٧	2016	4.9	V			
28	O/S ROOM 409	6L FOAM	V	2016	9.3	V			
29	O/S ROOM 414	2KG CO2	٧	2016	4.9	V			
30	O/S ROOM 414	6L FOAM	٧	2016	9.3	V			
31	3RD FLOOR O/S ROOM 314	2KG CO2	٧	2016	4.9	V			
32	3RD FLOOR O/S ROOM 314	6L FOAM	V	2016	9.3	V			
33	OS ROOM 309	2KG CO2	٧	2016	4.9	V			
34	O/S ROOM 309	6L FOAM	٧	2016	9.3	٧			
35	O/S ROOM 325	2KG CO2	٧	2016	4.9	٧			
36	O/S ROOM 325	6L FOAM	٧	2016	9.3	V			
37	O/S ROOM 329	2KG CO2	٧	2016	4.9	٧			
38	O/S ROOM 329	6L FOAM	٧	2016	9.3	٧			
39	AT LIFTS	2KG CO2	٧	2019	4.9	٧			
40	AT LIFTS	6L FOAM	٧	2016	9.3	٧			
41	2ND FLOOR AT LIFTS	2KG CO2	٧	2016	4.9	٧			
42	2ND FLOOR AT LIFTS	6L FOAM	٧	2016	9.3	٧			
43	O/S ROOM 230	2KG CO2	٧	2016	4.9	٧			
44	O/S ROOM 230	6L FOAM	٧	2016	9.3	٧			
45	O/S ROOM 209	2KG CO2	٧	2016	4.9	٧			
46	O/S ROOM209	6L FOAM	٧	2016	9.3	V			
47	O/S ROOM 212	2KG CO2	٧	2016	4.9	V			
48	O/S ROOM 212	6L FOAM	٧	2016	9.3	٧			
49	O/S ROOM 214	2KG CO2	٧	2016	4.9	٧			
50	O/S ROOM 214	6L FOAM	V	2016	9.3	V			
51	1ST FLOOR O/S ROOM 114	2KG CO2	v	2016	4.9	V			
		1	لــَــا				<u> </u>	<u> </u>	

EXTINGUISHER NUMBER:	EXTINGUISHER LOCATION:	EXTING UISHER TYPE:	SERVICED	YEAR OF MANUFACTURE	WEIGHT (KG)	PRESSURE RELEASE DEVICE	YEAR OF T/D/R	COMMENTS:
52	1ST FLOOR O/S ROOM 114	6L FOAM	<	2016	9.3	V		
53	O/S ROOM 109	2KG CO2	٧	2016	4.9	V		
54	O/S ROOM 109	6L FOAM	٧	2016	9.3	V		
55	O/S ROOM 125	2KG CO2	<	2016	4.9	٧		
56	O/S ROOM 125	6L FOAM	٧	2016	9.3	٧		
57	O/S ROOM 130	2KG CO2	V	2016	4.9	V		
58	O/S ROOM 130	6L FOAM	V	2015	9	٧		
59	AT LIFTS	2KG CO2	V	2016	4.9	V		
60	AT LIFTS	6L FOAM	٧	2016	9.3	٧		
61	GROUND FLOOR AT LIFTS	2KG CO2	V	2016	4.9	V		
62	GROUND FLOOR AT LIFTS	6L FOAM	V	2016	9.3	V		
63	AT RECEPTION	2KG CO2	٧	2016	4.9	٧		
64	AT RECEPTION	6L FOAM	٧	2016	9.3	٧		
65	O/S TOILETS	2KG CO2	٧	2016	4.9	٧		
66	O/S TOILETS	6L FOAM	V	2016	9.3	V		
67	KITCHEN	2KG CO2	V	2016	4.9	٧		
68	KITCHEN	6L FOAM	V	2019	9.3	٧		
69	KITCHEN	6L WET CHEM	V	2019	10.8	٧		
70	KITCHEN	F/BLANKET	V	-	-	-		
71	CORRIDOR BEHIND RECEPTION	2KG CO2	V	2016	4.9	٧		
72	CORRIDOR BEHIND RECEPTION	6L FOAM	٧	2016	9.3	٧		
73	BASEMENT O/S LIFT	2KG CO2	٧	2016	4.9	V		
74	BASEMENT O/S LIFT	6L FOAM	٧	2016	9.3	V		
75	EXIT AT MEETING ROOMS	2KG CO2	٧	2016	4.9	٧		
76	EXIT AT MEETING ROOMS	6L FOAM	٧	2016	9.3	٧		
77	O/S STAFF CANTEEN	2KG CO2	V	2016	4.9	V		
78	O/S STAFF CANTEEN	6L FOAM	V	2016	9.3	V		
79	BASEMENT ENTRANCE	2KG CO2	٧	2016	4.9	V		
80	BASEMENT ENTRANCE	6L FOAM	٧	2016	9.3	V		
81	BASEMENT STORE ROOM	2KG CO2	٧	2016	4.9	V		
82	BASEMENT STORE ROOM	6L FOAM	V	2016	9.3	V		
83	BASEMENT STORE ROOM	2KG CO2	V	2016	4.9	V		
84	BASEMENT STORE ROOM	6L FOAM	٧	2016	9.3	V		
85	BASEMENT PLANT ROOM	2KG CO2	٧	2016	4.9	V		
86	BASEMENT PLANT ROOM	6KG ABC	٧	2016	9	V		
87	EXIT AT BACK OF RESTAURANT	2KG CO2	٧	2019	4.9	V		
88	EXIT AT BACK OF RESTAURANT	6L FOAM	٧	2019	9.3	V		
89	OFFICE BEHIND RESTAURANT	2KG CO2	٧	2019	4.9	V		
90	OFFICE BEHIND RESTAURANT	6L FOAM	٧	2019	9.3	V		
91	BASEMENT CARPARK	9KG ABC	٧	2019	14	V		
92	BASEMENT CARPARK	9KG ABC	٧	2019	14	V		
93	BASEMENT FOOD STORE	2KG CO2	٧	2019	4.9	V		
94	BASEMENT FOOD STORE	6L FOAM	٧	2019	9.3	V		
95	BASEMENT PLANT ROOM	5KG CO2	V	2019	11.9	V		