

Summary of Defective Items

Customer: FINDLATER HOUSE LTD

FINDLATER HOUSE 28-32 O CONNELL STREET

DUBLIN 1 J75920

End Date: 11/01/2024

Site:

Job No:

Aviva No.	Serial No.	Description	Status	A Defects	B Defects	Observation
L001	42403245	Electric Passenger Lift By Kone No. 42403245	B Defect	No A Defect Noted	The lift car communication system is inoperative with the power off, repair by 11-02-2024	No C Defect Noted
L009	OP01 0091	Electric Hydraulic Goods/Passenger Lift By Wessex No. OP01 0091	Observations	No A Defect Noted	No B Defect Noted	There is no CE marking observed, this is a legislative requirement, it should be clearly displayed and of the correct format.
L005	42403246	Electric Passenger Lift By Kone No. 42403246	B Defect	No A Defect Noted	The lift car communication system is inoperative with the power off, repair by 11-02-2024	No C Defect Noted

Name Of Person Making This Report: DECLAN LEVINS

Signature:

Declan Levins