



***Bringing Clean Water to Your Environment™***

*CRO No: 690661*

**Artane, Dublin 5, DO5 RT28**

**Telephone: 086-8635861 Email: gemwaterirl@gmail.com**

**VAT No: 3748364QH**

## Cleaning & Disinfection Certificate

<b>Job Ref:</b>	GEMW
<b>Job Details:</b>	Clean & Disinfection
<b>Client Name:</b>	Quinn & Downes
<b>Site Name:</b>	Holiday Inn
<b>Site address:</b>	O'Connell Street, Dublin

<b>Clean / Disinfect</b>	Clean & Disinfection
<b>Water System</b>	C&D of 1 x 27m3 CWST (split 15m3/12m3)
<b>Guidance / Standard</b>	HPSC standard
<b>Chemical</b>	Sanosil
<b>Level PPM (50-75)</b>	50
<b>Date</b>	28 <sup>th</sup> September 2023
<b>Due Next</b>	September 2024



**Bringing Clean Water to Your Environment™**

CRO No: 690661

Artane, Dublin 5, DO5 RT28

Telephone: 086-8635861 Email: gemwaterirl@gmail.com


VAT No: 3748364QH

### **Tank: 27m3 CWST (Split – Side A: 15m3)**


Tank Lid Condition	Good	Corrosion Presence	None
Tank Vent	Yes	Scale Presence	None
Over Flow	Yes	Biofilm Presence	None
Over flow Inset Screen	Yes	Tank Lid Support	Yes
Cross Flow	Yes	Leaks	None

### **Photographs**

#### **Before**



#### **After**





**Bringing Clean Water to Your Environment™**

CRO No: 690661

Artane, Dublin 5, DO5 RT28

Telephone: 086-8635861 Email: gemwaterirl@gmail.com

VAT No: 3748364QH

### **Tank: 27m3 CWST (Split – Side B: 12m3)**


Tank Lid Condition	Good	Corrosion Presence	None
Tank Vent	Yes	Scale Presence	None
Over Flow	Yes	Biofilm Presence	None
Over flow Inset Screen	Yes	Tank Lid Support	Yes
Cross Flow	Yes	Leaks	None

### **Photographs**

**Before**



**After**



### **Comments and Recommendations**

This tank has been cleaned and disinfected in accordance with the HPSC standard, National Guidelines for the control of Legionellosis, L8 Standards and Irish Safety, Health at Work regulations.

This system should be cleaned and disinfected annually as per recommended guidelines.

**Signature GEM WATER**

*Stephen Noble*