

ROUTINE MAINTENANCE SERVICE

SULZER

SULZER PUMPS WASTEWATER IRELAND
RIVERVIEW BUSINESS PARK
NEW NANGOR ROAD, DUBLIN 12
TEL 01 4608888 FAX 01 4608889

ORDER NO.**963352**

RMS Number 1498 08 18 Building Code _____

Client QIUNNDOWNES

Service Date 15/02/2024 Call out by CLIENT / CONTACT

Site address HOLIDAY INN EXPRESS
28-32 OCONNELL STREET UPPER , DUBLIN

Contact MAURA MADIGAN

Tel 01 4242424 E-Mail _____

Issue Invoice to _____

System Details

Routine ☐ Emergency ☐ Warranty ☐ RMS ☐ X

Pump Qty Sump Depth Power Medium

Level control Control panel Priority

Pump Type

Serial Number Pump No.1 Hrs Run Serial Number Pump No.2 Hrs Run

Application Description

Service Report Details

Pump No.1
PUMP OPERATING CORRECTLY .

Stator Resis Ω	<input type="text" value="550"/>	DI Resis Ω	<input type="text" value="N/A"/>	Cable X or OK	<input type="text" value="OK"/>	Lifting Chain	<input type="text" value="Y"/>	Certified Y or N	<input type="text" value="Y"/>
----------------	----------------------------------	------------	----------------------------------	---------------	---------------------------------	---------------	--------------------------------	------------------	--------------------------------

Pump No.2
PUMP OPERATING CORRECTLY .

Stator Resis Ω	<input type="text" value="550"/>	DI Resis Ω	<input type="text" value="N/A"/>	Cable X or OK	<input type="text" value="OK"/>	Lifting Chain	<input type="text" value="Y"/>	Certified Y or N	<input type="text" value="Y"/>
----------------	----------------------------------	------------	----------------------------------	---------------	---------------------------------	---------------	--------------------------------	------------------	--------------------------------

Control Panel

Sump condition

Level Control

Valves

Fault Analysis Equipment OK Requires Attention

Estimated Cost Details

Part No	Description	Qty	Nett Price Subtotal
	RMS Service		

Service Engineer IGOR KITTEL/ PJ QUINN On Time _____ Off Time _____

Clients Signature _____ Date 15/02/2024.

SULZER CONFIDENTIAL