

Customer: **Holiday Inn Express**

Site: **Holiday Inn Express**

Quote Ref: **Q10745**

FAO: **David Hurley**

PPM Date: **Feb 25**

PPM Visit: **1 of 2**

Date: **10/03/2025**

Plant Covered: **PPM Sewage**

Repair Report:

Following our recent visit, please see below quotation on repairs we recommend are carried out.

Repair No	Plant Asset	Repair/Materials	Cost
1.	Sewage Maintenance	<p>Following on from recent maintenance, it was found that the internal rails are corroded on the internal Foul pump station at the water Tank.</p> <p>This is restricting the removal of both pumps. To remedy this, we propose to remove and replace both rails in the tank.</p> <p>A Tanker is required for cleaning on both Tanks prior to any work carried out.</p> <p>A full analysis will be carried out on one of the pumps which is tripping out and a proposal will be sent to you</p> <p>The outside Tank in the carpark has a split hose which will be removed and replaced with new.</p>	<p>Total €3,271.00</p>

Material & Labour Total €3,271.00 Excluding VAT

Quinn Downes Service & Maintenance, Unit h17, Centrepont Business Park, Oak Road, Dublin 12.

Tel: (01) 424 2424 Email: service@quinndownes.com www.quinndownes.com

Quinn Downes Service & Maintenance (Registered as Quinn Downes Ltd.), Derek Downes, Alan Carton Reg no. 555445. Vat no. 3321961FH



Exclusions

1. The Above Cost Excludes VAT
2. Quote Valid for 30 Days
3. Excludes out of hours works.

Quinn Downes Service & Maintenance, Unit h17, Centrepont Business Park, Oak Road, Dublin 12.

Tel: (01) 424 2424 Email: service@quinndownes.com www.quinndownes.com

Quinn Downes Service & Maintenance (Registered as Quinn Downes Ltd.), Derek Downes, Alan Carton Reg no. 555445. Vat no. 3321961FH

