

HOLIDAY INN

HOLIDAY INN (HOLI001)

28 -32 O CONNELL STREET
DUBLIN 1
Ireland

ASSET DETAILS

Asset Holiday Inn O Connell St
Asset Address O Connell Street, Dublin, ,

CASE DETAILS

Date 5/2/2025
Case No. 93740
Subject Electrical Private - Service Callout
Sales Order #SO79701
Details Call out due to fault

Parts & Charges

Quantity	Item	Description
1	CALLOUT1	Callout - 1St Hour
1	S4-711-V-VAD-LPR	S4 Dual Optical Heat Sensor Voice Sounder Standard

TASKS

TASK NO. 5829801

Service Date 5/2/2025
Task Type Site Visit
Technician Mick Martin
Actions Taken Call out to investigate fault on panel. L4-62 smoke detector in store room beside bedroom 628 in fault. Replaced device and allocated loop. System reset and left in healthy condition.

SIGN OFF

Customer Name David
Customer Signature

