



Legionella Sampling

Reference
No.

J005313

Date

7 Feb 2025

t. +353 1 8252775 www.aquachem.ie

| Aquachem DAC | Unit 9 | Dunboyne Business Park | Dunboyne | Co. Meath
Company Reg. No. 632210

Legionella Sampling

Findlater Ltd.

Holiday Inn Express Dublin City Centre - 28-32 , O'Connell Street Upper, Lower Dublin 1 , D01 T2X2

Date 5 Feb 2025
Job Reference No. J005313
Work Order No. Cont2024.08.01

Site Actions / Overall Comments

No task related remedial recommendations identified

Please see full details of the analysis below.

Engineer

Post Flush Samples

	Legionella - Volume tested (cfu/ml)	Other Legionella Species (cfu/ml)	Legionella pneumophila SG 1 (cfu/ml)	Legionella pneumophila SG 2-14 (cfu/ml)
Sink tap RHS Ground floor Public toilet Gents	---	Not Detected	---	---
Shower Room 224 Bathroom	---	Not Detected	---	---
Shower Room 407 Bathroom	---	Not Detected	---	---
Sink tap Room 524 Bathroom	---	Not Detected	---	---
Sink tap Room 525 Bathroom	---	Not Detected	---	---

Shane Neylon
 Aquachem DAC
 Unit 9 Dunboyne Business Park
 Dunboyne
 Co Meath

TEST REPORT

Date Samples Received:	06/02/2025	Date of Issue:	17/02/2025
Date Analysis Commenced:	06/02/2025	Test Report Ref:	2250427
Date Analysis Completed:	16/02/2025	Customer O/No:	10302

Holiday Inn express

SAMPLE DESCRIPTION	RESULT	MATRIX TYPE	METHOD	SAMPLE DATE	LAB REF
5th floor Bathroom Sink tap Hot Sample barcode 0Z-1A-5P-116		Drinking Water		05/02/2025 10:09	22502091
Legionella spp. in 1L	Not Detected		TM22		
Room 524 Bathroom Sink tap Cold Sample barcode 0Z-1A-5P-117		Drinking Water		05/02/2025 10:13	22502092
Legionella spp. in 1L	Not Detected		TM22		
Room 407 Bathroom Shower Hot Sample barcode 0Z-1A-5P-118		Drinking Water		05/02/2025 10:17	22502093
Legionella spp. in 1L	Not Detected		TM22		
Room 224 Bathroom Shower Hot Sample barcode 0Z-1A-5P-119		Drinking Water		05/02/2025 10:22	22502094
Legionella spp. in 1L	Not Detected		TM22		
Gf public toilet Gents Sink tap RHS Cold Sample barcode 0Z-1A-5P-120		Drinking Water		05/02/2025 10:26	22502095
Legionella spp. in 1L	Not Detected		TM22		
Gf Lobby bar Sink tap Cold Sample barcode 0Z-1A-5P-121		Drinking Water		05/02/2025 10:28	22502096
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	3		TM20		
TVC @ 37°C (cfu/ml)	7		TM20		

Job ID: 96468

Page 1 of 2

Bio Search (N.I.) Limited · 31 Dufferin Road · Belfast · BT3 9AA
 Telephone: 028 9035 2066 · Fax: 028 9035 2161 · Email: info@biosearch.co.uk
 VAT Registration No. GB 887 1276 83 · www.biosearch.co.uk
 Registered office: 31 Dufferin Road · Belfast BT3 9AA · Company Reg. No. NI023096



SAMPLE DESCRIPTION	RESULT	MATRIX TYPE	METHOD	SAMPLE DATE	LAB REF
Main kitchen Juice bar Tap Cold Sample barcode 0Z-1A-5P-122		Drinking Water		05/02/2025 10:32	22502097
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	0		TM20		
TVC @ 37°C (cfu/ml)	0		TM20		
Guide day coffee Sink tap Cold Sample barcode 0Z-1A-5P-123		Drinking Water		05/02/2025 10:35	22502098
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	0		TM20		
TVC @ 37°C (cfu/ml)	0		TM20		



LOIS HENRY (LEGIONELLA TEAM LEADER)

Legionella theoretical limit of detection <50 cfu/L
 Results of analysis relate only to samples as received and tested on the date(s) detailed above
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.
 This test report should not be reproduced except in full, without written approval of the laboratory.

2250-427

Job ID: 96468

Page 2 of 2

Bio Search (N.I.) Limited · 31 Dufferin Road · Belfast · BT3 9AA
 Telephone: 028 9035 2066 · Fax: 028 9035 2161 · Email: info@biosearch.co.uk
 VAT Registration No. GB 887 1276 83 · www.biosearch.co.uk
 Registered office: 31 Dufferin Road · Belfast BT3 9AA · Company Reg. No. NI023096

