

CASE NO. 69189
SALES ORDER SO63109
ORDER DATE 1/5/2024

CASE TYPE Electrical Private - Service PPM
CASE DETAILS 11 of 21

CUSTOMER DETAILS

CUSTOMER HOLI001 HOLIDAY INN (HOLI001) HOLIDAY INN
ADDRESS 28 -32 O CONNELL STREET
DUBLIN 1
Ireland

ASSET DETAILS

ASSET NAME Holiday Inn O Connell St
ADDRESS O Connell Street, Dublin, ,

PARTS & CHARGES

QUANTITY	ITEM	DESCRIPTION
1	SERVICEFA	Fire Alarm Service

TASK NO. 4436626

SERVICE DATE: 28/5/2024

TECHNICIAN: Mick Martin

TASK TYPE: Site Visit

RESULT FOLLOW UP
Job Completed

ACTIONS COMPLETED DURING SERVICE

Quarterly service of fire alarm system, all automatic and manual devices tested in good working order, 6th-5th and 4th floor bedrooms checked. Full report on nimbus. Panel batteries checked. No output test by request (client does weekly test and nothing to report). System reset and left in healthy condition.

Fire Alarm System

ASSET: Holiday Inn O Connell St

Were there any faults on the system before the service commenced	No
Entries in the logbook were checked	Yes
Event logs checked on the fire alarm panels	Yes
False alarm reports were investigated and corrective actions communicated to the client	
Fire panel alarm functions and controls were checked	Yes
Standby batteries and connections were checked	Yes
Manual call points and detectors were checked in accordance with current IS3218 standard	Yes
Sounders & VADs were tested and verified	No
ARC link to the monitoring station was tested and verified	N/A
Client has been notified of links to third party equipment and the tests required	Yes
Alternations (if any) to the fire detection and alarm system since the last service has been documented	N/A
Structural and occupancy alternations (if any) to the building layout which affect the FDAS has been documented	N/A
All zones are clearly identified	Yes
A zone chart is fitted beside the fire panel	No
A model D2 fire detection and alarm system certificate is in place and has been updated	Yes
Logbook has been updated	Yes
A model D1 Fire detection and alarm system certificate has been issued	Yes
Fire alarm system returned to normal operating mode on departure	Yes
Recommendation were made (if yes list in body of report)	N/A

SIGN OFF

Customer: Jerome

Customer signature not entered
