

NOTES

1. NOTES ON ALL DRAWINGS APPLY WHERE APPROPRIATE.
2. THE FOLLOWING SYMBOLS DENOTE:-

- ⊕ HEAT DETECTOR
⊕-⊕ COMBINED HEAT DETECTOR, SPEECH
SOUNDER & STROBE
⊕-⊕ COMBINED HEAT & CARBON MONOXIDE
DETECTOR
⊕ SMOKE DETECTOR
⊕ SMOKE DETECTOR LOCATED IN CEILING
VOID
⊕-⊕ COMBINED SMOKE DETECTOR, SPEECH
SOUNDER & STROBE
⊕-⊕ OPTICAL, HEAT MULTISENSOR, SPEECH
SOUNDER, STROBE FIRE ALARM HEAD.
⊕-⊕ MANUAL CALL POINT (NUMBER BELOW
DENOTES FIRE PANEL LOOP).
⊕-⊕ GREEN MANUAL CALL POINT FOR
OVERRIDE/ROCKING ELECTRONIC DOOR
CONTROLS.
⊕-⊕ FIREMAN WINDOW CONTROL.
⊕-⊕ SPEECH SOUNDER STROBE.
⊕-⊕ MAIN FIRE ALARM PANEL.
⊕-⊕ MOTORIZED FIRE DAMPER.
⊕-⊕ REFUGE INTERCOM.
⊕-⊕ MAIN REFUGE INTERCOM
⊕-⊕ DOOR HOLD OPEN DEVICES.
⊕-⊕ FLOOR MOUNTED DOOR HOLD OPEN
DEVICE.
⊕-⊕ AUTOMATIC INTERFACE TO THE FIRE
ALARM SYSTEM.

3. ALL VOID DETECTION TO HAVE REMOTE VISIBLE
INDICATORS



- LOOP 1 - BASEMENT
LOOP 2 - GROUND FLOOR
LOOP 3 - LEVEL 1
LOOP 4 - LEVEL 2
LOOP 5 - LEVEL 3
LOOP 6 - LEVEL 4
LOOP 7 - LEVEL 5
LOOP 8 - LEVEL 6 & ROOF

FIRE ALARM INTERFACE FOR
BOLLER CONTROL PANEL.

INCLUDE ALL NECESSARY OFFSETS OF
SERVICES IN CEILING VOIDS, SERVICE
DUCTS AND ALL OTHER AREAS TO ACHIEVE
CROSSOVERS AND CO-ORDINATION OF
MECHANICAL AND ELECTRICAL SERVICES.

Caldwell

ARCHITECT
ICA ARCHITECTS

JOB
FINDLATER HOUSE DUBLIN
HOLIDAY INN EXPRESS

DRAWING
ELECTRICAL SERVICES INSTALLATION

FIRE ALARM

BASEMENT

Drawing No./Revision
3682/E301

C4

SCALE/PRIORIT AT DATE DRAWN CHECKED
1:1250A1 JAN'15 DW

UNIT 6 FORTITUDE BUSINESS PARK TEL (0203)9089720 FAX (0203)9041425
NEWTONHEATH B'G BAW EMAIL: cdm@caldwellconsulting.net