



Test & Inspection Certificate

Test Number: 24/2016-330T
Test Date: 03/04/2024
Project Name & Address: Holiday Inn Express, 28-32 O'Connell Street
Upper, Dublin 1 D01 T2X2
Client: Joe Hayes, General Manager, Holiday Inn Express
Address: 28-32 O'Connell Street, Dublin 1 D01 T2X2

Type of Equipment Tested & Inspected:

Quantity	Description	Inspection Method	Result	Next Inspection Date
1	Skyway Cable System - Keeline II (C01)	Thorough Inspection	Passed	03/04/2025 (12 months)
1	Skyway Cable System - Keeline II (C02)	Thorough Inspection	Passed	03/04/2025 (12 months)
1	Safety Anchor - Keeline II (A01)	Not Found	N/A	N/A
1	Safety Anchor - Keeline II (A02)	Not Found	N/A	N/A

Recommendations/Comments:

**Quotation to follow for 10m rope and grab required for anchors on low roof.*

Tests and Inspections of the components listed above have been performed in accordance with the requirements of the "Safety, Health and Welfare at Work (General Application) Regulation 2007 Part 4: Work at Height", Skyway's Instructions and Recommendations & Standards; EN 795 & BS 7883.

Only trained and competent operatives are to use the equipment outlined in this contract. Please ensure that all operatives read the Skyway Operation Manual and comply with the instructions contained therein.

Skyway Safe Access Equipment Ltd

Kells Business Park, Kells, Co Meath, A82 Y466

(P) 046 9241771 (F) 046 9240189

Email: contactus@skyway.ie Web Site: www.skyway.ie

Wellington Executive, Rochester Building, 28 Adelaide Street, Belfast, BT2 8GD


(P) 0800 917 9932



Test & Inspection Certificate

Please note fall prevention cable systems are not certified for rope access work (abseiling) – cable systems should not be used for rope access work without consulting Skyway.

Approved Signature:


Fergus Rainey, FCMI

Date:

03/04/2024

Skyway Safe Access Equipment Ltd

Kells Business Park, Kells, Co Meath, A82 Y466

(P) 046 9241771 (F) 046 9240189

Email: contactus@skyway.ie Web Site: www.skyway.ie

Wellington Executive, Rochester Building, 28 Adelaide Street, Belfast, BT2 8GD

(P) 0800 917 9932