



# AQUACHEM

Innovators in Tailored Water Treatment



## Cleaning & Disinfection

Reference No.	J005308
---------------	---------

Date	11 Sep 2024
------	-------------

t. +353 1 8252775 [www.aquachem.ie](http://www.aquachem.ie)

| Aquachem DAC | Unit 9 | Dunboyne Business Park | Dunboyne | Co. Meath  
Company Reg. No. 632210

# Cleaning & Disinfection

Holiday Inn Express Dublin City Centre

Holiday Inn Express Dublin City Centre - 28-32 , O'Connell Street Upper, Lower Dublin 1 , D01 T2X2

**Date** 10 Sep 2024  
**Job Reference No.** J005308  
**Work Order No.** Cont2024.08.01

## Summary

No.	Summary	Action Required	
1	<b>1.5m3 CWST</b> Holiday Inn Express Dublin City Centre No Inset Screen		High
2	<b>1.5m3 CWST</b> Holiday Inn Express Dublin City Centre Not fitted correctly		High
3	<b>1.5m3 CWST</b> Holiday Inn Express Dublin City Centre Lid & Vent		High

Please see full details of the inspection below.

## Job Details

Clean / Disinfect	Clean / Disinfect
Water System	Domestic
Guidance / Standard HPSC standard	HPSC standard
Chemical	Huwa san
Level PPM (50-75)	50
Due Next	11 Sep 2025

## 1.5m3 CWST

Holiday Inn Express Dublin City Centre

Cleaning	
Pre Cleaning Photo	
Post Clean Photo	

## Tank Info



Ballcock operation	Yes
Corrosion Presence	No
Tank Lid and Vent	No
Scale Presence	None
Over Flow pipe fitted correctly	No
Biofilm Presence	None
Over flow Inset Screen	No
Hollow lid supports	No
Cross Flow	Yes
Leaks	No



Online disinfection

## 27m3 CWST



### Holiday Inn Express Dublin City Centre

Cleaning	
Pre Cleaning Photo	
Post Clean Photo	

## Tank Info

Ballcock operation	Yes
Corrosion Presence	No
Tank Lid and Vent	Yes
Scale Presence	None
Over Flow pipe fitted correctly	Yes
Biofilm Presence	None
Over flow Inset Screen	Yes
Hollow lid supports	No
Cross Flow	Yes
Leaks	No

**27m3 CWST**  
 +353 1 8252775 [www.aquachem.ie](http://www.aquachem.ie)  
 Holiday Inn Express Dublin City Centre


Cleaning	
Pre Cleaning Photo	
Post Clean Photo	

### Tank Info

Ballcock operation	Yes
Corrosion Presence	No
Tank Lid and Vent	Yes
Scale Presence	None
Over Flow pipe fitted correctly	Yes
Biofilm Presence	None
Over flow Inset Screen	Yes
Hollow lid supports	No
Cross Flow	Yes
Leaks	No

**Engineer**

Stephen Noble



**Customer**

## Disinfection Certificate

Site: Holiday Inn Express Dublin City Centre

The following systems have been disinfected to comply with the National Guidelines for the control of Legionellosis in Ireland: 2009 and / or BS8558: 2015 and / or L8 (4th edition) and / or HSG 274 and PD 855468: 2015

27m3 CWST , 27m3 CWST, 1.5m3 CWST

Certificate No: J005308

Date Completed: 11 Sep 2024

Next Cleaning & Disinfecting Due: 11 Sep 2025



**Shane Neylon** - Director

