

ROUTINE MAINTENANCE SERVICE

SULZER

SULZER PUMPS WASTEWATER IRELAND
RIVERVIEW BUSINESS PARK
NEW NANGOR ROAD, DUBLIN 12
TEL 01 4608888 FAX 01 4608889

ORDER NO. 1059240

RMS Number _____ Client HOLIDAY INN EXPRESS C/O QUINN DOWNES
Service Date 20/02/2025 Site Contact MAURA MADIGAN
Site address 28-32 O CONNELL STREET UPPER DUBLIN D01 T2X2
Tel 01 4242424 E-Mail maintenancereports@quinndownes.com

Issue Invoice to _____

System Details

RMS Service	<input checked="" type="checkbox"/>	Warranty	<input type="checkbox"/>	Breakdown	<input type="checkbox"/>	Remedial work	<input type="checkbox"/>
Pump Qty	<input type="text" value="2"/>	Sump Depth	<input type="text" value="2 METER"/>	Power	<input type="text" value="400"/>	Medium	<input type="text" value="FOUL"/>
Level control	<input type="text" value="FLOATS X 4"/>		Control panel	<input type="text" value="CP212"/>		Priority	<input type="text"/>
Pump Type	<input type="text"/>						
Serial Number Pump No.1	<input type="text" value="400/80"/>	Hrs Run	<input type="text" value="458.48"/>	Serial Number Pump No.2	<input type="text" value="107202"/>	Hrs Run	<input type="text" value="264.15"/>
Application Description	<input type="text" value="SUMP LOCATED IN BASEMENT CARPARK"/>						

Service Report Details

Pump No.1	PUMP CHECKED AND TRIPPING OUT . BUILD UP OF SLUDGE IN TANK .HOSE CONNECTIONS PERISHED .IN NEED OF REPLACING .PUMP ISOLATED TO PREVENT FURTHER DAMAGE								
Stator Resis Ω	<input type="text" value="550"/>	DI Resis Ω	<input type="text" value="."/>	Cable X or OK	<input checked="" type="checkbox"/>	Lifting Chain	<input type="text" value="OK"/>	Certified Y or N	<input type="text" value="Y"/>
Pump No.2	UNABLE TO LIFT PUMPS DUE TO EXCESSIVE SLUGDE BUILDUP IN TANK. LIFTING PUMPS MAY CAUSE FURTHER DAMAGE PUMP DROPPING LEVEL IN TANK, MOTOR INSULATION OK. TANK WILL NEED TO BE CLEANED								
Stator Resis Ω	<input type="text" value="550"/>	DI Resis Ω	<input type="text" value="."/>	Cable X or OK	<input checked="" type="checkbox"/>	Lifting Chain	<input type="text" value="OK"/>	Certified Y or N	<input type="text" value="Y"/>
Control Panel	ALL TERMINALS SECURE AND LAMPS WORKING OK . MCBs AND CONTACTORS ALL FUNCTIONING CORRECTLY								
Sump condition	NEEDS TO BE CLEANED TO BE ABLE TO LIFT PUMPS SAFELY AND REDUCE THE RISK OF AIRLOCKING .								
Level Control	ALL PARAMETERS ENGAGING PROPERLY .								
Valves	ALL OK								
Comments	P1 TRIPPING OUT .FURTHER INVESTIGATING REQUIRED .								

ADDITIONAL ITEMS USED

Part No	Description	Qty	Nett Price
	RMS	1	

Service Engineer JASON SAMUEL On Time _____ Off Time _____
Clients Signature _____ Date 20/02/2025