

CASE SERVICE REPORT

CASE NO. 80076 CASE TYPE Electrical Private - Service Callout

SALES ORDER SO66582 ORDER DATE 19/7/2024

CUSTOMER DETAILS

ASSET DETAILS

CUSTOMER HOLI001 HOLIDAY INN (HOLI001) HOLIDAY INN

ADDRESS 28 -32 O CONNELL STREET

DUBLIN 1 Ireland ASSET NAME Holiday Inn O Connell St ADDRESS O Connell Street, Dublin, ,

PARTS & CHARGES

QUANTITYITEMDESCRIPTION1CALLOUT1Callout - 1St Hour1S3EP-V-VAD-HPR-RS3 EP (IP66) red Body Voice Sounder High Power red1CALLOUT2Callout - 2Nd & Subsequent Hour(S)

TASK NO. 5054885

SERVICE DATE: 19/7/2024 TECHNICIAN: Mick Martin TASK TYPE: Site Visit

RESULT FOLLOW UP

More To Do

ACTIONS COMPLETED DURING SERVICE

Call out to investigate fault on panel. Sounder/beacon at main entrance in fault, return visit with new device required as none in stock, client advised.

TASK NO. 5056295

SERVICE DATE: 22/7/2024 TECHNICIAN: Mick Martin TASK TYPE: Site Visit

RESULT FOLLOW UP

Job Completed

ACTIONS COMPLETED DURING SERVICE

Return visit to replace sounder/ beacon L2-19 at main entrance. Replaced device, reallocated loop 2. System reset and left in healthy condition.

SIGN OFF

Customer: David

Customer signature not entered