



Legionella Sampling

Reference No.	J005312
---------------	---------

Date	14 Aug 2024
------	-------------

t. +353 1 8252775 www.aquachem.ie

Legionella Sampling

Holiday Inn Express Dublin City Centre

Holiday Inn Express Dublin City Centre - 28-32 , O'Connell Street Upper, Lower Dublin 1 , D01 T2X2

Date 14 Aug 2024
Job Reference No. J005312
Work Order No. Cont2024.08.01

Site Actions / Overall Comments

No task related remedial recommendations identified

Please see full details of the analysis below.

Engineer

Customer

Post Flush Samples

	Legionella - Volume tested (cfu/ml)	Other Legionella Species (cfu/ml)	Legionella pneumophila SG 1 (cfu/ml)	Legionella pneumophila SG 2-14 (cfu/ml)
Sink, Hot 1st floor, Room 108	---	Not Detected	---	---
Shower, Hot 4th floor, Room 426	---	Not Detected	---	---
Sink, Hot tap 6th floor, Room 608	---	Not Detected	---	---
Sink, Hot tap Coffee Shop	---	Not Detected	---	---
Sink, Hot tap Staff Canteen	---	Not Detected	---	---

Shane Neylon
 Aquachem DAC
 Unit 9 Dunboyne Business Park
 Dunboyne
 Co Meath

TEST REPORT

Date Samples Received:	15/08/2024	Date of Issue:	27/08/2024
Date Analysis Commenced:	15/08/2024	Test Report Ref:	8241568
Date Analysis Completed:	25/08/2024	Customer O/No:	AWM11165

Holiday Inn Express
 Dublin City Centre

SAMPLE DESCRIPTION	RESULT	MATRIX TYPE	METHOD	SAMPLE DATE	LAB REF
Coffee Shop Sink tap Hot		Drinking Water		14/08/2024 13:15	82407295
Sample barcode 0Z-13-H7-333					
Legionella spp. in 1L	Not Detected		TM22		
Coffee shop Sink tap Cold		Drinking Water		14/08/2024 13:15	82407296
Sample barcode 0Z-13-H7-334					
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	5		TM20		
TVC @ 37°C (cfu/ml)	0		TM20		
Reception Area Bar Sink Cold		Drinking Water		14/08/2024 13:18	82407297
Sample barcode 0Z-13-H7-335					
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	4		TM20		
TVC @ 37°C (cfu/ml)	0		TM20		
Main Kitchen Food Preparation General Sink Cold		Drinking Water		14/08/2024 13:19	82407298
Sample barcode 0Z-13-H7-336					
E.coli (confirmed) (cfu/100ml)	0		TM18		
Total Coliform (cfu/100ml)	0		TM18		
TVC @ 22°C (cfu/ml)	0		TM20		
TVC @ 37°C (cfu/ml)	0		TM20		

Job ID: 81829

Page 1 of 2

Bio Search (N.I.) Limited · 31 Dufferin Road · Belfast · BT3 9AA
 Telephone: 028 9035 2066 · Fax: 028 9035 2161 · Email: info@biosearch.co.uk
 VAT Registration No. GB 887 1276 83 · www.biosearch.co.uk
 Registered office: 31 Dufferin Road · Belfast BT3 9AA · Company Reg. No. NI023096



SAMPLE DESCRIPTION	RESULT	MATRIX TYPE	METHOD	SAMPLE DATE	LAB REF
Room 608 Sink Hot Sample barcode 0Z-13-H7-337		Drinking Water		14/08/2024 13:23	82407299
Legionella spp. in 1L	Not Detected		TM22		
Room 426 Shower Hot Sample barcode 0Z-13-H7-338		Drinking Water		14/08/2024 13:27	82407300
Legionella spp. in 1L	Not Detected		TM22		
Room 108 Sink tap Cold Sample barcode 0Z-13-H7-339		Drinking Water		14/08/2024 13:31	82407301
Legionella spp. in 1L	Not Detected		TM22		
Staff Canteen Sink tap Hot Sample barcode 0Z-13-H7-340		Drinking Water		14/08/2024 13:35	82407302
Legionella spp. in 1L	Not Detected		TM22		

N. Gordon

NIAMH GORDON - Lab Manager (Waters)

Legionella theoretical limit of detection <50 cfu/L

Results of analysis relate only to samples as received and tested on the date(s) detailed above

Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

8241-568

Job ID: 81829

Page 2 of 2

Bio Search (N.I.) Limited · 31 Dufferin Road · Belfast · BT3 9AA
 Telephone: 028 9035 2066 · Fax: 028 9035 2161 · Email: info@biosearch.co.uk
 VAT Registration No. GB 887 1276 83 · www.biosearch.co.uk
 Registered office: 31 Dufferin Road · Belfast BT3 9AA · Company Reg. No. NI023096

