



Customer Holiday Inn O'Connell Street
Address 28-32 O'Connell Street
Dublin
Co. Dublin
Dublin 1

Ref Job 21539 Date 20/02/2023
Job Type Deep Clean & Sterilisation
Model: Serial:
Time In 14:20 Time Out 15:00
Engineer Darryl McConville

Contact

Telephone 00353 852071727

ACTUAL WORK DONE

Unit deep cleaned and sterilised
Unit serviced

Description	Answer	Comments
1. Check LEDs	LEDs Operating correctly	
2. Check IP56 Socket, trip switch & fuses (if necessary)	All OK	
3. Check PLC Program	Program version V5.5	
Check PLC Time and dates:		
Start time 07:00		
Finish time 02:30		
Operational Times		
Roller time 300		
Roller time off 300		
Number of times unit has been switched off		
4. Check PLC Override Functions	Override functions working correctly	
5. Check Auger Motor and screw	Not applicable to this unit	
6. Check FOG motor	OK	
7. Check CIP function & overflow hose	Cleaned limescale build up blocking holes on CIP bar	
8. Check Solenoid valve	OK	
9. Check air vent on service pump	OK	
10. Check air sensor valve & sensor tubing	OK	
11. Check Pressure switch	OK	
12. Check hopper	Not applicable to this model	
13. Check FOG cartridge	OK	
14. Check wiper blade	OK	
15. Check for sediment at bottom of tank	Removed light sediment from tank	
16. Check water level in tank	Static water level OK	
17. Note any excessive tide level in tank	Tide level ok	
18. Check inlet drainage, restrictions, support and invert levels	OK	
19. Check outlet drainage, restrictions, support and invert levels	OK	
20. Service access	OK	
21. Check for leaks	OK	

PARTS USED

Qty	Part Number	Description	Quantity
1.00	DEEPCLEAN	Deep Clean and Sterilisation of GreaseShield Unit	1.00

SIGNATURES

Product Certifications



Industry Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
Estate, Hammond Avenue, South Reddish,
Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555





Customer Holiday Inn O'Connell Street
Address 28-32 O'Connell Street
Dublin
Co. Dublin
Dublin 1

Ref Job 21539 Date 20/02/2023

Job Type Deep Clean & Sterilisation

Model: Serial:

Time In 14:20 Time Out 15:00

Engineer Darryl McConville

Contact

Telephone 00353 852071727

This service has been carried out in accordance with the manufacturer's recommendations.
For and on behalf of Environmental Products and Services Ltd.

Darryl mcconville

vianna

Product Certifications



Industry Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
Estate, Hammond Avenue, South Reddish,
Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555

