



112 Grange Way, Baldoyle Industrial Estate,
D13 HD91
T. 01 831 4882 E. info@aceengineering.ie
www.aceengineering.ie

**SERVICE &
INSTALLATION
No. 30488**

DATE: 11-23-2023

Client:	Holiday Inn	Call Logged By:	
Site Address:	Oconnell street	Type of Door:	
	Dublin1 Dublin D01 T2X2	Location:	
Site Contact:		Van Number:	3
Tel:		Customer Email:	

DESCRIPTION OF FAULT/ISSUE

call out to attached site ppm docket to be done on auto doors,

look at cafe next door issue with their swing door

ask for ann at the front desk

ENGINEERS NOTES

Call out service on auto doors

Serviced the two auto doors on premises

Tightened up all fixings on carriage wheels

Checked belt tightness

No issues to report all in good working order

Also call out on cafe next door to hotel

Issue with door closers doors will not stay in straight position wind able to blow doors in new door closer kit needed for both doors

Signed by ann

DATE	ARRIVAL TIME	DEPARTURE TIME	DURATION
11-23-2023	23-Nov-2023 01:30 PM	23-Nov-2023 02:29 PM	0:59:12

Part Used	Part Description	Quantity
-----------	------------------	----------

I confirm that the above work has been carried out to my complete satisfaction and the safe operation of door has been explained to me in full.

FITTER SIGNATURE:

SIGNED BY CUSTOMER:

DATE: 11-23-2023

TECH COMMENTS: