

Customer Holiday Inn O'Connell Street Ref Job 21409 Date 14/02/2023

28-32 O'Connell Street Job Type Maintenance Contract
Dublin

Co. Dublin Model: GS 1000 PF Serial: 207996

Dublin 1 Time In 10:40 Time Out 11:15

Contact Engineer Atanas Sotirov

## Telephone 00353 852071727 ACTUAL WORK DONE

Clean and check the unit

Address

Description	Answer	Comments
1. Check LEDs	LEDs Operating correctly	
Check IP56 Socket, trip switch & fuses (if neccessary)	All OK	
3. Check PLC Program	Program version V1.1	
Check PLC Time and dates:		
Start time 07:00		
Finish time 02:30		
Operational Times		
Roller time 300		
Roller time off 300		
Number of times unit has been switched off		
4. Check PLC Overide Functions	Override functions working correctly	
5. Check Auger Motor and screw	Not applicable to this unit	
6. Check FOG motor	OK	
7. Check CIP function & overflow hose	OK	
8. Check Solenoid valve	OK	
9. Check air vent on service pump	OK	
10. Check air sensor valve & sensor tubing	OK	
11. Check Pressure switch	OK	
12. Check hopper	Not applicable to this model	
13. Check FOG cartridge	OK	
14. Check wiper blade	OK	
15. Check for sediment at bottom of tank	Removed light sediment from tank	
16. Check water level in tank	Static water level OK	
17. Note any excessive tide level in tank	Tide level ok	
18. Check inlet drainage, restrictions, support and invert levels	OK	
19. Check outlet drainage, restrictions, support and invert levels	OK	
20. Service access	OK	
21. Check for leaks	OK	

## **PARTS USED**

Qtv	v	Part Number	Description	Quantity

## **SIGNATURES**

This service has been carried out in accordance with the manufacturer's recommendations. For and on behalf of Environmental Products and Services Ltd.

















Industry

Certifications







**Environmental Products and Services Ltd** 

6 Shepherd's Way, Carnbane Industrial Estate, Newry, Co. Down N. Ireland BT35 6EE **Tel:** +44 (0) 28 3083 3081 Email: Accounts@EPAS-Ltd.com Unit 6, Phoenix Court, Whitehill Industrial Estate, Hammond Avenue, South Reddish, Stockport, Manchester, UK. SK4 1PQ Tel: +44 (0) 161 477 5555





Date

Serial:

14/02/2023

207996

Customer Holiday Inn O'Connell Street Address

28-32 O'Connell Street

Dublin Co. Dublin

Telephone 00353 852071727

Contact

Dublin 1

Time In 10:40

Ref

Job Type

Model:

Time Out 11:15

Engineer Atanas Sotirov

Atanas Sotirov

**Maintenance Contract** 

GS 1000 PF

anna

**Product Certifications** 

















Industry







**Environmental Products and Services Ltd** 

6 Shepherd's Way, Carnbane Industrial Estate, Newry, Co. Down N. Ireland BT35 6EE **Tel:** +44 (0) 28 3083 3081 Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial Estate, Hammond Avenue, South Reddish, Stockport, Manchester, UK. SK4 1PQ **Tel:** +44 (0) 161 477 5555

