

HOLIDAY INN EXPRESS O'CONNELL ST

M1421 Holiday Inn Express  
O'Connell Street  
Dublin 1  
Ireland  
Contact: Joe



**Crystal Air**  
Unit 3  
Butterstream, Business Park, Kildare  
Ireland  
Tel: 0035345893228  
E-mail: service@crystalair.ie

J17977

Job is Completed

JOB DETAILS

SCHEDULED	JOB LEAD	CREW
10/04/2024, 11:53	Dylan Bingham	

<b>CLOSED BY OFFICE:</b> Yes	<b>CLOSED BY:</b> Kerryann	<b>OFFICE JOB DESCRIPTION:</b> Callout Holiday Inn Express - room 334 in error.
<b>JOB TYPE:</b> Call Out	<b>MATERIALS USED:</b>	<b>MATERIALS TO BE QUOTED:</b>
<b>APPRENTICE REQUIRED/PRESENT:</b> No	<b>CUSTOMER PURCHASE ORDER NUMBER:</b> PO Number For Invoicing	<b>INVOICING CODE:</b> Maintenance (M)

JOB DESCRIPTION

Called to site to investigate unit in room 334 not working.

When arrived on site met with a guy from maintenance who showed me up to the room and told me that when the unit is on in heating for a while there is water leaking. The room was checked into so I just ran the unit up in heating and took temperatures units temperatures were good and there was no sign of water dripping if this happens again we will need to come back to site to check for leak. There was no leak present when tested on site .

WORK DETAILS

NAME	DESCRIPTION	QTY
H&S Short Risk Assessment & Method Statement Sign Off	Risk Assessment to be completed in advance of any works carried out	
Service Call	Task to be added to call out to allow Engineers Submit Pictures	
All Removable Panels Securely Fastned Prior to Leaving Site on all HVAC Assets	Task is assigned for Engineer to Double Check that all removeable Panels are securely fixed.	