



Customer Holiday Inn O'Connell Street
Address 28-32 O'Connell Street
Dublin
Co. Dublin
Dublin 1

Ref Job 21469 Date 20/02/2023

Job Type Deep Clean & Sterilisation

Model:

Serial:

Time In 13:00 Time Out 14:15

Engineer Darryl McConville, Patrick McEvoy

Contact

Telephone 00353 852071727

ACTUAL WORK DONE

Unit deep cleaned and sterilised
Service completed

| Description | Answer | Comments |
|--|--|----------|
| 1. Check LEDs | LEDs Operating correctly | |
| 2. Check IP56 Socket, trip switch & fuses (if necessary) | All OK | |
| 3. Check PLC Program | Program version V1.1 | |
| Check PLC Time and dates: | | |
| Start time 07:00 | | |
| Finish time 02:30 | | |
| Operational Times | | |
| Roller time 300 | | |
| Roller time off 300 | | |
| Number of times unit has been switched off | | |
| 4. Check PLC Override Functions | Override functions working correctly | |
| 5. Check Auger Motor and screw | Not applicable to this unit | |
| 6. Check FOG motor | OK | |
| 7. Check CIP function & overflow hose | Cleaned limescale build up blocking holes on CIP bar | |
| 8. Check Solenoid valve | OK | |
| 9. Check air vent on service pump | OK | |
| 10. Check air sensor valve & sensor tubing | Not applicable to this model | |
| 11. Check Pressure switch | Not applicable to this model | |
| 12. Check hopper | Not applicable to this model | |
| 13. Check FOG cartridge | OK | |
| 14. Check wiper blade | OK | |
| 15. Check for sediment at bottom of tank | Removed heavy sediment from tank | |
| 16. Check water level in tank | Static water level OK | |
| 17. Note any excessive tide level in tank | Tide level ok | |
| 18. Check inlet drainage, restrictions, support and invert levels | OK | |
| 19. Check outlet drainage, restrictions, support and invert levels | OK | |
| 20. Service access | OK | |
| 21. Check for leaks | OK | |

PARTS USED

| Qty | Part Number | Description | Quantity |
|------|-------------|---|----------|
| 1.00 | DEEPCLEAN | Deep Clean and Sterilisation of GreaseShield Unit | 1.00 |

SIGNATURES

Product Certifications



Industry Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
Estate, Hammond Avenue, South Reddish,
Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555





Customer Address Holiday Inn O'Connell Street
28-32 O'Connell Street
Dublin
Co. Dublin
Dublin 1

Contact

Telephone 00353 852071727

Ref Job 21469 Date 20/02/2023


Job Type **Deep Clean & Sterilisation**


Model: Serial:

Time In 13:00 Time Out 14:15

Engineer Darryl McConville, Patrick McEvoy

This service has been carried out in accordance with the manufacturer's recommendations.
For and on behalf of Environmental Products and Services Ltd.


Darryl mcconville


anna

Product Certifications

Industry
Certifications

Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
Estate, Hammond Avenue, South Reddish,
Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555

