

1. NOTES ON ALL DRAWINGS APPLY WHERE APPROPRIATE.

— — 300mm GALVANISED CABLE TRAY

ALUMINIUM TRUNKING MOUNTED ON UNISTRUT.

UNISTRUT TO BE PROVIDED UNDER THIS CONTRACT

FINAL CONNECTION USING PYC — COVERED FLEXIBLE CONDUIT. PROVIDED AND INSTALLED UNDER THIS CONTRACT.

AIR CONDITIONING OUTDOOR UNIT

'wт'

32 Amp IP66 ISOLATING SW MOUNTED ON UNI-STRUT UP STAND PROVIDED AND INSTALLED UNDER THIS CONTRACT.

3. EXACT POSITIONS & ELECTRICAL REQUIREMENT OF BUILDING MOUNTED ISSUAGE TO BE AGREED ON SITE WITH SHOWLE CONTROLLED VIA THE EXTERNAL LUERING PHOTOSELL AND AN OVERRIDE SWITCH SHALL BE INSTALLED AT RECEPTION.

DENOTES MOTORISED FIRE DAMPER PROVIDED UNDER MECHANICAL CONTRACT WITH POWER SUPPLY AND FIRE ALARM INTERACE UNIT PROVIDED UNDER THIS CONTRACT

2. THE FOLLOWING SYMBOLS DENOTE:-