

HOLIDAY INN EXPRESS O'CONNELL ST

M1421 Holiday Inn Express
O'Connell Street
Dublin 1
Ireland



Crystal Air
Unit 3
Butterstream, Business Park, Kildare
Ireland
Tel: 0035345893228
E-mail: service@crystalair.ie

J19403

Job is Completed

JOB DETAILS

SCHEDULED	JOB LEAD	CREW
17/07/2024, 09:20	Cian Doyle	

CLOSED BY OFFICE: Yes	CLOSED BY: Jessica	OFFICE JOB DESCRIPTION: Q2400637 - Holiday Inn Express O Connell Street - Recommendation to replace damaged drain pan assembly to bedroom 334 following site visit j18780.
JOB TYPE: Service Repair	MATERIALS USED: PO70506	MATERIALS TO BE QUOTED:
APPRENTICE REQUIRED/PRESENT: No	CUSTOMER PURCHASE ORDER NUMBER: PO Number For Invoicing	INVOICING CODE: Service (SR)

JOB DESCRIPTION

Q2400637 - Holiday Inn Express O Connell Street - Recommendation to replace damaged drain pan assembly to bedroom 334 following site visit j18780.
Replaced drain pan and left unit served with no leak.

WORK DETAILS

NAME	DESCRIPTION	QTY
H&S Short Risk Assessment & Method Statement Sign Off	Risk Assessment to be completed in advance of any works carried out	
Service Call	Task to be added to call out to allow Engineers Submit Pictures	
All Removable Panels Securely Fastned Prior to Leaving Site on all HVAC Assets	Task is assigned for Engineer to Double Check that all removeable Panels are securely fixed.	