

Customer: **Holiday Inn Express**

Site: **Holiday Inn Express**

Quote Ref: **Q10037**

FAO: **David Hurley**

PPM Date: **Aug 24**

PPM Visit: **2 of 2**

Date: **04/10/2024**

Plant Covered: **PPM Mechanical**

### **Repair Report:**

Following our recent visit, please see below quotation on repairs we recommend are carried out.

Repair No	Plant Asset	Repair/Materials	Cost
1.	Repair 1	Following on from the recent maintenance, we recommend replacing the expansion vessel on boiler No.1 as it has become faulty.	Total <b>€504.00</b>
2.	Repair 2	Following on from the recent maintenance, we recommend replacing the safety valve on boiler No.1 as it has become faulty.	Total <b>€588.00</b>

**Material & Labour Total €1,092.00 Excluding VAT**

### **Exclusions**

1. The Above Cost Excludes VAT
2. Quote Valid for 30 Days
3. Excludes out of hours works.

Quinn Downes Service & Maintenance, Unit h17, Centrepont Business Park, Oak Road, Dublin 12.

Tel: (01) 424 2424 Email: [service@quinndownes.com](mailto:service@quinndownes.com) [www.quinndownes.com](http://www.quinndownes.com)

Quinn Downes Service & Maintenance (Registered as Quinn Downes Ltd.), Derek Downes, Alan Carton Reg no. 555445. Vat no. 3321961FH

