

CASE SERVICE REPORT

CASE NO. 73770 **CASE TYPE** Electrical Private - Install

SALES ORDER SO60543 **CASE DETAILS** Holiday Inn - Remedial Works on Disabled Refuge

System

CUSTOMER DETAILS

ORDER DATE

CUSTOMER HOLI001 HOLIDAY INN (HOLI001) HOLIDAY INN

ADDRESS 28 - 32 O CONNELL STREET

DUBLIN 1 Ireland

19/4/2024

ASSET DETAILS

ADDRESS

ASSET NAME Holiday Inn O Connell St O Connell Street, Dublin, ,

PARTS & CHARGES

QUANTITY ITEM **DESCRIPTION BVOCECPG OMNICARE REMOTE GREEN** 3 **BVOCECPG** 3 INSTALL Installation 1 COMM Commissioning, Test & Verify - Day Rate

TASK NO. 4681669

SERVICE DATE: 25/4/2024 TECHNICIAN: Mick Martin TASK TYPE: Site Visit

FOLLOW UP RESULT

Job Completed

ACTIONS COMPLETED DURING SERVICE

Call out to replace/ repair 3x call points on call refuge. Replaced 2x call points replaced which cleared faults. Tested all points, all points calling in on right locations. System reset and left fault free. 1x call point left as spare for client.

SIGN OFF

Customer: Nuwan

Customer signature not entered