

Quinn Downes Service & Maintenance Unit H17, Centrepoint Business Park Oak Road, Dublin D12

P462 Email: service@quinndownes.com

Tel: 0142 42424 | 24 Emergency: 0818 252288

Job No:	14261	Date:	24/01/2024		
Customer:	Holiday Inn Express Dublin City Centre	Equipment Reference:			
Site / Building:	Holiday Inn Express Dublin City Centre	Equipment Serving:			
Address	Findlater House Ltd	Asset No:			
	28-32 O'Connell Street	Quote Required:	No		
		Repairs Report No:	0		
	D01 T2X2				

Job Description

Caller Advised there is a Major leak in the Lobby's Bathroom , Advised the leak is coming from the ceiling and its been happening all week Anna Foljusnikova 0877089815

Action Taken

On arrival asses leak in ground floor main toilet area hallway and inside door at gents toilots.

There was water coming down from ceiling.

On further investigation this water appeared to be coming down concrete wall rather than pipework.

With the hotel maintenance staff we poured buckets of water on an area up on the roof off hotel, and this water then came down concrete wall in ceiling into toilet area.

We checked all risers and pipework above this area and could not see any leak.

The hotel is going to get roof company out to investigate possible weatherproof issue up there.

As this leak only appears during heavy winds and rain.

Materials	Supplied

Material Qty

Follow Up Required

Job Completed Yes **Customers Signature**

FANAF

Engineers Signature

Donal Quinn Healy

Auxilliary Engineers Name/s

				Norm	Normal Hours		Overtime x (1.5)		Overtime x (2)	
Day	Date	In	Out	Eng.	Aux Eng.	Eng.	Aux Eng.	Eng.	Aux Eng	
Wednesday	24/01/2024	10:00	12:00	2	0	0	0	0	0	

















Quinn Downes Service & Maintenance Unit H17, Centrepoint Business Park Oak Road, Dublin D12
P462
Email: service@quinndownes.com
Tel: 0142 42424 | 24 Emergency: 0818 252288 **QUINN DOWNES**














































Quinn Downes Service & Maintenance

Unit H17, Centrepoint Business Park Oak Road, Dublin D12
P462
Email: service@quinndownes.com
Tel: 0142 42424 | 24 Emergency: 0818 252288

SERVICE & MAINTENANCE

I can confirm that I have undertaken the Risk Assessment

RISK ASSESSMENT

Falls From heights		Dust / Fumes / Solvents		Confined spaces	
Falling / Flying objects		Electricity		Spillages	
Heat / Fire / Explosion		Noise		Generation of waste	
Vehicle		Poor lighting		Risk of structural damage	
Slips / Trips / Falls		Use store equipment		Interference with trading	
Adverse weather		Asbestos		Machinery	
Infection Control / Hygiene		Other -			













