

ROUTINE MAINTENANCE SERVICE



SULZER PUMPS WASTEWATER IRELAND
RIVERVIEW BUSINESS PARK
NEW NANGOR ROAD, DUBLIN 12
TEL 01 4608888 FAX 01 4608889

ORDER NO. 917962

91565212

RMS Number	1498 08 18	Building Code	
Client	QUINNDOWNES		
Service Date	25/08/2023	Call out by	CLIENT / CONTACT
Site address	HOLIDAY INN EXPRESS 28-32 OCONNELL STREET UPPER, DUBLIN		
Contact	CAOIMHE		
Tel	01 4242424	E-Mail	

Issue Invoice to

System Details

Routine	<input type="checkbox"/>	Emergency	<input type="checkbox"/>	Warranty	<input type="checkbox"/>	RMS	<input checked="" type="checkbox"/>
Pump Qty	2	Sump Depth	2.5 METRE	Power	400 V	Medium	FOUL
Level control	HYDROSTATIC SENSOR		Control panel	CP212		Priority	
Pump Type	CONFORTO TYPE KM 400/80 -4T / AS0841.196-S22/4 EX-D01						
Serial Number Pump No.1	400/80-4	Hrs Run	189.02	Serial Number Pump No.2	300865225	Hrs Run	400.16
Application Description	FOUL PUMP STATION LOCATED IN CARPARK						

Service Report Details

Pump No.1	PUMP CHECKED AND TESTED ,MOTOR INSULATION OK ,OIL OK ,CABLE OK ,HYDRAULICS OK .PIPEWORK OK .						
PUMP OPERATING CORRECTLY .							
Stator Resis Ω	500	DI Resis Ω	N/A	Cable X or OK	OK	Lifting Chain	Y
Certified Y or N	Y						
Pump No.2	PUMP CHECKED AND TESTED ,MOTOR INSULATION OK ,OIL OK ,CABLE OK ,HYDRAULICS OK .PIPEWORK OK .						
PUMP OPERATING CORRECTLY .							
Stator Resis Ω	500	DI Resis Ω	N/A	Cable X or OK	OK	Lifting Chain	Y
Certified Y or N	Y						
Control Panel	ALL TERMINALS SECURE AND LAMPS WORKING OK .						
Sump condition	TANK APPEARS TO BE OK .						
Level Control	CALIBRATED HYDROSTATIC SENSOR ,ALL PARAMETERS ENGAGING CORRECTLY .						
Valves							
Fault Analysis	OK	Equipment OK	X	Requires Attention			

Estimated Cost Details

Part No	Description	Qty	Nett Price Subtotal
	RMS Service		

Service Engineer	MICHAEL BROWNE/ KEVIN CONWAY	On Time	Off Time
Clients Signature		Date	25/08/2023

ROUTINE MAINTENANCE SERVICE

SULZER

SULZER PUMPS WASTEWATER IRELAND
RIVERVIEW BUSINESS PARK
NEW NANGOR ROAD, DUBLIN 12
TEL 01 4608888 FAX 01 4608889

ORDER NO.

917962

91565212

RMS Number	1498 08 18	Building Code	
Client	QUINNDOWNES		
Service Date	25/08/2023	Call out by	CLIENT / CONTACT
Site address	HOLIDAY INN EXPRESS		
	28-32 OCONNELL STREET UPPER, DUBLIN		
Contact	CAOIMHE		
Tel	01 4242424	E-Mail	

Issue Invoice to

System Details

Routine	<input type="checkbox"/>	Emergency	<input type="checkbox"/>	Warranty	<input type="checkbox"/>	RMS	<input checked="" type="checkbox"/>
Pump Qty	2	Sump Depth	3 METRE	Power	400 V	Medium	FOUL
Level control	FLOATS X 4	Control panel	BPC PANEL	Priority			
Pump Type	XFP 80C CB1.1 PE 13/6						
Serial Number Pump No.1	399290	Hrs Run	N/A	Serial Number Pump No.2	399289	Hrs Run	N/A
Application Description	FOUL PUMP STATION LOCATED IN TANK ROOM						

Service Report Details

Pump No.1	PUMP CHECKED AND TESTED .MOTOR INSULATION OK ,OIL OK ,CABLE OK , HYDRAULICS OK ,SEAL AND BRACKET OK .								
PUMP OPERATING CORRECTLY .									
Stator Resis Ω	590	DI Resis Ω	590	Cable X or OK	OK	Lifting Chain	Y	Certified Y or N	Y
Pump No.2	PUMP CHECKED AND TESTED .MOTOR INSULATION OK ,OIL OK ,CABLE OK , HYDRAULICS OK ,BRACKET AND SEAL OK .								
PUMP OPERATING CORRECTLY .									
Stator Resis Ω	590	DI Resis Ω	590	Cable X or OK	OK	Lifting Chain	Y	Certified Y or N	Y
Control Panel	ALL TERMINALS SECURE AND LAMPS AND TRIPS WORKING OK .								
Sump condition	CRUST BUILD UP IN TANK ,TO BE CLEANED OUT .								
Level Control	FLOATS TESTED AND CHECKED .ALL OK .								
Valves									
Fault Analysis	OK	Equipment OK	X	Requires Attention					

Estimated Cost Details

Part No	Description	Qty	Nett Price Subtotal
	RMS Service		

Service Engineer	MICHAEL BROWNE / KEVIN CONWAY	On Time	Off Time
Clients Signature		Date	25/08/2023