

Customer Holiday Inn O'Connell Street
 Address 28-32 O'Connell Street
 Dublin
 Co. Dublin
 Dublin 1

Ref Job 21411 Date 14/02/2023
Job Type Maintenance Contract
 Model: GS1850 PF Serial: 207440
 Time In 12:05 Time Out 12:55
 Engineer Atanas Sotirov

Contact
 Telephone 00353 852071727

ACTUAL WORK DONE

Clean and check the unit

Description	Answer	Comments
1. Check LEDs	LEDs Operating correctly	
2. Check IP56 Socket, trip switch & fuses (if necessary)	All OK	
3. Check PLC Program	Program version V1.1	
Check PLC Time and dates:		
Start time 07:00		
Finish time 02:30		
Operational Times		
Roller time 300		
Roller time off 300		
Number of times unit has been switched off		
4. Check PLC Override Functions	Override functions working correctly	
5. Check Auger Motor and screw	Not applicable to this unit	
6. Check FOG motor	OK	
7. Check CIP function & overflow hose	OK	
8. Check Solenoid valve	OK	
9. Check air vent on service pump	Not applicable to this model	
10. Check air sensor valve & sensor tubing	Not applicable to this model	
11. Check Pressure switch	Not applicable to this model	
12. Check hopper	Not applicable to this model	
13. Check FOG cartridge	OK	
14. Check wiper blade	OK	
15. Check for sediment at bottom of tank	Removed heavy sediment from tank	
16. Check water level in tank	Static water level OK	
17. Note any excessive tide level in tank	Tide level ok	
18. Check inlet drainage, restrictions, support and invert levels	OK	
19. Check outlet drainage, restrictions, support and invert levels	OK	
20. Service access	OK	
21. Check for leaks	OK	

PARTS USED

Qty	Part Number	Description	Quantity
-----	-------------	-------------	----------

SIGNATURES

This service has been carried out in accordance with the manufacturer's recommendations.
 For and on behalf of Environmental Products and Services Ltd.

Product Certifications



Industry Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
 Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
 Estate, Hammond Avenue, South Reddish,
 Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555





Customer Address Holiday Inn O'Connell Street
28-32 O'Connell Street
Dublin
Co. Dublin
Dublin 1

Contact

Telephone 00353 852071727

Ref	Job 21411	Date	14/02/2023
Job Type	Maintenance Contract		
Model:	GS1850 PF	Serial:	207440
Time In	12:05	Time Out	12:55
Engineer	Atanas Sotirov		

Atanas Sotirov

anna

Product Certifications



Industry
Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,
Newry, Co. Down N. Ireland BT35 6EE
Tel: +44 (0) 28 3083 3081
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial
Estate, Hammond Avenue, South Reddish,
Stockport, Manchester, UK. SK4 1PQ
Tel: +44 (0) 161 477 5555

