



112 Grange Way, Baldoyle Industrial Estate,
D13 HD91
T. 01 831 4882 E. info@aceengineering.ie
www.aceengineering.ie

**SERVICE &
INSTALLATION
No. 30518**

DATE: 11-28-2023

Client:	Holiday Inn	Call Logged By:	
Site Address:	Oconnell street	Type of Door:	
	Dublin1 Dublin	Location:	
Site Contact:		Van Number:	5
Tel:		Customer Email:	

DESCRIPTION OF FAULT/ISSUE

issue with carpark shutter please attend

ENGINEERS NOTES

callout to shutter brought down on something.

they then brought the shutter up all the way causing it to get stuck and bag in the head.

managed to get shutter down and back into guide.

had to trim on lath that was stuck.

removed bag and tested.

shutter left in working order

DATE	ARRIVAL TIME	DEPARTURE TIME	DURATION
11-28-2023	28-Nov-2023 03:12 PM	28-Nov-2023 04:12 PM	1:00:01

Part Used	Part Description	Quantity
-----------	------------------	----------

I confirm that the above work has been carried out to my complete satisfaction and the safe operation of door has been explained to me in full.

FITTER SIGNATURE:

SIGNED BY CUSTOMER:

DATE: 11-28-2023

TECH COMMENTS: