

CERTIFICATE OF FIRE DAMPER TEST

Client: Holiday Inn Express Dublin City

Chief Engineer: David Hurley

Month of Test: September 2024

It is a requirement of **Annex 1 of BS 9999 - Routine inspection and maintenance of fire safety installations paragraph 1.7** (see below) that a certificate of fire damper test is obtained and this document serves as that certificate.

*“Arrangements should be made for annual inspections and performance tests of the following [.....] **e) fire dampers** to be carried out by competent persons, for any defects to be logged and the necessary action taken, and for certificates of testing to be obtained:”*

This document certifies that **349** fire dampers were located and/or reported on in **September 2024**, refer to the Fire Damper Test Report and Asset Register issued in July 2024 for details on individual damper and installation compliance.