

Customer Holiday Inn O'Connell Street  
 Address 28-32 O'Connell Street  
 Dublin  
 Co. Dublin  
 Dublin 1

Ref Job 18651 Date 14/11/2022  
**Job Type Maintenance Contract**  
 Model: GS 1000 PF Serial: 207839  
 Time In 11:50 Time Out 12:10  
 Engineer Darryl McConville

Contact  
 Telephone 00353 852071727

## ACTUAL WORK DONE

Unit cleaned out and service completed

Description	Answer	Comments
1. Check LEDs	LEDs Operating correctly	
2. Check IP56 Socket, trip switch & fuses (if necessary)	No IP56 socket	
3. Check PLC Program	Program version V5.5	
Check PLC Time and dates:		
Start time 07:00		
Finish time 02:30		
Operational Times		
Roller time 300		
Roller time off 300		
Number of times unit has been switched off		
4. Check PLC Override Functions	Override functions working correctly	
5. Check Auger Motor and screw	Not applicable to this unit	
6. Check FOG motor	OK	
7. Check CIP function & overflow hose	Cleaned limescale build up blocking holes on CIP bar	
8. Check Solenoid valve	OK	
9. Check air vent on service pump	OK	
10. Check air sensor valve & sensor tubing	OK	
11. Check Pressure switch	OK	
12. Check hopper	Cleaned heavy build up within hopper	
13. Check FOG cartridge	OK	
14. Check wiper blade	OK	
15. Check for sediment at bottom of tank	Removed light sediment from tank	
16. Check water level in tank	Static water level OK	
17. Note any excessive tide level in tank	Tide level ok	
18. Check inlet drainage, restrictions, support and invert levels	OK	
19. Check outlet drainage, restrictions, support and invert levels	OK	
20. Service access	OK	
21. Check for leaks	OK	

## PARTS USED

Qty	Part Number	Description	Quantity
-----	-------------	-------------	----------

## SIGNATURES

This service has been carried out in accordance with the manufacturer's recommendations.  
 For and on behalf of Environmental Products and Services Ltd.

### Product Certifications



### Industry Certifications



### Members of



### ISO Certifications



### Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,  
 Newry, Co. Down N. Ireland BT35 6EE  
**Tel:** +44 (0) 28 3083 3081  
**Email:** Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial  
 Estate, Hammond Avenue, South Reddish,  
 Stockport, Manchester, UK. SK4 1PQ  
**Tel:** +44 (0) 161 477 5555





Customer Holiday Inn O'Connell Street  
Address 28-32 O'Connell Street  
Dublin  
Co. Dublin  
Dublin 1

Contact

Telephone 00353 852071727

Ref Job 18651 Date 14/11/2022

**Job Type Maintenance Contract**

Model: GS 1000 PF Serial: 207839

Time In 11:50 Time Out 12:10

Engineer Darryl McConville

*Darryl McConville Anna*

Darryl mcconville

anna

Product Certifications



Industry  
Certifications



Members of



ISO Certifications



Environmental Products and Services Ltd

6 Shepherd's Way, Carnbane Industrial Estate,  
Newry, Co. Down N. Ireland BT35 6EE  
**Tel:** +44 (0) 28 3083 3081  
Email: Accounts@EPAS-Ltd.com

Unit 6, Phoenix Court, Whitehill Industrial  
Estate, Hammond Avenue, South Reddish,  
Stockport, Manchester, UK. SK4 1PQ  
**Tel:** +44 (0) 161 477 5555

**GreaseShield®**  
The Grease Management Solution

**FilterShield®**  
The Coffee Grinds Solution